

April 13, 1976

Mr. John O'Kieff, Chief  
Facilities Planning Staff  
Office of the Secretary  
Department of Health, Education,  
and Welfare  
330 Independence Avenue, S.W.  
Washington, D.C.

Dear Mr. O'Kieff:

At your request, a series of bulk and air samples for asbestos were collected in the South Portal Building on March 30, 1976. Per our telephone discussion, an analysis of six bulk insulation samples, in our Salt Lake City laboratory, did not show positive for asbestos in any instance. This being the case, the air samples were not analyzed. These results are presented in the attached Table.

It was a pleasure to work with Mr. Dan McFarland of your staff. If we can be of assistance in some other manner, or if you should have any questions, please do not hesitate to contact us.

Sincerely yours,

Kenneth J. Krudoveter  
Sr. Sanitary Engineer  
Hazard Evaluation and Technical  
Assistance Branch

Attachment

KJ KRUDOVETER/tc: 526 P. O. Bldg., Cinn. Ohio: 4/13/76

RESULTS OF SAMPLING FOR ASBESTOS  
IN  
DHEW SOUTH PORTAL BUILDING

MARCH 30, 1976

SAMPLE TYPE	LOCATION	ASBESTOS CONCENTRATION
Bulk	3rd floor, Room 350-G2	0%
Bulk	4th floor, Room 435-G8	0%
Bulk	5th floor, Executive Area	0%
Bulk	6th floor, Round Conference Room	0%
Bulk	7th floor, Executive Area	0%
Bulk	Penthouse, N.W. Quadrant	0%
Air	1st floor, Guard Station	Not Analyzed
Air	3rd floor, Room 326E	Not Analyzed
Air	3rd floor, Room 350-G2	Not Analyzed
Air	4th floor, Room 442E	Not Analyzed

---