

97. CHALLENGES IN DESIGNING A VENTILATION SYSTEM FOR UPSET CONDITIONS. F. Boelter, C. Schweiger, J. Ruhl, Boelter & Yates, Inc., Park Ridge, IL

A ventilation system was desired to control human comfort related to dust and heat in a chemical plant. During the initial evaluation, furfural vapors as well as dust and heat were evident. Initial estimates called for 250,000 cfm of local and general exhaust ventilation to meet the original objectives. However, the greatest return in employee protection was to focus on dust and heat control on the 2nd floor and to focus on the control of vapors in the basement. Employees were observed entering the basement while wearing an organic cartridge, full-face respirator. SCBAs were available for use during upset conditions; however, they were not used. The typical 1,000 gallon spill during an upset was composed not just of furfural but also of methanol, acetaldehyde, acetone and isobutyraldehyde. The sumps could return the majority of the spilled volume back to process lines within 15 minutes. However, the approximately 10 gallons of residual would evaporate and the area would need ventilation. Further, it was determined that acetaldehyde and not furfural would drive the ventilation design criteria. A dual stage 20,000 cfm ventilation system was designed which would operate in a step mode. Half the volume of exhaust would be drawn continuously during normal operations and respirators would not be needed. During an upset condition, the exhaust volume would automatically step up and thus meet the protection factor necessary if full-face respirators were used. In order to have this system be effective, process changes were also necessary. Therefore, reasonable process changes along with a reasonable ventilation system and a limited condition respiratory protection program were utilized to address an exposure condition unanticipated by the original objectives.

98. REAL-TIME HVAC FILTER EFFICIENCY TESTING USING OPTICAL PARTICLE COUNTERS. S. Berardinelli, S. Fotta, J. Hayes, E. Moyer, NIOSH, Morgantown, WV

The National Institute for Occupational Safety and Health (NIOSH) has undertaken a long-term performance test of heating, ventilation, and air-conditioning (HVAC) system filters. This testing is being conducted at the NIOSH facility in Morgantown, WV in an air handling unit (AHU) that services the animal quarters. The filtration needs of animal quarters are similar to that of a medical facility due to presence of immune compromised animals. The medium efficiency bag filters in this AHU have been replaced with higher efficiency mini-pleat V-Bank™ filters and have been monitored monthly for filtration efficiency since they were installed. This study required the development of a method to determine the

actual HVAC filtration efficiency using optical particle counters while the system was in operation. Grimm aerosol monitors with isokinetic sampling inlets were used to collect particle counts in 15 different particle size ranges from 0.30 μm to 20 μm . The challenge aerosol was the ambient particulate within the HVAC system. Instruments are placed upstream and downstream of the filter bank and data were collected over 56 days. From these data, filtration efficiency was determined for submicron to supermicron particles averaged over the sampling period. The results indicated the medium efficiency bag filters were 25% efficient for 0.35 μm diameter particles, 28% efficient for 0.45 μm particles, and 30% efficient for 0.57 μm particles. The new V-Bank™ filters were 70% efficient for 0.35 μm particles, 74% efficient for 0.45 μm particles, and 81% efficient for 0.57 μm particles. The V-Bank™ filters have provided superior filtration in the submicron range (for particles less than 1 μm) over that of the previous filters and have maintained this level of efficiency during our study.

99. A COMPARATIVE STUDY OF VARIOUS COMPUTATIONAL FLUID DYNAMICS MODELS FOR THE ASSESSMENT OF BREATHING ZONE SIZE. J. Richmond-Bryant, M. Flynn, University of North Carolina, Chapel Hill, NC

The majority of industrial hygiene studies incorporating computational fluid dynamics use the standard $k-\epsilon$ model with little explanation for model choice. In this study, five computational fluid dynamics models were compared with experimental data for their ability to reproduce the size of the breathing zone, defined here as the time-averaged two-dimensional recirculation zone formed downstream of the body in a uniform flow induced by a hood. This definition for breathing zone was applied because the time-averaged flow streamlines in the recirculation zone circulate along the centerline towards the body. A two-dimensional circular cylinder was used to represent the body. For comparative purposes, all quantities considered were normalized by the diameter of the body. Results from four turbulence models (standard $k-\epsilon$, extended $k-\epsilon$, renormalized group $k-\epsilon$, and anisotropic $k-\epsilon$) and one vortex model were compared with experimental data acquired at $Re = 5,232$. Key features of the breathing zone, such as centerline length and angle of separation from the body were used for comparison between the models and the experimental data. For normalized centerline length, three of the four $k-\epsilon$ models (standard, extended, and renormalized group) fell within the confidence bound measured experimentally, [1.59, 2.42]. For the vortex method, convergence with respect to breathing zone length could not be proven; therefore, no comparison could be drawn with the experimental data. All of the $k-\epsilon$ models predicted separation angles ranging from 120°-130°; hence, the $k-\epsilon$ models underpredicted the normalized breath-

ing zone width by 12-23%. The vortex method predicted the wake width with negligible error; however, unless convergence is attained with respect to the breathing zone length, this finding is preliminary. It is important to point out that the behavior discussed for each model refers only to the flow analyzed here, and not necessarily for airflow with different turbulence properties.

100. FILTER EFFICIENCY OF SELECTED HVAC FILTERS. E. Moyer, M. Commodore, J. Hayes, S. Fotta, NIOSH, Morgantown, WV

Air quality begins with good engineering controls in the air handling system (HVAC system). For particulate matter this involves having an air handler containing filters which remove the majority of particulate matter from the incoming ambient air. The National Institute for Occupational Safety and Health (NIOSH) has conducted a study of various bag filters used in its air handler to determine the filtration efficiency of these filters against submicrometer particles (0.03-0.4 micrometers) because this is in the most penetrating size range for these filters. Experimental aerosol penetration data shows that an extremely large range of filter efficiency exists. Aerosol penetration through new filters ranged from less than one percent to greater than ten percent were observed. The values depend on flow rate, surface area of the media, challenge agent particle size, and challenge agent state (liquid or solid). Filters which were removed from the filter bank were also tested to determine the effect of routine inlet air exposure. The filter efficiency of the exposed filters (9 months of use) showed that the six chamber filters had penetrations of from 40% to 60% as compared to the control which had less than 1.5% penetration. Similarly the twelve chamber filters had penetrations ranging from 25% to 50% when compared to the control filters penetrations of less than 3.0% penetration. As expected there was a shift in most penetrating aerosol particle size toward the larger size range which is an extreme disadvantage for filters employed in this application. Both mechanical and electrostatic filters are used in this application. The filtration mechanisms of the various filters tested were evaluated to ascertain the cause of this phenomenon. The electrostatic filters are showing a significant reduction in filter performance over the expected service lifetime of the filters.

101. REDUCED-SCALE MODELING OF A FREESTANDING EXHAUST HOOD. K. Mead, NIOSH, Cincinnati, OH; D. Johnson, N. Esmen, M. Phillips, University of Oklahoma, Oklahoma City, OK

Local exhaust ventilation (LEV) design equations do not normally account for worker presence, varying cross-drafts, or turbulence. In recognition, the American Society of Heating, Refrigerating and Air-Conditioning

The Premier Conference for Occupational and Environmental Health
and Safety Professionals

POWERFUL PARTNERSHIPS

Leveraging the power of collaboration to expand knowledge



ABSTRACTS



American Industrial Hygiene Conference & Expo

Cosponsored by AIHA and ACGIH®

June 1–6, 2002, San Diego Convention Center, San Diego, California

NIOSH LIBRARY SYSTEM

ALICE HAMILTON LIBRARY
4676 COLUMBIA PARKWAY
CINCINNATI, OH 45226

2002 Abstract Index by Session Topic



Platform Session Topic	Abstract No.
Aerosols	157-164
Agricultural Health and Safety	1-6
Air Sampling Instrument Performance	79-86
Bioaerosols	165-173
Biological Monitoring	56-66
Community Environmental Health and Safety Issues and Social Concerns	121-126
Computer Applications in Industrial Hygiene	270-280
Construction and Equipment	218-223
Contaminant Control	140-147
Current Topics in Noise and Hearing Loss	32-38
Dermal Exposures	174-184
Ergonomics Intervention	67-72
Exposure Assessment Strategies I	39-46
Exposure Assessment Strategies II	210-217
Gas & Vapor Detection	127-132
Health Care	112-120
Indoor Environmental Quality	242-250
Industrial Hygiene General Practice	251-262
International Occupational Hygiene	232-241
Investigating Community Air Quality	203-209
Ionizing and Nonionizing Radiation Risks: Measuring the Exposure	13-18
Laboratory Health and Safety	87-94
Lead I	103-111
Lead II	263-269

Platform Session Topic	Abstract No.
Management/Leadership	224-231
Occupational Epidemiology	25-31
Occupational Ergonomics: Training and Risk Assessment	7-12
Occupational Medicine/Occupational Epidemiology	148-156
Personal Protective Clothing and Equipment	133-139
Regulating the Right Hazards Rightly	19-24
Respiratory Protection	185-195
Risk Assessment in Industry and of Terrorism's Aftermath	196-202
Testing for Air Quality in the Garage	73-78
Toxicology and Toxicology Models (PBPK and QSAR)	47-53, 53.1-55
Ventilation	95-102

Poster Sessions	Abstract No.
Poster Session 501	327-356
Poster Session 502	357-384
Poster Session 503	385-413
Poster Session 504	414-442

Case Study Sessions	Abstract No.
Case Study 301	281-292
Case Study 302	293-303
Case Study 303	304-310
Case Study 304	311-314, 317-318
Case Study 305	319-326

PF 101 Agricultural Health and Safety

Papers 1-6

1. RELATIONSHIPS BETWEEN WORK EXPOSURE AND RESPIRATORY OUTCOMES IN POULTRY WORKERS.

S. Kirychuk, J. Dosman, P. Willson, L. Dwernychuk, University of Saskatchewan, Saskatoon, SK, Canada; J. Feddes, A. Senthilselvan, C. Ouellette, University of Alberta, Edmonton, AB, Canada

A pilot study was conducted on 74 poultry barn workers in Western Canada during the winters of 1998-2000. General respiratory health, current, chronic and work related respiratory symptoms; general work duties, and work-site factors were ascertained, pre-exposure, by questionnaire. Personal airborne exposure levels and changes in symptoms and lung function were measured across the work-shift for all workers. Workers were classified according to the type of poultry operation (floor based, n=53; cage based, n=13) in which they worked. There was no significant difference in daily hours spent in the barn between those who worked with caged poultry (5.41±2.35 hours) and those who worked with floor-based poultry (4.42±2.48 hours). Age of birds was 47.10±58.36 days for floor based versus 155.91±63.01 days for cage based facilities.

There were no significant differences in personal environmental measurements between cage-based and floor-based facilities (ammonia 13.22±13.70 ppm, 17.34±16.35 ppm; total dust 5.74±4.85mg/m³, 10.01 ±8.84 mg/m³; endotoxin 6046±6089 EU/m³, 5457±5934 EU/m³ respectively). There were no significant differences in across work-shift change in pulmonary function indices between workers from cage and floor-based operations. For the entire sample total dust dose (work hours/day x total dust) significantly correlated with across-shift change in FEV₁, whereas endotoxin dose and ammonia dose did not. Stocking density was significantly correlated with average ammonia (ppm, p=0.002) and ammonia dose (ppm x work hours/day; p=0.004) in floor based operations and with total dust (particles/ml, p=0.002) in cage based populations. Stocking density was also significantly correlated with chronic cough (p=0.003) and across work-shift cough (p=0.05) and chest tightness (p=0.06) for workers from floor based operations; and with phlegm when working (p=0.018) and chest tightness across the work-shift (p=0.004) for workers from cage based operations. Type of poultry production operation and therefore type of work exposures appear to significantly impact symptoms experienced by workers exposed to these atmospheres.

2. DUST GENERATION SYSTEM FOR AGRICULTURAL SOIL DUST. K. Lee, R. Domingo-Neumann, R. Southard, UC Davis, Davis, CA

Agricultural workers are prone to exposure to mixed dust of inorganic and organic compounds. Diverse working conditions and operations in agriculture make direct measurements of the mixed dust exposure difficult. This study was conducted to develop a new dust generation system to determine possible exposure potency indicators of soil samples. The dust generator consists of a blower, a rotating chamber and a settling chamber. The rotating chamber has inner baffles to provide sufficient agitation of the samples while the chamber is rotating. A blower provides air into the rotating chamber, and the suspended dust is moved to the settling chamber through a perforated pipe. A small fan inside the settling chamber helps maintain suspension of the dust. Various size fractions of dust are sampled on filters suspended in the chamber via outlet ports and attached pumps. Air pressure is released through a filter plate mounted on the wall of the settling chamber. Various operating conditions were evaluated: air intake from blower, speed of rotation, soil mass and sampling time. To evaluate the characteristics of dust from the system, we collected dust samples from agricultural fields while the soil was prepared for