

remediation activities at the seven study sites could only be estimated (~10,000 in 1996). Radiologic exposure histories for these workers are reasonably comprehensive due to standardized monitoring practices. However, industrial hygiene, medical, and personnel data collection and reporting are not standardized and tend to be incomplete.

NIOSH identified that considerable changes are needed in the collection and maintenance of work, exposure, and medical history data. Examples include the development of a centralized remediation worker data base and standardized industrial hygiene data collection and reporting programs. Such changes will facilitate the conduct of future surveillance efforts and epidemiologic studies.

### **344. QUALITATIVE EXPOSURE ASSESSMENTS IN THE ADJUDICATION OF WORKERS' COMPENSATION CLAIMS FOR OCCUPATIONAL DISEASES: ROLE OF OCCUPATIONAL HYGIENISTS.**

D. Chung, C. St. Pierre, WSIB, Toronto, ON, Canada

**Introduction:** In 1999, the WSIB adjudicated approximately 100,000 lost-time claims. Only 4.4% of these claims were attributed to exposure to a harmful substance. However, the cost associated with these claims accounted for an estimated 20% of the total compensation cost. To adjudicate occupational disease claims 2 essential pieces of information are required, a medical diagnosis and the exposure profile for the worker. Prior to 2001 few occupational disease claims at the WSIB were adjudicated with the aid of dedicated occupational hygienists.

**Scope of problem:** To provide exposure profiles the Hygienist must reconstruct the conditions and possible exposures for work processes that were in operation years and sometimes decades in the past. These exposure assessments can encounter a myriad of challenges such as: lack of access to the worker, changes to the work environment, lack of historical processes information and credible sampling data and complex work histories. Often traditional exposure assessment techniques such as sampling are not possible. Therefore, a qualitative approach is often utilized.

**Methods:** Exposure assessments are conducted in manufacturing work sites to ascertain claimants' exposures to a variety of chemical substances present at these facilities. Tools used to conduct these assessments included: interview of retired co-workers and family, union seniority lists, historical SOP, regulatory inspection reports and process and exposure information from sources such as NIOSH, the EPA and OSHA. Risk maps are drawn to mark the locations in the workplaces where processes and potential hazards were found. All the information gathered is then summarized to obtain exposure risk rating for different substances by process, job, tasks, time period and work site factors. Exposures are rated for their potential/intensity, frequency, duration, and

certainty. This information is then linked to the work history of the worker to obtain personal exposure estimates.

### **345. USE OF SWALLOWABLE CORE BODY TEMPERATURE SENSORS AND OTHER MEASURES FOR A HEAT STRESS EVALUATION OF EMPLOYEES OF A SOUTHWESTERN U.S. PARK.** A. Krake, NIOSH, Cincinnati, OH

Because of working conditions of high heat stress and moderate to extreme physical exertion, the potential for the development of heat stress prompted southwestern U.S. park managers to request NIOSH assistance. In response, NIOSH investigators evaluated heat stress and strain among park service personnel using swallowable core body temperature (CBT) sensors, external heart rate monitors, and WBGT monitors. Pre- and post-shift weight comparisons were made and changes in blood chemistries were determined. In addition, job activities were analyzed according to metabolic heat production estimates. ACGIH suggests a maximum CBT of 101.3°F for medically selected, acclimatized personnel and 100.4°F for unselected, unacclimatized personnel. For individuals with normal cardiac performance, sustained heart rate (over several minutes) should not exceed 180 beats per minute (bpm) minus age. Chronic demands placed on the body were evaluated by calculating the average heart rate for the entire activity, which should not exceed 115 bpm. Finally, there is a greater risk of heat strain if profuse sweating is sustained over hours, so weight loss over a shift should not exceed 1.5% of body weight. NIOSH work/rest regimen tables were used to plot the estimated metabolic heat against the environmental heat measurements. On all but two days (of eight), WBGT temperatures exceeded 90°F, with a high of 98.8°F. Dry bulb temperatures exceeded 109°F every day, with a high of 122.5°F. Physiological sampling results indicated that every study participant experienced heat strain to some degree. Most of the participants developed mild dehydration during their activities, but their electrolytes remained within normal limits. Body weight comparisons showed an average loss of 1.2% among participants. Metabolic heat production estimates showed most activities were close to or exceeded the parameters of the NIOSH work/rest regimen. Recommendations were made to develop heat stress management and illness surveillance systems.

### **Indoor Air Quality** *Papers 346-350*

### **346. THE RELATIVE CONTRIBUTION OF THE HVAC SYSTEM TO THE TOTAL FIBER BURDEN IN INDOOR SPACES.** W. Thomann, J. Tulis, E. Chen, Duke University, Durham, NC

The HVAC system is frequently cited as a primary source of fibers in indoor spaces, particularly if the system has internal fiberglass insulation. On-going studies, using NIOSH Method 7400 A, are being conducted to provide quantitative data on the relative contribution of the ventilation system per se to the total fiber burden. The HVAC systems evaluated include both internally and externally insulated ductwork. The relative contribution of the HVAC system to the total fiber burden is determined by collecting samples at the supply air diffuser using a tent-like enclosure to shield the sample from the room environment. Concurrent samples of the room air are then compared to the supply diffuser information. Additional studies to assess potential emission or removal of fibers within the HVAC system have been conducted by collecting "isolated" samples at various sites within the air handling unit, namely, the outdoor air intake, the return air plenum, and the post-filtration area. These samples were collected using an engineered orifice that is sized for isokinetic sampling of the airstream. Microscopic analysis of the samples allows characterization between natural and synthetic vitreous fibers (SVF). The supply diffuser fiber counts in one study of laboratory buildings averaged 0.00036 fibers/cc in externally insulated systems and 0.00048 fibers/cc in internally insulated duct systems. The average count in a similar study of office buildings was 0.0107 fibers/cc in internally insulated duct systems (no externally insulated systems were evaluated). SVF were not detected in many of the samples in both studies and the average concentration of SVF was 0.00015 fibers/cc. These studies suggest both that SVF constitute a minor component of the total fiber count in occupied spaces and that the air distribution system is not a significant source of fiber emissions into the indoor environment.

### **347. HVAC SYSTEM EVALUATION-AN INITIAL RESPONSE TO IAQ COMPLAINTS.** V. Ivensky, T. May, Urban Engineers, Inc., Philadelphia, PA; B. Scott, K. Banks, City of Philadelphia, Philadelphia, PA

The evaluation of HVAC systems on the initial stages of an IAQ investigation and prompt correction of identified problems can quickly alleviate IAQ complaints and avoid costly and often inconclusive air sampling efforts. Typical HVAC problems may include design or construction flaws, history of poor maintenance with associated problems, lack of minimum outside air supply, improperly selected filters, improperly positioned thermostats, or building renovations with no regard to HVAC system design. Recent IAQ investigations conducted by the authors in large, multi-use public buildings identified several such concerns related to HVAC systems. Problems that caused the most widespread IAQ complaints were: inadequate return ventilation, entrapment of contaminated air by return and induction systems, incorrect

The Premier Conference for Occupational and Environmental Health  
and Safety Professionals

# POWERFUL PARTNERSHIPS

Leveraging the power of collaboration to expand knowledge



## ABSTRACTS



**American Industrial Hygiene Conference & Expo**

Cosponsored by AIHA and ACGIH®

**June 1–6, 2002, San Diego Convention Center, San Diego, California**

**NIOSH LIBRARY SYSTEM**

ALICE HAMILTON LIBRARY  
4676 COLUMBIA PARKWAY  
CINCINNATI, OH 45226

# 2002 Abstract Index by Session Topic



Platform Session Topic	Abstract No.	Platform Session Topic	Abstract No.
Aerosols . . . . .	157-164	Management/Leadership . . . . .	224-231
Agricultural Health and Safety . . . . .	1-6	Occupational Epidemiology . . . . .	25-31
Air Sampling Instrument Performance . . . . .	79-86	Occupational Ergonomics: Training and Risk Assessment . . . . .	7-12
Bioaerosols . . . . .	165-173	Occupational Medicine/Occupational Epidemiology . . . . .	148-156
Biological Monitoring . . . . .	56-66	Personal Protective Clothing and Equipment . . . . .	133-139
Community Environmental Health and Safety Issues and Social Concerns . . . . .	121-126	Regulating the Right Hazards Rightly . . . . .	19-24
Computer Applications in Industrial Hygiene . . . . .	270-280	Respiratory Protection . . . . .	185-195
Construction and Equipment . . . . .	218-223	Risk Assessment in Industry and of Terrorism's Aftermath . . . . .	196-202
Contaminant Control . . . . .	140-147	Testing for Air Quality in the Garage . . . . .	73-78
Current Topics in Noise and Hearing Loss . . . . .	32-38	Toxicology and Toxicology Models (BPBK and QSAR) . . . . .	47-53, 53,1-55
Dermal Exposures . . . . .	174-184	Ventilation . . . . .	95-102
Ergonomics Intervention . . . . .	67-72		
Exposure Assessment Strategies I . . . . .	39-46	<b>Poster Sessions</b>	<b>Abstract No.</b>
Exposure Assessment Strategies II . . . . .	210-217	Poster Session 501 . . . . .	327-356
Gas & Vapor Detection . . . . .	127-132	Poster Session 502 . . . . .	357-384
Health Care . . . . .	112-120	Poster Session 503 . . . . .	385-413
Indoor Environmental Quality . . . . .	242-250	Poster Session 504 . . . . .	414-442
Industrial Hygiene General Practice . . . . .	251-262		
International Occupational Hygiene . . . . .	232-241	<b>Case Study Sessions</b>	<b>Abstract No.</b>
Investigating Community Air Quality . . . . .	203-209	Case Study 301 . . . . .	281-292
Ionizing and Nonionizing Radiation Risks: Measuring the Exposure . . . . .	13-18	Case Study 302 . . . . .	293-303
Laboratory Health and Safety . . . . .	87-94	Case Study 303 . . . . .	304-310
Lead I . . . . .	103-111	Case Study 304 . . . . .	311-314, 317-318
Lead II . . . . .	263-269	Case Study 305 . . . . .	319-326

## PF 101 Agricultural Health and Safety

Papers 1-6

### 1. RELATIONSHIPS BETWEEN WORK EXPOSURE AND RESPIRATORY OUTCOMES IN POULTRY WORKERS.

S. Kirychuk, J. Dosman, P. Willson, L. Dwernychuk, University of Saskatchewan, Saskatoon, SK, Canada; J. Feddes, A. Senthilselvan, C. Ouellette, University of Alberta, Edmonton, AB, Canada

A pilot study was conducted on 74 poultry barn workers in Western Canada during the winters of 1998-2000. General respiratory health, current, chronic and work related respiratory symptoms; general work duties, and work-site factors were ascertained, pre-exposure, by questionnaire. Personal airborne exposure levels and changes in symptoms and lung function were measured across the work-shift for all workers. Workers were classified according to the type of poultry operation (floor based, n=53; cage based, n=13) in which they worked. There was no significant difference in daily hours spent in the barn between those who worked with caged poultry (5.41±2.35 hours) and those who worked with floor-based poultry (4.42±2.48 hours). Age of birds was 47.10±58.36 days for floor based versus 155.91±63.01 days for cage based facilities.

There were no significant differences in personal environmental measurements between cage-based and floor-based facilities (ammonia 13.22±13.70 ppm, 17.34±16.35 ppm; total dust 5.74±4.85mg/m<sup>3</sup>, 10.01 ±8.84 mg/m<sup>3</sup>; endotoxin 6046±6089 EU/m<sup>3</sup>, 5457±5934 EU/m<sup>3</sup> respectively). There were no significant differences in across work-shift change in pulmonary function indices between workers from cage and floor-based operations. For the entire sample total dust dose (work hours/day x total dust) significantly correlated with across-shift change in FEV<sub>1</sub>, whereas endotoxin dose and ammonia dose did not. Stocking density was significantly correlated with average ammonia (ppm, p=0.002) and ammonia dose (ppm x work hours/day; p=0.004) in floor based operations and with total dust (particles/ml, p=0.002) in cage based populations. Stocking density was also significantly correlated with chronic cough (p=0.003) and across work-shift cough (p=0.05) and chest tightness (p=0.06) for workers from floor based operations; and with phlegm when working (p=0.018) and chest tightness across the work-shift (p=0.004) for workers from cage based operations. Type of poultry production operation and therefore type of work exposures appear to significantly impact symptoms experienced by workers exposed to these atmospheres.

### 2. DUST GENERATION SYSTEM FOR AGRICULTURAL SOIL DUST. K. Lee, R. Domingo-Neumann, R. Southard, UC Davis, Davis, CA

Agricultural workers are prone to exposure to mixed dust of inorganic and organic compounds. Diverse working conditions and operations in agriculture make direct measurements of the mixed dust exposure difficult. This study was conducted to develop a new dust generation system to determine possible exposure potency indicators of soil samples. The dust generator consists of a blower, a rotating chamber and a settling chamber. The rotating chamber has inner baffles to provide sufficient agitation of the samples while the chamber is rotating. A blower provides air into the rotating chamber, and the suspended dust is moved to the settling chamber through a perforated pipe. A small fan inside the settling chamber helps maintain suspension of the dust. Various size fractions of dust are sampled on filters suspended in the chamber via outlet ports and attached pumps. Air pressure is released through a filter plate mounted on the wall of the settling chamber. Various operating conditions were evaluated: air intake from blower, speed of rotation, soil mass and sampling time. To evaluate the characteristics of dust from the system, we collected dust samples from agricultural fields while the soil was prepared for