

Information Circular 8901

Real-Time Calculation of Product-of-Combustion Spread in a Multilevel Mine

By John C. Edwards and Rudolf E. Greuer



UNITED STATES DEPARTMENT OF THE INTERIOR

James G. Watt, Secretary

BUREAU OF MINES

Robert C. Horton, Director

This publication has been cataloged as follows:

Edwards, John C

Real-time calculation of product-of-combustion spread in a multi-level mine.

(Information circular : United States Department of the Interior, Bureau of Mines ; 8901)

Includes bibliographical references.

Supt. of Docs. no.: I 28.27:8901.

I. Mine fires--Data processing. 2. Mine ventilation--Data processing. 3. Combustion gases--Data processing. 4. FORTRAN (Computer program language). 5. Real-time data processing. I. Greuer, Rudolf E. II. Title. III. Series: Information circular (United States. Bureau of Mines) ; 8901.

TN295.U4 [TN315] 622s [622' 8] 82-600293

CONTENTS

	<u>Page</u>
Abstract.....	1
Introduction.....	2
Input data preparation.....	4
Network input.....	4
Concentration input.....	4
Real-time input.....	5
Tables 1-13.....	5
Applications.....	10
Fuel-rich fire in a downcast shaft.....	11
Fuel-rich fire in a downcast shaft with a fan failure.....	11
Conclusion.....	13
Explanation of appendixes.....	14
Appendix A.--Listing of computer program.....	15
Appendix B.--Input data for fuel-rich fire in a downcast shaft.....	76
Appendix C.--Output data for fuel-rich fire in a downcast shaft calculation....	79
Appendix D.--Input data for fuel-rich fire in a downcast shaft calculation with fan failure.....	91
Appendix E.--Output data for fuel-rich fire in a downcast shaft calculation with fan failure.....	94

ILLUSTRATIONS

1. Base schematic of small multilevel mine with an exhaust fan and booster fan.....	10
2. Schematic of flow reversal in small multilevel mine with failure of exhaust fan.....	12

TABLES

1. Network control card.....	6
2. Airway cards.....	6
3. Junction cards.....	7
4. Fan characteristic card 1.....	7
5. Fan characteristic card 2.....	7
6. Additional airway cards.....	7
7. Concentration control card.....	8
8. Average value card.....	8
9. Additional concentration airway cards.....	8
10. Additional concentration junction cards.....	8
11. Contamination cards, steady-state input.....	9
12. Real-time control card.....	9
13. Contamination cards, real-time input.....	9



REAL-TIME CALCULATION OF PRODUCT-OF-COMBUSTION SPREAD IN A MULTILEVEL MINE

By John C. Edwards¹ and Rudolf E. Greuer²

ABSTRACT

A computer program, developed for the Bureau of Mines under contract, predicts in a quasi-steady-state approximation the ventilation and contaminant concentrations and temperatures when a fire occurs in a multilevel mine. For periods of time in which there is no significant change in the ventilation, yet a fire is producing fumes, a real-time fume concentration throughout the mine is calculated. Multiple and time-variable contaminant sources can be simulated. Recirculation paths that can develop provide a mechanism for increasing the fume concentration in the mine network and are identified by the computer program. This report contains a listing of the Fortran computer program as well as the required format of the input data. Two examples are provided of the real-time spread of smoke from a fuel-rich fire throughout a multilevel mine. The first example considers an operational exhaust fan as well as a booster fan. The second example evaluates the real-time smoke spread following a failure in the exhaust fan; recirculation occurs in this latter case.

¹Physicist, Pittsburgh Research Center, Bureau of Mines, Pittsburgh, Pa.

²Professor of mining engineering, Michigan Technological University, Houghton, Mich.

INTRODUCTION

The successful planning of miner escape and rescue measures in the event of a fire in a mine, as well as the implementation of a fire detection system, is contingent upon the capability to predict the time-dependent concentration of the products of combustion in the mine network. Michigan Technological University (MTU)³ has developed for the Bureau of Mines under contract JO285002 a computer program for the real-time spread of fumes throughout a multilevel mine network. The program is a combination of an earlier program⁴ developed by MTU, that was restructured for steady-state analysis⁵ with a real-time modification and a program modification that gives the user the choice of using a least squares representation of the fan characteristic data as an alternative to a Lagrange interpolation of the fan data.

The computation procedure accounts for airway resistances, interaction of fans, and thermal exchange with the airway walls. The buoyancy induced natural ventilation is calculated directly from the airway temperatures, which change in a quasi-steady-state manner owing to thermal diffusion into the airway walls. The fire is quantified by its heat production in determining the effects of natural

ventilation. Discussion of the program capability was reported earlier.⁶

This report furnishes the user a complete listing of the mine ventilation computer program for a real-time calculation of contaminant spread throughout a multilevel mine network. Instructions are provided on how to prepare the data, and two sample calculations are presented.

The mine ventilation computer program is used to simulate airflow in a multilevel mine network by designating each junction (crosscut and intersection) and branch (airway) with an identification number. The program internally forms closed paths (meshes) throughout the network. The conservation of energy is applied to each mesh, and the conservation of mass is applied to each junction. The program iteratively develops solutions to the airflow rates and temperatures throughout the mine. In the case where one or more fires are simulated, the program calculates the smoke concentration in each airway in the steady-state mode based upon an airflow rate computed for a fixed time after the inception of the fire. These airflow rates are further utilized to calculate the smoke spread throughout the mine network under the condition of one or more fires of various durations.

The real-time concentration calculation performed by the computer program assumes a steady ventilation flow. This is a reasonable approximation for fires in their incipient stage of growth. In this early stage changes occur primarily in the immediate vicinity of the fire. There are three ways to characterize the fire in an airway: (1) a specified

³Greuer, R. E. Real-Time Precalculation of the Distribution of Combustion Products and Other Contaminants in the Ventilation System of Mines. Final Report to Bureau of Mines (Contract JO285002 by Michigan Technological University). BuMines OFR 22-82, March 1981, 261 pp.; NTIS PB 82-183104.

⁴Greuer, R. E. Study of Mine Fires and Mine Ventilation. Part I. Computer Simulation of Ventilation Systems Under the Influence of Mine Fires. BuMines OFR 115(1)-78, October 1977, 162 pp.; NTIS PB 288 231/AS.

⁵Computer Sciences Corp. Computer Simulation of Ventilation Systems Under the Influence of Mine Fires. Program Users Manual and Program Maintenance Manual, 1980; prepared for the Bureau of Mines under GSA Contract GS-045-22715.

⁶Edwards, J. C. Computer-Aided Ventilation Modeling. Paper in underground Metal and Nonmetal Mine Fire Protection. BuMines IC 8865, 1981, pp. 78-85. Proceedings: Bureau of Mines Technology Transfer Seminars, Denver, Colo., Nov. 3, 1981, and St. Louis, Mo., Nov. 6, 1981.

concentration and heat input, (2) the oxygen concentration of the fumes that leave the fire zone, or (3) the fume and heat production associated with the oxygen delivered to the fire. Options 2 and 3 correspond to oxygen-rich and fuel-rich fires respectively.

The real-time computational feature of the computer program enables the user to discriminate between (1) airways that have subcritical product-of-combustion concentrations for a period of time adequate for rescue measures before reaching a critical level of concentration, and (2) airways that remain subcritical for long times. The word "critical" is applied to those airways that are unsafe for human survival.

In addition to a time-dependent evaluation of the product-of-combustion hazard throughout the mine network, the program can be used to evaluate the total exposure a miner receives while waiting for rescue in a specified airway.

The computational procedure for the network computation is explained elsewhere,⁷ as is that for the real-time fume (product of combustion, contaminants).⁸ To facilitate the real-time concentration calculation, the program generates control volumes of homogeneous contaminant concentrations that advance with the flow throughout the mine network. When two or more control volumes meet at a junction, a new control volume leaves the junction with a concentration determined by conservation of mass at the junction.

As part of the computer output, the terms "fumes" and "waves" are used. "Fumes" represents contaminated air, and "waves" represents the boundary between moving control volumes with different concentrations.

Waves are introduced to enable the program user to monitor the spread of contaminated air throughout the network.

When contaminated air enters an airway at the starting junction of an airway with otherwise fresh air, the wave marks the interface between the contaminated and the fresh air. The wave travels with the airflow velocity in the airway and is identified with a number. When two waves of different concentration meet at a junction and further contamination or dilution occurs, a new wave is used to characterize the resultant contaminant concentration. In this manner, one or more waves are generated. The output of the program execution identifies in ascending order those airways that have contaminated air by the highest wave number for the airway, the concentration (volume-percent) of the contaminated air behind the front of the wave, and the starting time for the wave. Subsequent output specifies the start and arrival time and concentration for the last five waves generated. The number of waves generated depends upon the complexity of the ventilation system. If recirculation occurs, then potentially an infinite number of waves can be generated. The wave generation process is suspended when the difference between the concentration associated with two sequential waves becomes less than a user-specified threshold, designated CRITSM in the data input. A more detailed explanation of the wave generation mechanism is available.⁹

The program has a limitation of a maximum of five waves that can be stored per airway. If more than five waves are stored, wave compaction occurs through the removal of the excess waves and the advancement of the data in the remaining waves in the storage by the number of deleted waves.

The following section gives an overview of the structure of the input data and explains how to prepare the input data for a real-time calculation. This is followed by a section that presents the results of two sample calculations. A listing of the Fortran computer program is supplied in appendix A.

⁷Work cited in footnote 4.

⁸Work cited in footnote 3.

⁹Work cited in footnote 3.

INPUT DATA PREPARATION

There are three major sections of the input data: (1) network input, (2) concentration input, and (3) real-time input.

NETWORK INPUT

The network input furnishes a basic description of the mine network including the fan characteristic data and physical dimensions, airflow resistance, and thermal properties of the airways. This section controls the type of calculation requested, i.e., network airflow rates with or without concentration and temperature calculations. The following data cards are included: network control card, airway cards, junction cards, fan characteristic cards, and additional airway cards. (Tables 1-6, which illustrate these cards, appear on pages 6-7.) The network control card specifies the number of airways, NB, the number of junctions NJ, and the number of fans NFNUM in the network. If additional airway cards are used to supplement or replace the original airway cards to be read in, their number NADBC is entered. Further data on the network control card includes conditional values as to whether NJ junction cards will be entered for use in calculating the natural ventilation pressures as well as to whether a network, temperature, or concentration calculation will be made. The conditional values are set by the value 1 for occurrence and 0 for omission. Suggested values for the maximum number of network calculations and the maximum number of iterations within the network and concentration parts of the program are MADJ=10 and ITN=30 respectively. The reference air density DR and air temperature TR must be specified. If a real-time analysis is to be made, the marker IRTCC is set equal to 1; otherwise it is at 0.

The airway cards identify each airway by a number, NO, from starting junction JS to ending junction JF, as well as the type of airway, NWTYP. Each airway is one of three types: (1) a fixed-quantity

airway, (2) a regular airway, or (3) an airway containing a fan. The airway resistance R is specified for each airway, or, if not, the program will calculate the resistance from the friction factor KF, length LA, cross-sectional area A, and perimeter O that are specified for each airway. The airflow rate Q is either the desired value in the case of no network calculation or a regulated airway, or the value estimated prior to the network calculation.

The junction cards are used to specify junction temperature and elevation in preparation for a natural ventilation calculation, as well as methane concentration in the case of a gassy mine.

The fan characteristic cards specify the airway number of the fan as well as the number of data points that will be used to represent the fan characteristic curve. The fan data points are entered as pairs--airflow rate QF and pressure PF.

The additional airway cards are used to supplement or replace airway data on the airway cards.

CONCENTRATION INPUT

The concentration input section is used to specify the contaminant source, either smoke from a fire or methane in a gassy mine, in preparation for a calculation of the steady-state contaminant distribution in a mine network. The concentration input (tables 7-11) consists of concentration control card, average value card, additional concentration airway cards, additional concentration junction cards, and contamination cards. The concentration control card specifies the number NDIM of concentration airway cards and the number NCH4C of junction cards, as well as the number INFLOW of contamination cards used to specify a contaminant source. It is recommended to let JSTART, the starting junction number from which the concentration calculation is

calculated, be the surface junction. The accuracy required for the fume, methane, and temperature calculations, as well as the critical values for pressure loss, fume concentration, methane concentration, and temperature, are specified in the concentration control card. The word "critical" is used in the sense of prohibiting safe usage of an airway.

The average value card is used to specify average thermal properties and temperature of the airway walls, as well as average flow resistance for the airways. These values are used by the program if they were not made available elsewhere in the input data.

The additional concentration airway cards were used to assign methane production rates, either as volume production CH4VX or as volume production per unit surface area CH4PAX, and rock temperature TROCKX and thermal properties (rock thermal diffusivity HAX and rock thermal conductivity HKX) to airway number NOX. The airway elevation change can be entered through this card if the junction elevation had not been inserted on the junction cards.

The additional concentration junction cards can be used to specify methane concentration in the junctions. If the methane production has not been specified on the additional concentration airway cards, the methane concentration in the junctions will be used to calculate the methane production rate for that airway.

The contamination cards are used to specify for airway number NCENT a contaminant source in one of three ways. The first option is to specify the volume flow rate and concentration of contaminant inflow as well as the heat production in the airway. The second option is to specify the oxygen concentration of the gas leaving the fire zone for an oxygen-rich fire. The third option is to specify the fume and heat production for a fuel-rich fire. The options correspond

to sections 1, 2, and 3 of the contamination card.

REAL-TIME INPUT

The real-time input is used if a real-time analysis of the contaminant spread from one or more fires throughout the mine network is desired. These fires can be of various durations. The airflow rate used for the calculation is output from the network concentration section. The real-time input includes a real-time control card and contamination cards (tables 12-13). The real-time control card specifies the number NACC of additional contamination cards, the duration IDUR of the simulation, and the time interval INC for printing output from the real-time simulation. The program internally calculates a time interval XINT for calculation of the time contaminants take to travel an airway with some exclusion of travel time and airways. The exclusion is introduced because airways with a travel time considerably less than that of the majority of the airways would produce an unnecessary number of calculations. The percent of travel time EPX and the percent REP of airways that can be excluded are entered on the real-time control card. A value of 5% is a reasonable choice for EPX and REP. Values of the threshold critical fume concentration and accuracy of the contamination calculation are entered on the real-time control card.

The contamination cards are the same as in the concentration input section except for the inclusion of the starting time ISTT and ending time IENDT of the contamination event.

TABLES 1-13

The input data are entered on 80-character punch cards (80 columns) as integer (I) or real (F) variables. The term "Symbol" specifies the variable name used in the program. A short definition

of each variable name (symbol) is given. The column labeled "Option" describes when the variable must be stated in the input. The following abbreviations are used in this column:

C - Conditional, depends on details of the ventilation system.

O - optional for all calculations.

R - required.

RC - required for concentration calculations.

RN - required for network calculations.

RO - required, but optional modes of specification are possible.

RR - required for real time.

RT - required for temperature calculations.

TABLE 1. - Network control card

Column	Format	Symbol	Option	Definition of symbol
1-5	I5	NB	R	Number of airways in network.
6-10	I5	NJ	R	Number of junctions in network.
11-15	I5	NFNUM	C	Number of fan characteristics to be read in.
16-20	I5	NADBC	C	Number of additional airway cards to be read in.
21-25	I5	NVPN	C	Junction card marker; NVPN > 0 indicates that NJ junction cards shall be read in and the natural ventilation pressures will be calculated from the junction data as part of the network part of the program.
26-30	I5	NETW	RN	= 1 marker for network calculation.
31-35	I5	NCONC	RC	= 1 marker for concentration calculation.
36-40	I5	NTEMP	RT	= 1 marker for temperature calculation.
41-45	I5	MADJ	R	Maximum number of times a network calculation shall be performed in 1 program run.
46-50	I5	ITN	R	Maximum number of iterations permitted within the network and concentration parts of the program.
51-60	F10.5	DR	R	Reference air density, lb/ft ³ .
61-70	F10.5	TR	R	Reference air temperature, ° F.
71-75	I5	IRTCC	RR	= 1 marker for real-time calculation.

TABLE 2. - Airway cards

Column	Format	Symbol	Option	Definition of symbol
1-5	I5	NO	R	Identification number of airway.
6-10	I5	JS	R	Starting junction number.
11-15	I5	JF	R	Ending junction number.
16-20	I5	NWTYP	R	Airway type: -1 = fixed quantity airway. 0 = regular airway. 1 = fan airway.
21-30	F10.3	R	C,RO	Resistance of airway, in wg/cfm ² × 10 ¹⁰ (as fan pressure, in wg).
31-40	F10.0	Q	C	Desired or estimated airflow rate, cfm.
41-50	I10	KF	C	Friction factor of airway.
51-60	I10	LA	RO	Length of airway, ft.
61-70	F10.1	A	RO	Cross-sectional area, ft ² .
71-78	F8.0	O	C,RO	Perimeter of airway, ft.

TABLE 3. - Junction cards

Column	Format	Symbol	Option	Definition of symbol
1-5	I5	JNO	R	Junction number.
11-16	F5.1	T	R	Air temperature in junction, ° F.
20-26	F6.0	Z	R	Elevation of junction, ft.
27-31	F5.2	CH4C	O	Methane concentration in junction, pct.

TABLE 4. - Fan characteristic card 1

Column	Format	Symbol	Option	Definition of symbol
1-5	I5	NOF	R	Airway number of fan.
6-10	I5	MPTS	R	Number of points that will be used to define the fan curve; 2 are required, 10 is maximum.

TABLE 5. - Fan characteristic card 2

Column	Format	Symbol	Option	Definition of symbol
1-8	F8.0	QF	R	Airflow rate at point on fan curve, cfm.
9-14	F6.2	PF	R	Fan pressure at point on fan curve, in wg.
15-22	F8.0	QF	R	Airflow rate.
23-28	F6.2	PF	R	Fan pressure.
29-36	F8.0	QF	R	Airflow rate.
37-42	F6.2	PF	R	Fan pressure.
43-50	F8.0	QF	R	Airflow rate.
51-56	F6.2	PF	R	Fan pressure.
57-64	F8.0	QF	R	Airflow rate.
65-70	F6.2	PF	R	Fan pressure.

TABLE 6. - Additional airway cards

Column	Format	Symbol	Option	Definition of symbol
1-5	I5	NOX	R	Airway number.
41-50	I10	KX	O	Friction factor K.
51-60	I10	LX	O	Airway length, ft.
61-70	F10.1	AX	O	Cross-sectional area of airway, ft ² .
71-80	F10.1	OX	O	Perimeter of airway, ft.

TABLE 7. - Concentration control card

Column	Format	Symbol	Option	Definition of symbol
1-5	I5	NDIM	C	Number of concentration airway cards.
6-10	I5	NCH4C	C	Number of concentration junction cards.
11-15	I5	NAV	C	Marker for presence of average value card (NAV = 0, NO; NAV > 0, Yes).
16-20	I5	MAXJ	R	Highest junction number used in network NOT number of junctions.
21-25	I5	INFLOW	C	Number of contamination cards to be read.
26-30	I5	JSTART	R	Number of junctions from which concentration calculation shall start.
31-35	F5.1	TSTART	RT	Air temperature in JSTART, ° F.
36-43	F8.2	TIME	RT	Elapsed time since the start of contamination, hr.
44-50	F7.2	CRITSM	RC	Accuracy of fume and methane concentrations pct and temperature (° F) calculation when recirculation occurs.
51-55	F5.3	CRITGS	RC	
56-61	F6.3	CRITHT	RT	
62-66	F4.2	WRNPR	R	Pressure loss (in wg), fume concentration pct, methane concentration pct, and temperatures (° F) that shall be considered critical.
67-71	F6.4	WRNSM	RC	
72-75	F4.1	WRNGS	RC	
76-80	F5.0	WRNHT	RT	

TABLE 8. - Average value card

Column	Format	Symbol	Option	Definition of symbol
1-10	F10.5	TAVR	0	Rock temperature, ° F.
11-20	F10.5	HAAVR	0	Rock diffusivity, ft ² /hr.
21-30	F10.5	HKA VR	0	Rock thermal conductivity, Btu/hr/ft ² /° F/ft.
31-40	I10	KFAVR	0	Friction factor.
41-50	I10	LA AVR	0	Length airway, ft.
51-60	F10.2	AAVR	0	Cross-sectional area, ft ² .
61-70	F10.2	O AVR	0	Perimeter of airway, ft.

TABLE 9. - Additional concentration airway cards

Column	Format	Symbol	Option	Definition of symbol
1-5	I5	NOX	R	Airway number.
6-15	F10.2	CH4VX	0	Methane volume production, cfm.
16-20	F10.5	CH4PAX	0	Methane volume production rate per unit surface area, cfm/ft ² .
26-35	F10.5	TROCKX	0	Average rock temperature in airway, ° F.
36-45	F10.5	HAX	0	Thermal diffusivity of rock, ft ² /hr.
46-55	F10.5	HKX	0	Thermal conductivity of rock, Btu/hr/ft ² /° F/ft.
56-65	F10.1	DZRD X	RO	Elevation change in airway, ft.

TABLE 10. - Additional concentration junction cards

Column	Format	Symbol	Option	Definition of symbol
1-5	I5	JNOX	R	Junction number.
26-30	F5.2	CH4CX	0	Methane concentration in junction, pct.

TABLE 11. - Contamination cards, steady-state input

Column	Format	Symbol	Option	Definition of symbol
1-5	I5	NCENT	R	Airway number into which contaminant enters.
SECTION 1				
6-15	F10.0	CONT	0	Volume flow rate of contaminant inflow, cfm.
16-25	F10.5	CONC	0	Concentration of contaminant inflow, pct.
26-35	F10.2	HEAT	0	Heat entering airway, Btu/min.
SECTION 2				
36-45	F10.5	O2MIN	0	Oxygen concentration with which fumes leave fire zone, pct used for oxygen-rich fires.
SECTION 3				
46-55	F10.5	SMPO2	0	Fume production per ft ³ of oxygen delivery for fuel-rich fires, ft ³ .
56-65	F10.5	HTP02	0	Heat production per ft ³ of oxygen delivery for fuel-rich fires, Btu.

TABLE 12. - Real-time control card

Column	Format	Symbol	Option	Definition of symbol
1-5	I5	NACC	C	Number of additional contamination cards.
6-10	I5	IDUR	R	Simulation duration, min.
11-15	I5	INC	R	Interval at which conditions are output, min.
16-21	F6.2	EPX	R	Average fume travel time that can be excluded in the calculation of XINT, pct.
22-27	F6.2	REP	R	Maximum airways that can be excluded in the calculation of XINT, pct.
28-35	F8.4	WRNSM	R	Threshold value for critical fume contamination, pct.
36-40	I5	JSURF	R	Number of atmospheric junction.
41-46	F6.5	CRITSM	R	Accuracy of contamination calculation, pct.

TABLE 13. - Contamination cards, real-time input

Column	Format	Symbol	Option	Definition of symbol
1-5	I5	NCENT	R	Airway number into which contaminant enters.
SECTION 1				
6-15	F10.0	CONT	0	Volume flow rate of contaminant inflow, cfm.
16-25	F10.5	CONC	0	Concentration of contaminant inflow, pct.
26-35	F10.2	HEAT	0	Heat entering airway, Btu/min.
SECTION 2				
36-45	F10.5	O2MIN	0	Oxygen concentration with which fumes leave fire zone, pct used for oxygen-rich fires.
SECTION 3				
46-55	F10.5	SMPO2	0	Fume production per ft ³ of oxygen delivery for fuel-rich fires, ft ³ .
56-65	F10.5	HTP02	0	Heat production per ft ³ of oxygen delivery for fuel-rich fires, Btu.
66-70	I5	ISTT	0	Starting time of contamination event, min.
71-75	I5	IENDT	0	Ending time of contamination event, min.

APPLICATIONS

Figure 1 shows the base schematic of a small multilevel mine with an exhaust fan in airway 51 and a booster fan in airway 6 as well as the airflow direction. (See figure 2 for identification of airways.) The computer program was used to perform both a steady-state and a

real-time analysis following the occurrence of a fuel-rich fire in passage-way 20, which is a descensionally ventilated raise (downcast shaft). As a second application, ventilation calculations were made for the same network under




FIGURE 1. - Base schematic of small multilevel mine with an exhaust fan and booster fan.

the condition of a failure of the exhaust fan.

In both applications the mine is slightly gassy with methane and there is buoyancy-driven natural ventilation. A steady-state calculation is made of methane and smoke concentration, followed by a real-time calculation of smoke spread. The input parameter WRNSM is set to 0.001% as the threshold for critical fume concentration, and the threshold for wave generation, CRITSM, is set to 0.001%. Figure 1 shows the base schematic-flow rates and direction before the fire and with both fans operational.

FUEL-RICH FIRE IN A DOWNCAST SHAFT

The fuel-rich fire in passageway 20 is characterized by a production of 1 cu ft of fumes and 300 Btu per cubic foot of delivered oxygen. The input data are listed in appendix B. A steady-state ventilation network and temperature calculation was made with the program for a time of 1 hr after the fire occurred. During this 1-hr period thermal exchange between the ventilation air and the wall surface and thermal diffusion into the mine wall occurred, thereby altering the ventilation flows. The results of this calculation are listed in appendix C.

The steady-state ventilation calculation is followed by a real-time calculation. The airflow reversal that occurred in airways 20 and 21 as a result of the fire provides a direct path via airways 11, 49, and 51 to the surface for the fumes generated by the fire, thereby precluding the occurrence of contamination in the remainder of the mine. The output from the real-time analysis in appendix C covers a period of 10 min with output at 2-min increments. Only one wave is generated, and it reaches the surface via airway 51 at 8.68 min, at which time a steady-state fume concentration is established in the mine network. Based on the steady-state increase in the total exposure, evaluated as parts per million per hour the junctions, the user can make linear projections of the total

contaminant concentration for extended periods of time.

FUEL-RICH FIRE IN A DOWNCAST SHAFT WITH A FAN FAILURE

An additional hazard that could occur in a mine following a fire would be a fan failure. The above example will be re-evaluated with the additional constraint of an operational failure of the exhaust fan in airway 51. Those airways that undergo a flow reversal as a result of the fan failure that differ from flow reversals that occur in the above example 1 hr after the occurrence of the fire are indicated by arrows in figure 2. Appendix D lists the input data for the calculation, and appendix E contains the output for the steady-state and real-time analysis. A comparison of appendixes E and C shows that the number of airways with a critically high fume (smoke) concentration has increased from 4 to 44. The complexity of the fume spread in this latter case is analyzed with the real-time position of the program. The real-time results are tabulated in appendix E at 60-min increments for a duration of 360 min. A steady-state real-time fume concentration is not achieved until 174 min has elapsed. After 120 min has elapsed, the number of waves in airway 48 exceeds five. When this occurs, these waves are replaced internally by the program to permit the generation of new waves. The wave generation process is only suspended when the difference between successive waves becomes less than CRITSM, which equals 0.001% in these examples.

Since the methane production in an airway is determined from the concentrations at the airway ends and the volumetric flow rate, which may be positive or negative depending upon the flow direction, it is possible to have a negative methane production, as the output shows. This is a computational artifice. As the output shows for the temperatures and concentrations of smoke and methane in junctions 1 hr after the fire occurs, the methane




FIGURE 2. - Schematic of flow reversal in small multilevel mine with failure of exhaust fan.

concentrations are positive quantities at junctions.

The real-time analysis of the mine network shows that the failure of the exhaust fan produced a recirculation of contaminated air. The recirculated air occurs through airways 5, 46, 48, 26, 25, 23, 21, 20, 10, 8, 7, and 6. The computer output identifies airways 5 and 26 as closing the recirculation path through

flow reversal. The list of temperatures and concentrations at the airway ends shown that junctions 2 and 17 have a negative sign. This is used to indicate that it is the flow into these junctions that closes the recirculation path.

The program can be used to evaluate fume concentrations from more than one fire by increasing the number NACC of

contamination cards. Each fire may be specified by its start and completion time. The program could be used to

predict the restoration of the mine to a fresh air condition following the suppression of contaminant fume production.

CONCLUSION

The computer program listed in the appendix can be used to describe the real-time spread of smoke from one or more fires throughout a multilevel mine that is ventilated by fans and temperature-induced natural ventilation. Paths of recirculation are identified as part of

the program output. Each airway of the mine can be a regular airway, can be a regulated airway, or can contain a fan. The program can be used for planning ventilation control measures, as well as miner escape and rescue in case of a hazardous event such as a fire.

EXPLANATION OF APPENDIXES

The computer program is divided into a main program and subroutines. The subroutines and their purpose are enumerated below:

<u>Subroutines</u>	<u>Purpose</u>
NETWRK.....	Initializes network and forms meshes.
ITT.....	Solves for flow rates using Hardy-Cross method.
RESIST.....	Calculates resistance of regulators.
RDCONC.....	Reads concentration and temperature data and initializes for selected mine scenarios.
FLOWSK.....	Checks for airflow reversals.
ROADWY.....	Computes temperature and concentration for airways due to temperature change.
NATVP1.....	Calculates natural ventilation pressure and adjusts resistance due to temperature change.
SQRS.....	Used for least squares representation of fan data.
MINV.....	Used for least squares representation of fan data.
WRITR.....	Writes output results.
RTIME1.....	Reads input data for real-time fume spread calculation and selects time interval.
RTIME2.....	Performs real-time calculation of fume spread.
CTPAM.COM.....	Defines array sizes.
CTCONN.COM.....	Common block for subroutines.

The program automatically represents the fan characteristic data by a Lagrange interpolation. If the user wishes to represent the data by a least squares approximation, the parameter IFAN in the main program should be set to any nonzero integer value.

References to page numbers in the program refer to Gruer's "Study of Mine Fires and Mine Ventilation."¹

¹Work cited in text footnote 4.

APPENDIX A.--LISTING OF COMPUTER PROGRAM

```

300 C      11111111112222222222333333333333444444444455555555556666666666777
400 C23456789012345678901234567890123456789012345678901234567890123456789012
500 C
600 C      COMBINED PROGRAMS FOR NETWORK, CONCENTRATION, AND TEMPERATURE
700 C
800 C
900 C      CALCULATIONS
1000 C      AND REAL TIME CONCENTRATION SPREAD
1100 C
1200 C
1300 C      DATA DIVISION.
1400 C      COMMON SECTION.
1500 C
1600 C      INCLUDE 'CTPAM.COM'
1700 C      INCLUDE 'CTCONN.COM'
1800 C      COMMON/SCLR1/ADDT, BI, COR, DIFCH4, FRO, I, ITN, K, MRC, NM, PI, RN, SUMAIR,
1900 C      1TDM, TOLD, X, ARGMT, CH4JS, CP, DIFPR, FX, ICFTM, J, L, MSTART, NREC, PDT,
2000 C      2RTCONT, SUMCH4, TFS, TR, AVRCH4, COAGE, CRITGS, DIFTRD, HC, INFLOW, JX, LP,
2100 C      3N, NSTART, PROPJS, SRCH4, SUMHT, TIME, VART, AVRPR, CONTAM, CRITHT, DR,
2200 C      4HEATAD, ISTART, JY, M, NB, NTEMP, QIN, SRPR, SUMPR, TJS, VISC, AVTRD, CONTQ,
2300 C      5CRITSM, FO, HKA, ITCT, JZ, MARKC, NJ, OLADDT, QREC, STRD, SUMT, TM, WT,
2400 C      6AX, HSU, IO, NFNUM, NT, DNVP, TO, FACT, H, MADJC, MENDW, NADBC, NSFLOW,
2500 C      7OX, T1, ZDOWN, FNTM, MND, NSNVP, NVPN, ZUP, INDEX, LX, MARKD, NCONC,
2600 C      8NNVP, NX, ZO, DNVP, KX, MARKN, NETW, NOX, NSW, TSU, Z1, MADJ, MBEGW,
2700 C      9ITRUE, IFALSE
2800 C      COMMON/NETWK/KNUM, JBM, NBL, JEM, KB, NBU, NK, NRETU, NO, Q1, IND,
2900 C      1KCO, MESC, N1, KE, NMIN, NUC, MMIN
3000 C      COMMON/ITTCOM/DQSUM, QBL, ADEN, IT, PART, QBR, RQSUM, ANUM, DP,
3100 C      1NBDR, RQ2, TABF, DPSUM, FANP, LL, DQ, FANG, NPTS, NABF
3200 C      COMMON/RESCOM/NWRN
3300 C      COMMON/WRTCOM/MINREV, JFF, NRCT, MEMI, WRNHT, WRNPR, WRNSM,
3400 C      1WRNSUM, WRNGS
3500 C      COMMON/RDCCOM/AAVR, CH4CX, CH4VX, ES, HAX, HKX, KFAVR, CH4F,
3600 C      1JNOX, NAV, NCH4C, JSTART, CH4PAX, DZRD, NDIM, DAVR, CH4S,
3700 C      2HAAVR, HKA, LA, LAVR, MAXJ, TSTART, TRF, TROCKX, TAVR, TRS, EF
3800 C      COMMON/FLOCOM/MM
3900 C      COMMON/NATCOM/E, B, G, GX, GXX, TMRD, TMSQR, TRA
4000 C      COMMON/CNNGE1/QO(IAR)
4100 C      COMMON/LEAST/ATA(3, 3), ATY(3), CL(40, 6), LK(5), MQ(5), IFAN
4200 C      COMMON/RTNCOM/NACC, IDUR, INC, EPX, REP, SNRW, JSURF
4300 C      1      , MULT, XINT
4400 C      2      , ISCOB(IAR), IENDT(20), RTAC(IAR, 240, 4), RTJC(IAR, 2)
4500 C      COMMON/RTMCOM/MRKL
4600 C      COMMON/RTSC/EXPO(8), MINER(8), JMST(8), ARSJ(8), DEPSJ(8),
4700 C      1      NJR(8), NOTR(8), JREST(8, 10), REST(8, 10), NESC(8,
4800 C      2      10), VESC(8, 10), SPFCT(8, 10), JFESC(8, 10), EXRTA(8,
4900 C      3      10), EXRTJ(8, 10, 2), NEXPD, MIND
4950 C      COMMON/CHECKK/JTMP(300)
5000 C
5100 C      WORKING-STORAGE SECTION.
5200 C
5300 C      LOGICAL LGT020
5400 C
5500 C      PROCEDURE DIVISION.
5600 C
5700 C
5800 C      INITIALIZATION SECTION.
5900 C
6000 C
6100 C      INITIALIZATION-OPERATIONS.
6200 C
6300 C      IST=1
6400 C      IFAN=0

```

```

6500      IFALSE=0
6600      ITRUE=1
6700      LP=2
6800      IO=1
6900      NSNVP=IFALSE
7000      NSFLOW=IFALSE
7100      DO 182 I=1, IAR
7200 182      NREV(I)=0
7300      DO 202 I=1, 10
7400 202      RGRAD(I)=0.0
7500      C
7600      C READ-INPUT-DATA.
7700      C
7800      C          READ NETWORK CONTROL CARD
7900      OPEN(UNIT=IO, FILE='MRTIM2.DAT', TYPE='OLD')
8000      OPEN(UNIT=LP, FILE='MRTAM2.LST', TYPE='UNKNOWN')
8100      READ(IO, 241) NB, NJ, NFNUM, NADBC, NVPN, NETW, NCONC, NTEMP, MADJ, ITN,
8200      ; DR, TR, IRTCC
8300 241      FORMAT (10I5, 2F10.5, I5)
8400      IF (IRTCC .NE. 1) IRTCC=0
8500      IF (NVPN .NE. IFALSE) NVPN=ITRUE
8600      IF (NETW .NE. IFALSE) NETW=ITRUE
8700      IF (NCONC .NE. IFALSE) NCONC=ITRUE
8800      IF (NTEMP .NE. IFALSE) NTEMP=ITRUE
8900      C          READ NETWORK AIRWAY CARDS
8950      DO 1234 K=1, NB
9000      READ(IO, 301) NO(K), JS(K), JF(K), NWTYP(K), R(K), Q(K), KF(K), LA(K),
9050      1      A(K), D(K)
9175      1234 CONTINUE
9200 301      FORMAT (4I5, F10.3, F10.0, 2I10, 2F10.1)
9300      DO 355 I=1, NB
9400      QD(I)=Q(I)
9500      355 CONTINUE
9525      C          CHECK IF CORRECT NO. BRANCHES/JUNCTIONS
9550      K=0
9562      MXJ=-1
9568      MAXSF=1
9575      DO 352 J=1, NJ
9587      DO 354 I=1, NB
9590      IF (JS(I) .GT. MAXSF) MAXSF=JS(I)
9591      IF (JF(I) .GT. MAXSF) MAXSF=JF(I)
9593      IF (JS(I) .EQ. J .OR. JF(I) .EQ. J) GO TO 352
9595      354 CONTINUE
9598      K=K+1
9599      JTMP(K)=J
9625      MXJ=K
9650      352 CONTINUE
9662      IF (MXJ .GT. 0) WRITE(2, 4323)
9668      4323      FORMAT(5X, 'INCORRECT NO AIRWAYS/JUNCTIONS')
9675      IF (MXJ .GT. 0) WRITE(2, 4321) (JTMP(K), K=1, MXJ)
9681      IF (MXJ .GT. 0) WRITE(2, 4322) MXJ, MAXSF
9687      4321      FORMAT(5(4X, I4))
9693      4322      FORMAT(4X, 'MXJ=', I4, 3X, 'MAXSF=', I4)
9696      C          IF (NVPN) READ NETWORK JUNCTION CARDS
9700      IF (NVPN .EQ. ITRUE) READ(IO, 321) (JNO(K), T(K), PROP(K), PRCH4(K),
9800      ; K=1, NJ)
9900 321      FORMAT (I5, T11, F5.1, T20, F6.0, F5.2)
10000      IF (NFNUM .LE. 0) GOTO 410
10100      DO 400 K=1, NFNUM
10200      C          READ FAN CARDS
10300      READ(IO, 361) NOF(K), MPTS(K)
10400 361      FORMAT (2I5)
10500      INDEX=MPTS(K)

```

```

10600 C          READ FAN-CHARACTERISTIC CARDS
10700          READ (IO,391) (QF(K,I),PF(K,I),I=1,INDEX)
10800 391          FORMAT (5(FB.0,F6.2))
10900 400          CONTINUE
11000 C
11100 C FINISH-READING-INPUT-DATA.
11200 C
11300 410          IF(NADBC.LE.0)GOTO 580
11400          L=0
11500          DO 550 I=1,NADBC
11600 C          READ ADDITIONAL NETWORK AIRWAY CARDS
11700          READ (IO,451) NOX,KX,LX,AX,OX
11800 451          FORMAT (I5,T41,2I10,2F10.1)
11900          DO 480 J=1,NB
12000          IF(NOX.EQ.NO(J))GOTO 500
12100 480          CONTINUE
12200          GO TO 548
12300 500          L=L+1
12400          KF(J)=KX
12500          LA(J)=LX
12600          A(J)=AX
12700          O(J)=OX
12800 548          CONTINUE
12900 550          CONTINUE
13000          IF(NADBC.NE.L)WRITE(LP,571)
13100 571          FORMAT (//////, ' MISTAKE IN ADDITIONAL NETWORK AIRWAY CARDS%',
13200 1              //, ' INVALID AIRWAY NUMBER IN _NOX_ ON SOME CARDS.',
13300 2              //, ' OR WRONG NUMBER OF CARDS. ')
13400 580          CONTINUE
13500          MARKD=IFALSE
13600          IF(NETW.NE.ITRUE)GOTO 720
13700          DO 700 I=1,NB
13800          IF(NWTYP(I).NE.0 .OR. R(I).GT. 0.0)GOTO 690
13900          IF(A(I).GT. 0.0)GOTO 680
14000          WRITE (LP,651) NO(I)
14100 651          FORMAT (//////, ' NO RESISTANCE OR DIMENSIONS WERE ',
14200 1              ' STATED FOR AIRWAY NO',I10)
14300          MARKD=ITRUE
14400          GO TO 688
14500 C          _R(I)_ EQUATIONS% USED TO ADJUST _HL_ ON PAGE 12.
14600 C          ;          _R_ IS ESTIMATED ON PAGE 13.
14700 C680          R(I)=KF(I)*LA(I)*O(I)/(5.2*A(I)**3)*DR/0.075
14800 680          R(I)=FLOAT(KF(I))*FLOAT(LA(I))*O(I)/(5.2
14900 1              *A(I)**3)*DR/0.075
15000 688          CONTINUE
15100 690          RSTD(I)=R(I)
15200 700          CONTINUE
15300          IF(MARKD.NE.ITRUE .AND. NETW.EQ.ITRUE)GOTO 770
15400 C          WRITE INPUT DATA AND BYPASS NETWORK INITIALIZATION
15500 720          WRITE (LP,731)
15600 731          FORMAT(//////,T17, ' NO NETWORK CALCULATION HAS BEEN ',
15700 1              ' PERFORMED, THESE ARE THE INPUT DATA',
15800 2              '//, ' AIRWAY FROM TO AIRFLOW AIRWAY TYPE',
15900 3              ' LENGTH AREA RESISTANCE K PERIMETER')
16000          WRITE(LP,751) (NO(K),JS(K),JF(K),G(K),NWTYP(K),LA(K),A(K),R(K),
16100          KF(K),O(K),K=1,NB)
16200 751          FORMAT (I5,I7,I7,F13.0,BX,I5,8X,I7,F9.1,F10.3,I7,F10.3)
16300          GO TO 1370
16400 770          CONTINUE
16500 C
16600 C NETWORK SECTION.
16700 C
16800 C INITIALIZE-NETWORK.

```

```

16900 C
17000     NSW=IFALSE
17100     MADJC=0
17200     MARKN=IFALSE
17300     ITCT=0
17400 C
17500 C CALL-NETWRK.
17600 C
17700 818 CONTINUE
17800 820 CONTINUE
17900     IF(IFAN.EQ.0) GO TO 1915
18000     DO 1910 KK=1,NFNUM
18100     INDEX=MPTS(KK)
18200     CALL SGR5(KK, INDEX)
18300     CALL MINV(ATA,3)
18400     CALL SGRSS(KK, INDEX)
18500 1910 CONTINUE
18600 1915 CONTINUE
18700     CALL NETWRK
18800 C           CALCULATE NATURAL VENTILATION PRESSURE
18900 C WRITE(LP,841)NSNVP,NVPN,NSFLOW
19000 C841     FORMAT(1X,'DRIVER,L841%NSNVP,NVPN,NSFLOW=',3I5)
19100     IF(NSNVP.NE.ITRUE)GOTO 890
19200     IF(NSFLOW.EQ.ITRUE)GOTO 1190
19300     NNVP=ITRUE
19400     GO TO 1470
19500 890     IF(NVPN.NE.ITRUE)GOTO 1188
19600 C
19700 C NATURAL-VENTILATION-PRESSURE=0.
19800 C
19900 C           COMPUTE _FNVP_ FOR EACH MESH USING NEWTORK INPUT DATA
20000 C           FOR EQUATIONS, SEE PAGE 21.
20100 C WRITE(LP,911)
20200 C911     FORMAT(1X,'DRIVER,L911% ENTER NATVPO')
20300     MBEGW=1
20400     DO 1180 K=1,MNO
20500     MENDW=MEND(K)
20600     FNVP(K)=0.
20700     NT=0
20800     TSU=0.
20900     DO 1140 J=MBEGW,MENDW
21000     N=MSL(J)
21100     NX=IABS(N)
21200     DO 1080 L=1,NJ
21300     IF(JS(NX).NE.JND(L))GOTO 1050
21400 C           _TO_ IS _TS_ IN EQUATION ON BOTTOM OF PAGE 21.
21500     TO=T(L)+460.
21600 C           _ZO_ IS _ZS_ IN EQUATION ON BOTTOM OF PAGE 21.
21700     ZO=PROP(L)
21800 1050     IF(JF(NX).NE.JND(L))GOTO 1078
21900 C           _T1_ IS _TF_ IN EQUATION ON BOTTOM OF PAGE 21.
22000     T1=T(L)+460.
22100 C           _Z1_ IS _ZF_ IN EQUATION ON BOTTOM OF PAGE 21.
22200     Z1=PROP(L)
22300 1078     CONTINUE
22400 1080     CONTINUE
22500     H=TO*Z1-T1*ZO
22600     IF(N.LT.0)H=-H
22700 C           _FNVP_ IS _HN_ IN EQUATION ON BOTTOM OF PAGE 21.
22800     FNVP(K)=FNVP(K)+H
22900     TSU=TSU+TO+T1
23000     NT=NT+1
23100 1140     CONTINUE

```

```

23200          TM=TSU/NT
23300      C          _FNVP_ IS _HN_ IN EQUATION ON BOTTOM OF PAGE 21.
23400          FNVP(K)=FNVP(K)*DR/(5.2*TM)
23500          MBEGW=MENDW+1
23600      1180      CONTINUE
23700      C
23800      C ITERATION.
23900      C
24000      1184      CONTINUE
24100      1186      CONTINUE
24200      1188      CONTINUE
24300      1190      CONTINUE
24400          CALL ITT(LGTO20)
24500          IF(LGTO20)GOTO 820
24600      C
24700      C          WRITE(LP,1231)NSNVP,NSFLOW
24800      C1231      FORMAT(1X,'DRIVER,L1231% NSNVP,NSFLOW=',2I5)
24900          IF(NSNVP.NE.ITRUE)GOTO 1350
25000      C
25100      C DETECT-INSTABLE-AIRWAYS.
25200      C
25300      C          NOTE% THE ONLY PLACE IN THIS ENTIRE SUBSYSTEM WHERE
25400      C ;          FLAG _NSFLOW_ MAY BE SET TO _ITRUE_ IS THE FIRST
25500      C ;          STATEMENT IN PARAGRAPH _CHECK-FOR-AIRFLOW-REVERSALS_ IN
25600      C ;          SUBROUTINE _FLOWSK_ FOR REASONS OF SAFETY AND
25700      C ;          RELIABILITY% IF IN DOUBT AS TO AIRFLOW-REVERSALS,
25800      C ;          CALL _FLOWSK_ _NSFLOW_ IS TRUE ONLY AFTER SUBROUTINE
25900      C ;          _FLOWSK_ CHECKS ALL AIRWAYS FOR AIRFLOW-REVERSAL
26000      C ;          AND FINDS NONE.
26100          DO 1310 I=1,NB
26200          IF(Q(I).GT. 0.0)GOTO 1300
26300          IF(MADJC. GE. MADJ)WRITE(LP,1281)NO(I)
26400      1281      FORMAT (//,T20,' AIRWAY NO',I7,' IS AN UNSTABLE ',
26500          ;          'AIRWAY WITH CHANGING AIRFLOW DIRECTIONS')
26600          NSFLOW=IFALSE
26700      1300      Q(I)=Q(I)*100000.
26800      1310      CONTINUE
26900          ITCT=0
27000          IF(NSFLOW.EQ. ITRUE)GOTO 1430
27100          GOTO 1420
27200      C
27300      1350      CONTINUE
27400      C
27500      C CALCULATE-RESISTANCE-OF-REGULATORS.
27600      C
27700          CALL RESIST
27800      C
27900      C
28000      C          CONCENTRATION SECTION.
28100      C
28200      C CHECK-FOR-CONCENTRATION.
28300      C
28400      1370      IF (NCONC.EQ. ITRUE .OR. NTEMP.EQ. ITRUE)GOTO 1410
28500          WRITE (LP,1391)
28600      1391      FORMAT (/////,' NO TEMPERATURE OR CONCENTRATION ',
28700          ;          'CALCULATIONS WERE DEMANDED')
28800          GO TO 2098
28900      1410      CALL RDCONC
29000      C
29100      C CALL-FLOWSK.
29200      C
29300      1420      CALL FLOWSK
29400      C

```

```

29500 C CALL-ROADWY.
29600 C
29700 1430 CALL ROADWY
29800 IF(NTEMP.NE. ITRUE .OR. NETW.NE. ITRUE)GOTO 2090
29900 C CALCULATION OF NATURAL VENTILATION PRESSURE
30000 CALL NATVP1
30100 IF(NSFLOW.NE. ITRUE)GOTO 1930
30200 C
30300 1470 CONTINUE
30400 C
30500 C NATURAL-VENTILATION-PRESSURE-2.
30600 C
30700 C COMPUTE _FNVP_ FOR EACH MESH USING CONCENTRATION
30800 C ; INPUT DATA
30900 C WRITE(LP,1491)
31000 C1491 FORMAT(1X,'DRIVER,L1470% ENTER NATVP2')
31100 MBEGW=1
31200 DNVP=0.0
31300 DO 1850 K=1,MND
31400 ONVP=FNVP(K)
31500 MENDW=MEND(K)
31600 FNVP(K)=0.
31700 ZUP=0.0
31800 ZDOWN=0.0
31900 HSU=0.
32000 TSU=0.
32100 DO 1740 J=MBEGW,MENDW
32200 N=MSL(J)
32300 IF(N.GE.0)GOTO 1660
32400 FACT=-1.
32500 NX=-N
32600 GO TO 1680
32700 1660 FACT=1.
32800 NX=N
32900 1680 HSU=HSU+FACT*FRNVP(NX)
33000 TSU=TSU+ABS(FRNVP(NX))
33100 IF (DZRD(NX)*FACT) 1730,1736,1710
33200 1710 ZUP=ZUP+DZRD(NX)*FACT
33300 GO TO 1738
33400 1730 ZDOWN=ZDOWN+DZRD(NX)*FACT
33500 1736 CONTINUE
33600 1738 CONTINUE
33700 1740 CONTINUE
33800 IF(ZDOWN+ZUP.EQ.0)GOTO 1780
33900 HSU=HSU-(ZUP+ZDOWN)*TR
34000 TSU=TSU+ABS((ZUP+ZDOWN)*TR)
34100 1780 IF(TSU.GT.0.0)GOTO 1810
34200 FNVP(K)=0.0
34300 GO TO 1830
34400 1810 FNTM=TSU/(ZUP-ZDOWN)
34500 FNVP(K)=HSU*DR/(5.2*(FNTM+460.))
34600 1830 DNVP=DNVP+ABS(ONVP-FNVP(K))
34700 MBEGW=MENDW+1
34800 1850 CONTINUE
34900 C WRITE(LP,1871) NNVP
35000 C1871 FORMAT(1X,'DRIVER,L1850% LEAVE NATVP2 WITH NNVP=',I5)
35100 IF(NNVP.NE. ITRUE)GOTO 1920
35200 NNVP=IFALSE
35300 ITCT=0
35400 GO TO 1186
35500 C
35600 C CHECK-FOR-END-OF-RUN.
35700 C

```

```

35800 C1920 IF(DNVP/MNO. LE. 0. 001)GOTO 2070
35900 1920 CONTINUE
36000 IF(IST. EQ. 1) GO TO 1935
36100 ITFLG=0
36200 IF(DNVP/MNO. GT. 0. 001) ITFLG=1
36300 DO 1925 J=1,NB
36400 TEST=ABS(Q(J)-QO(J))/ABS(QO(J))
36500 IF(TEST. GT. 0. 001) ITFLG=1
36600 QO(J)=Q(J)
36700 1925 CONTINUE
36800 IF(ITFLG. EQ. 0) GO TO 2070
36900 1935 CONTINUE
37000 IST=0
37100 C
37200 C CHECK-FOR-NEXT-NETWORK-PASS.
37300 C
37400 C REROUTE TO APPROPRIATE PROGRAM SECTION
37500 1930 IF(MADJC. GE. MADJ)GOTO 2050
37600 NSNVP=ITRUE
37700 MADJC=MADJC+1
37800 ITCT=0
37900 MARKN=IFALSE
38000 DO 2010 I=1,NB
38100 JF(I)=IABS(JF(I))
38200 Q(I)=Q(I)/100000.
38300 2010 CONTINUE
38400 IF(NSFLOW. EQ. ITRUE)GOTO 1184
38500 NSW=ITRUE
38600 GO TO 818
38700 C
38800 C OUTPUT-OF-RESULTS SECTION.
38900 C
39000 C WRITE-RESULTS-RUN-TOO-LONG.
39100 C
39200 2050 WRITE (LP,2061)
39300 2061 FORMAT (//////, ' THE CALCULATION WAS NOT COMPLETED SINCE THE ',
39400 1 'NUMBER OF EXCHANGES BETWEEN NETWORK AND CONCENTRATION'/
39500 2 ' PARTS OF THE PROGRAM BECAME EXCESSIVE')
39600 C
39700 C WRITE-RESULTS-TEMPERATURE.
39800 C
39900 2070 CALL WRITR
40000 GOTO 2100
40100 C
40200 C WRITE-RESULTS-NO-TEMPERATURE.
40300 C
40400 2090 CALL WRITS
40500 C
40600 2098 CONTINUE
40700 2100 CONTINUE
40800 C
40900 C REAL-TIME-CALCULATION
41000 C
41100 IF(IRTCC) 2096,2096,2095
41200 2095 CALL RTIME1
41300 CALL RTIME2
41400 2096 CONTINUE
41500 C
41600 C END OF RUN
41700 C
41800 WRITE(LP,2121)
41900 2121 FORMAT(1X,1H /16X, 'END OF RUN'/1X,1H )
42000 CLOSE(UNIT=LP)

```

```
42100      CLOSE(UNIT=ID)
42200      STOP
42300      C
42400      END
```

```

200      SUBROUTINE NETWRK
300      C      1111111111222222222223333333333334444444444555555555566666666666777
400      C23456789012345678901234567890123456789012345678901234567890123456789012
500      C
600      C      "NETWRK" INITIALIZES NETWORK OF MINE PRIOR TO
700      C      ITERATIONS BY SUBROUTINE "ITT" BY GENERATING "MSL" LIST OF
800      C      AIRWAYS IN MESHES AND "MEND" INDEX OF LAST AIRWAY
900      C      IN EACH MESH.
1000     C      THE "INU"(LIST OF AIRWAYS WITH ASC. "RG"), "KND"
1100     C      (LIST OF AIRWAYS IN BASE SYSTEM), "KJS"(BASE SYSTEM "JS"),
1200     C      AND "KJF"(BASE SYSTEM "JF") ARE INTERMEDIATE LISTS
1300     C      TO MAKE "MSL" AND "MEND" FROM, AND WILL NOT BE NEEDED FOR
1400     C      THE SAME PURPOSE AFTER RETURN FROM THIS SUBROUTINE.
1500     C
1600     C      DATA DIVISION.
1700     C      COMMON SECTION.
1800     C
1900     C
2000     C      INCLUDE 'CTPAM.COM'
2100     C      INCLUDE 'CTCONN.COM'
2200     C      COMMON/SCLR1/ADDT, BI, CDR, DIFCH4, FRO, I, ITN, K, MRC, NM, PI, RN, SUMAIR,
2300     C      1TDM, TOLD, X, ARGMT, CH4JS, CP, DIFPR, FX, ICFTM, J, L, MSTART, NREC, POT,
2400     C      2RTCONT, SUMCH4, TFS, TR, AVRCH4, COAGE, CRITGS, DIFTRD, HC, INFLOW, JX, LP,
2500     C      3N, NSTART, PROPJS, SRCH4, SUMHT, TIME, VART, AVRPR, CONTAM, CRITHT, DR,
2600     C      4HEATAD, ISTART, JY, M, NB, NTEMP, QIN, SRPR, SUMPR, TJS, VISC, AVTRD, CONTQ,
2700     C      5CRITSM, FO, HKA, ITCT, JZ, MARKC, NJ, OLADDT, QREC, STRD, SUMT, TM, WT,
2800     C      6AX, HSU, ID, NFNUM, NT, DNVP, TO, FACT, H, MADJC, MENDW, NADBC, NSFLOW,
2900     C      7OX, T1, ZDOWN, FNTM, MNO, NSNVP, NVPN, ZUP, INDEX, LX, MARKD, NCONC,
3000     C      8NNVP, NX, ZO, DNVP, KX, MARKN, NETW, NOX, NSW, TSU, Z1, MADJ, MBEGW,
3100     C      9ITRUE, IFALSE
3200     C      COMMON/NETWK/KNUM, JBM, NBL, JEM, KB, NBU, NK, NRETU, NO, Q1, IND,
3300     C      1KCD, MESC, N1, KE, NMIN, NUC, MMIN
3400     C      COMMON/ITTCOM/DGSUM, QBL, ADEN, IT, PART, QBR, RQSUM, ANUM, DP,
3500     C      1NBDR, RQ2, TABF, DPSUM, FANP, LL, DG, FANG, NPTS, NABF
3600     C      COMMON/RESCOM/NWRN
3700     C      COMMON/WRTCOM/MINREV, JFF, NRCT, MEMI, WRNHT, WRNPR, WRNSM,
3800     C      1WRNSUM, WRNGS
3900     C      COMMON/RDCCOM/AAVR, CH4CX, CH4VX, ES, HAX, HKX, KFAVR, CH4F,
4000     C      1JNOX, NAV, NCH4C, JSTART, CH4PAX, DZRDY, NDIM, QAVR, CH4S,
4100     C      2HAAVR, HKAVR, LAAVR, MAXJ, TSTART, TRF, TROCKX, TAVR, TRS, EF
4200     C      COMMON/FLOCOM/MM
4300     C      COMMON/NATCOM/E, B, G, GX, GXX, TMRD, TMSQR, TRA
4400     C
4500     C      PROCEDURE DIVISION WITH ENTRY POINT NETWRK.
4600     C
4700     C      NETWRK.
4800     C
4900     C      WRITE(LP, 121)
5000     C121      FORMAT(1X, 'ENTERING NETWRK')
5100     C
5200     C      MAKE-INU-LIST SECTION.
5300     C
5400     C      INU-LIST-FLAG-AIRWAYS.
5500     C
5600     C      ARRANGE ORDINARY AIRWAYS IN ASC. ORDER OF ABS(R*Q)
5700     C      INTO "INU" LIST
5800     C      NBU=NB
5900     C      NBL=1
6000     C      DO 320 K=1, NB
6100     C      IF (NSW.NE. ITRUE)Q(K)=Q(K)/100000.
6200     C      DO 190 J=1, NFNUM
6300     C      IF (NOF(J).EQ. NO(K)) GOTO 210
6400     C190      CONTINUE
6500     C      IF (NWTYP(K)) 220, 250, 280

```

```

6600 210      NFREG(J)=K
6700 220      INU(NBU)=K
6800          NBU=NBU-1
6900          GO TO 310
7000 250      RQ(K)=ABS(R(K)*Q(K))
7100          NWTYP(K)=2
7200          GO TO 300
7300 280      INU(NBL)=K
7400          NBL=NBL+1
7500 300      CONTINUE
7600 310      CONTINUE
7700 320      CONTINUE
7800 C
7900 C INU-LIST-BUBBLE-SORT.
8000 C
8100 330      IF (NBU.LT.NBL) GOTO 470
8200          NRETU=IFALSE
8300          DO 420 K=1,NB
8400              IF (NWTYP(K).LT.2) GOTO 410
8500              IF (NRETU.EQ.ITRUE)GOTO 400
8600              MMIN=K
8700              NRETU=ITRUE
8800 400      IF (RQ(MMIN).GT.RQ(K)) MMIN=K
8900 410      CONTINUE
9000 420      CONTINUE
9100          INU(NBL)=MMIN
9200          NBL=NBL+1
9300          NWTYP(MMIN)=0
9400          GOTO 330
9500 C
9600 C SET-UP-BASE-SYSTEM-SECTION.
9700          MAKE "KJS","KJF",AND "KNO" LISTS TO CONNECT JUNCTIONS
9800 C
9900 C BASE-SYSTEM-INIT.
10000 C
10100 470      IND=INU(1)
10200 C          SUBSCRIPT "IND" COVERS AIRWAY NUMBERS WITH ASCENDING "RQ"
10300          KJF(NJ)=JS(IND)
10400          KJS(NJ-1)=JS(IND)
10500 C          IF (JS(IND).LT.0), THEN LOOK UP "KNO" LIST TO FIND "IND"
10600          JS(IND)=-JS(IND)
10700          KJF(NJ-1)=JF(IND)
10800          KNO(NJ-1)=IND
10900          KNUM=NJ-1
11000 C
11100 C BASE-SYSTEM-HUNT.
11200 C
11300 540      CONTINUE
11400 550      DO 690 NUC=2,NB
11500          IND=INU(NUC)
11600 C          SUBSCRIPT "IND" COVERS AIRWAY NUMBERS WITH ASCENDING
11700 C %          "RQ" IS "JS" OR "JF"
11800          IF (JS(IND).LT.0) GOTO 688
11900          N1=IFFALSE
12000          NO=IFFALSE
12100          DO 630 K=KNUM,NJ
12200 C          HUNT FOR "JS(IND)" AND "JF(IND)" IN (KJF(K),K=KNUM,NJ)
12300 C          SUBSCRIPT "KNO" COVERS JUNCTIONS IN ASC. "RQ" ORDER
12400 C %          FOR LISTS "KJS" AND "KJF"
12500 C          "KJS" AND "KJF" ARE JUNCTIONS FOR SECONDARY AIRWAYS:
12600 C %          "KNO(KNUM)" IS THE SECONDARY AIRWAY WITH THE
12700 C %          HIGHEST "RQ" CONNECTED TO THE PRIMARY AIRWAY
12800 C %          "NO(IND)": IF "(KNO(KNUM).LT.0)", THEN "JF" OF

```

```

12900 C % THIS AIRWAY CONNECTS TO "JS OF THE PRIMARY AIRWAY
13000 IF (JS(IND).EQ.KJF(K)) NO=ITRUE
13100 IF (JF(IND).EQ.KJF(K)) N1=ITRUE
13200 630 CONTINUE
13300 IF(N1.NE.NO)GOTO 760
13400 IF(N1.NE.ITRUE .AND. NO.NE.ITRUE)GOTO 680
13500 JS(IND)=-JS(IND)
13600 JF(IND)=-JF(IND)
13700 680 CONTINUE
13800 688 CONTINUE
13900 690 CONTINUE
14000 IF (KNUM.EQ.1) GOTO 910
14100 DO 740 K=1,NB
14200 IF (JS(K).GT.0) WRITE (LP,731)NO(K)
14300 C IF THIS MESSAGE GETS PRINTED AND THE AIRWAY IS NOT
14400 C REALLY A DEAD-END, THEN REFER TO THE NEWTORK AIRWAY
14500 C INPUT DATA CARD FOR THIS AIRWAY AND MAKE SURE THAT
14600 C "JS" AND "JF" (STARTING AND ENDING JUNCTIONS) FOR
14700 C THIS AIRWAY ARE WHAT YOUR MINE-NETWORK DIAGRAM SAYS
14800 C THEY ARE: IF NO MISTAKES ARE FOUND ON THIS CARD,
14900 C CHECK NETWORK AIRWAY CARDS FOR ALL AIRWAYS WHICH
15000 C CONNECT TO THIS AIRWAY FOR GOOD "JS" AND "JF".
15100 C THEN RE-SUBMIT YOUR CORRECTED DATA FOR
15200 C THE NEXT RUN.
15300 731 FORMAT(/////,'7H AIRWAY, IS, ' IS ISOLATED FROM NETWORK')
15400 740 CONTINUE
15500 GO TO 900
15600 760 IF (NWTYP(IND).LT.0) WRITE (LP,771)NO(IND)
15700 C IF YOU GET THIS MESSAGE, SCREAM H-E-L-P TO THE SOFTWARE
15800 C MAINTENANCE PEOPLE: THIS SHOULD NEVER HAPPEN
15900 771 FORMAT(/////,'ERROR: REGULATOR',IS,' IN BASE SYSTEM')
16000 KNUM=KNUM-1
16100 IF (NO.EQ.ITRUE) GOTO 850
16200 C
16300 C BASE-SYSTEM-INSERT-FOR-JF.
16400 C
16500 C HERE FOR (N1.EQ.1.AND.NO.EQ.0): JF(IND)IS IN KJF(K),
16600 C % K=KNUM,NJ
16700 KJS(KNUM)=JF(IND)
16800 KJF(KNUM)=JS(IND)
16900 KNO(KNUM)=-IND
17000 JS(IND)=-JS(IND)
17100 GO TO 550
17200 C
17300 C BASE-SYSTEM-INSERT-FOR-JS.
17400 C
17500 C HERE FOR (NO.EQ.ITRUE.AND.N1.EQ.FALSE): JS(IND)IS IN
17600 C % KJF(K),K=KNUM,NJ)
17700 850 KJS(KNUM)=JS(IND)
17800 KJF(KNUM)=JF(IND)
17900 KNO(KNUM)=IND
18000 JS(IND)=-JS(IND)
18100 GO TO 540
18200 C
18300 C BASE-SYSTEM-EXIT.
18400 C
18500 900 CONTINUE
18600 910 CONTINUE
18700 DO 920 K=1,NB
18800 920 JS(K)=IABS(JS(K))
18900 C
19000 C FORM-MESHES-SECTION.
19100 C

```

```

19200 C FORM-MESHES.
19300 C
19400 C           AT LAST: MAKE "MSL" LIST AND "MEND" INDEX
19500 MESC=0
19600 MNO=0
19700 DO 1240 K=1,NB
19800 IF (JF(K).GE.0) GOTO 1230
19900 JF(K)=-JF(K)
20000 MNO=MNO+1
20100 JBM=JS(K)
20200 JEM=JF(K)
20300 NK=K
20400 1020 CONTINUE
20500 1030 CONTINUE
20600 C REPEAT UNTIL (KB.EQ.KE);
20700 MESC=MESC+1
20800 C           "MEND(MNO)" CONTAINS LAST "MSL" SUBSCRIPT
20900 C           FOR THIS AIRWAY
21000 MEND(MNO)=MESC
21100 C           "MSL" GETS ALL AIRWAYS IN THIS MESH
21200 MSL(MESC)=NK
21300 DO 1090 KCO=1,NJ
21400 IF (JBM.EQ.KJF(KCO)) GOTO 1100
21500 1090 CONTINUE
21600 1100 KB=KCO
21700 DO 1130 KCO=1,NJ
21800 IF (JEM.EQ.KJF(KCO)) GOTO 1140
21900 1130 CONTINUE
22000 1140 KE=KCO
22100 IF (KB-KE) 1160,1220,1190
22200 1160 NK=KNO(KB)
22300 JBM=KJS(KB)
22400 GO TO 1030
22500 1190 NK=-KNO(KE)
22600 JEM=KJS(KE)
22700 GO TO 1020
22800 1220 CONTINUE
22900 C END REPEAT(KB.EQ.KE);
23000 1230 CONTINUE
23100 1240 CONTINUE
23200 C
23300 C SATISFY-JUNCTION-EQUATIONS-SECTION.
23400 C SATISFY-JUNCTION-EQUATIONS.
23500 C
23600 MBEGW=2
23700 DO 1320 K=1,MNO
23800 MENDW=MEND(K)
23900 DO 1300 J=MBEGW,MENDW
24000 N=IABS(MSL(J))
24100 Q(N)=0.
24200 1300 CONTINUE
24300 MBEGW=MENDW+2
24400 1320 CONTINUE
24500 MBEGW=1
24600 DO 1490 K=1,MNO
24700 MENDW=MEND(K)
24800 N=IABS(MSL(MBEGW))
24900 Q1=Q(N)
25000 M=MBEGW+1
25100 DO 1470 J=M,MENDW
25200 N=MSL(J)
25300 FACT=1.
25400 IF (N.GE.0) GOTO 1450

```

```
25500          N=-N
25600          FACT=-1.
25700 1450      CONTINUE
25800          Q(N)=Q(N)+Q1*FACT
25900 1470      CONTINUE
26000          MBEGW=MENDW+1
26100 1490      CONTINUE
26200 C
26300 C NETWRK-BOOGIE SECTION.
26400 C NETWRK-BOOGIE.
26500 C
26600 C WRITE(LP,1511)
26700 C1511      FORMAT(1X,'RETURN FROM NETWRK')
26800          RETURN
26900          END
```

```

200      SUBROUTINE ITT(LGTO20)
300      C      111111111122222222223333333333444444444455555555556666666666777
400      C23456789012345678901234567890123456789012345678901234567890123456789012
500      C
600      C      "ITT" ADJUSTS "Q" (AIRFLOW) WITHIN THE MINE NETWORK FOR
700      C      THE INFLUENCE OF MESHES AND COMPUTED AIRFLOW OF FANS,
800      C      COMPUTES AIRFLOW OF FANS AFTER ACCOUNTING FOR
900      C      INFLUENCE OF AIRFLOW OF OTHER AIRWAYS, AND THEN REPEATS
1000     C      THIS COMPUTATION FOR AIRFLOWS AND FANS UNTIL CONVERGENCE
1100     C      IS REACHED OR MAXIMUM NUMBER OF ITERATIONS IS EXCEEDED.
1200     C
1300     C
1400     C      DATA DIVISION.
1500     C      COMMON SECTION.
1600     C
1700     C      INCLUDE 'CTPAM.COM'
1800     C      INCLUDE 'CTCONN.COM'
1900     C      COMMON/SCLR1/ADDT, BI, COR, DIFCH4, FRO, I, ITN, K, MRC, NM, PI, RN, SUMAIR,
2000     C      1TDM, TOLD, X, ARGMT, CH4JS, CP, DIFPR, FX, ICFTM, J, L, MSTART, NREC, POT,
2100     C      2RTCONT, SUMCH4, TFS, TR, AVRCH4, COAGE, CRITGS, DIFTRD, HC, INFLOW, JX, LP,
2200     C      3N, NSTART, PROPJS, SRCH4, SUMHT, TIME, VART, AVRPR, CONTAM, CRITHT, DR,
2300     C      4HEATAD, ISTART, JY, M, NB, NTEMP, QIN, SRPR, SUMPR, TJS, VISC, AVTRD, CONTQ,
2400     C      5CRITSM, FD, HKA, ITCT, JZ, MARKC, NJ, OLADDT, GREC, STRD, SUMT, TM, WT,
2500     C      6AX, HSU, ID, NFNUM, NT, ONVP, TO, FACT, H, MADJC, MENDW, NADBC, NSFLOW,
2600     C      7DX, T1, ZDOWN, FNTM, MND, NSNVP, NVPN, ZUP, INDEX, LX, MARKD, NCONC,
2700     C      8NNVP, NX, ZO, DNVP, KX, MARKN, NETW, NOX, NSW, TSU, Z1, MADJ, MBEGW,
2800     C      9ITRUE, IFALSE
2900     C      COMMON/NETWK/KNUM, JBM, NBL, JEM, KB, NBU, NK, NRETU, NO, Q1, IND,
3000     C      1KCO, MESC, N1, KE, NMIN, NUC, MMIN
3100     C      COMMON/ITTCOM/DQSUM, QBL, ADEN, IT, PART, QBR, RQSUM, ANUM, DP,
3200     C      1NBDR, RQ2, TABF, DPSUM, FANP, LL, DG, FANG, NPTS, NABF
3300     C      COMMON/LEAST/ATA(3,3), ATY(3), CL(40,6), LK(5), MQ(5), IFAN
3400     C
3500     C      LINKAGE SECTION.
3600     C      LOGICAL LGTO20
3700     C
3800     C      PROCEDURE DIVISION USING LGTO20
3900     C      %      WITH ENTRY POINT ITERATION-ITT.
4000     C
4100     C      ITERATION-ITT.
4200     C
4300     C      WRITE(LP, 101)
4400     C101      FORMAT(1X, 'ENTERING ITT')
4500     C      LGTO20=.FALSE.
4600     C      IT=0
4700     C
4800     C      ITERATION-MESSAGE-Q.
4900     C
5000     C110      CONTINUE
5100     C120      DQSUM=0.
5200     C      MBEGW=1
5300     C      DO 530 K=1, MND
5400     C      MESSAGE "Q" FOR MESHES AND COMPUTE "DQSUM"
5500     C      %      IN ACCORDANCE WITH EQUATION AT TOP OF PAGE 22
5600     C      %      (4.1.8, "CROSS CORRECTION" FORMULA).
5700     C      MENDW=MEND(K)
5800     C      DPSUM=0.
5900     C      RQSUM=0.
6000     C      N=IABS(MSL(MBEGW))
6100     C      IF (NWTYP(N).EQ.-1) GOTO 520
6200     C      DO 410 J=MBEGW, MENDW
6300     C      COMPUTE "RQSUM", "DPSUM", AND "DG" FOR ONE MESH
6400     C      N=MSL(J)

```

```

6500          FACT=1.
6600          IF (N. GE. 0)GOTO 260
6700          N=-N
6800          FACT=-1.
6900 260      IF (NWTYP(N)) 400, 270, 320
7000 270      RG2=R(N)*ABS(Q(N))*2
7100          RGSUM=RGSUM+RG2
7200          DP=R(N)*Q(N)*ABS(Q(N))
7300 C          "DPSUM" GOES TO NUMERATOR IN EQUATION AT
7400 C %          TOP OF PAGE 22.
7500          DPSUM=DPSUM+FACT*DP
7600          GO TO 390
7700 320      DPSUM=DPSUM-FACT*R(N)
7800 C          "R" AND "RGRAD" FOR FANS GETS COMPUTED IN PARA-
7900 C %          GRAPH "FANCHARACTERISTICS" IN THIS SUBROUTINE
8000          DO 350 L=1,NFNUM
8100          IF (NFREG(L).EQ.N) GOTO 370
8200 350      CONTINUE
8300          GO TO 380
8400 C
8500 C          "RGRAD" IS DH(F(I))" IN EQUATION AT TOP
8600 C %          OF PAGE 22.
8700 370      RGSUM=RGSUM-RGRAD(L)
8800 380      CONTINUE
8900 390      CONTINUE
9000 400      CONTINUE
9100 410      CONTINUE
9200 C          "FNVP" IS "HN" IN EQUATION AT TOP OF PAGE 22.
9300 C %          "RGSUM" GOES TO DENOMINATOR IN EQUATION AT
9400 C %          TOP OF PAGE 22.
9500          DG=(DPSUM-FNVP(K))/RGSUM
9600          DO 500 J=MBEGW,MENDW
9700 C          MESSAGE "Q" FOR AIRWAYS IN THIS MESH AND
9800 C %          ACCUMULATE "DQSUM"
9900          N=MSL(J)
10000         FACT=1.
10100         IF (N. GE. 0)GOTO 490
10200         N=-N
10300         FACT=-1.
10400 490      Q(N)=Q(N)-(DG*FACT)
10500 500      CONTINUE
10600 C          "DQ" IS AIRFLOW CHANGE FOR THIS MESH: WHEN "DQSUM"
10700 C %          IS ZERO OR VERY SMALL, "ITT" CAN RETURN
10800         DQSUM=DQSUM+ABS(DG)
10900 520      MBEGW=MENDW+1
11000 530      CONTINUE
11100 C
11200 C FANCHARACTERISTICS.
11300 C
11400         DO 1090 J=1,NFNUM
11500         NFCW(J)=IFALSE
11600         DO 580 K=1,NB
11700 C          HUNT FOR FAN "J" IN AIRWAY "K"
11800         IF (NOF(J).EQ.NO(K)) GOTO 600
11900 580      CONTINUE
12000         GO TO 1080
12100 C
12200 600      NPTS=MPTS(J)
12300         IF(NVFN.EQ.ITRUE.OR.MADJC.GT.0)GOTO 640
12400         TABF=TR
12500         GO TO 720
12600 640      NABF=JS(K)
12700         DO 700 L=1,NJ

```

```

12800 C          HUNT FOR JUNCTION "L" FOR FAN "J" IN AIRWAY "K"
12900 C          GET TEMPERATURE FROM "T(L)" FOR "FANG"
13000          IF (NABF. NE. JND(L)) GOTO 690
13100          TABF=T(L)
13200          GO TO 710
13300 690          CONTINUE
13400 700          CONTINUE
13500 710          CONTINUE
13600 720          FANG=Q(K)*100000. *(TABF+460.)/(TR+460.)
13700          NBDR=MPTS(J)-1
13800          QBL=GF(J, 2)
13900          QBR=GF(J, NBDR)
14000 C          COMPUTE "FANP" FOR "R(K)"
14100          IF (FANG. GE. QBL) GOTO 800
14200          R(K)=PF(J, 2)
14300          NFCW(J)=ITRUE
14400          GO TO 1070
14500 C
14600 800          IF (FANG. LE. QBR) GOTO 840
14700          R(K)=PF(J, NBDR)
14800          NFCW(J)=ITRUE
14900          GO TO 1060
15000 C
15100 840          FANP=0.
15200          IF (IFAN. EQ. 1) GO TO 1055
15300          DO 960 L=1, NPTS
15400 C          THIS DO-LOOP COMPUTES "FANP" IN EQUATION IN
15500 C %          4. 1. 9 AT BOTTOM OF PAGE 22
15600 C %          (LAGRANGE'S INTERPOLATION FORMULA).
15700          ANUM=1. 0
15800          ADEN=1. 0
15900          DO 930 M=1, NPTS
16000          IF (M. EQ. L) GOTO 920
16100          ANUM=ANUM*(FANG-QF(J, M))/10000
16200          ADEN=ADEN*(GF(J, L)-GF(J, M))/10000
16300 920          CONTINUE
16400 930          CONTINUE
16500          PART=ANUM*PF(J, L)/ADEN
16600          FANP=FANP+PART
16700 960          CONTINUE
16800          DO 1030 L=1, NPTS
16900 C          COMPUTE "RGRAD" FOR USE IN "ITERATION-MASSAGE-Q":
17000 C %          "RGRAD" IS DERIVATIVE OF "PF" WITH RESPECT TO "QF"
17100          IF (FANG. GT. GF(J, L)) GOTO 1020
17200          IF (L. LT. 2) GOTO 1040
17300          LL=L-1
17400          RGRAD(J)=(PF(J, L)-PF(J, LL))*100000. /(GF(J, L)-GF(J, LL))
17500          GO TO 1050
17600 1020          CONTINUE
17700 1030          CONTINUE
17800 1040          RGRAD(J)=0. 0
17900 C          STICK "FANP" INTO "R" FOR AIRWAY "K"
18000 1050          R(K)=FANP
18100          GO TO 1060
18200 1055          CONTINUE
18300          FANP=CL(J, 1)+CL(J, 2)*Q(K)+CL(J, 3)*Q(K)*Q(K)
18400          R(K)=FANP
18500          RGRAD(J)=CL(J, 2)+2. *CL(3, J)*Q(K)
18600 1060          CONTINUE
18700 1070          CONTINUE
18800 1080          CONTINUE
18900 1090          CONTINUE
19000          IT=IT+1

```

```
19100         ITCT=ITCT+1
19200         C
19300         C ROUTE-TO-APPROPRIATE-PROGRAM-SECTION.
19400         C
19500         IF (IT.LE.1) GOTO 120
19600         IF(DGSUM.LT.0.002) GOTO 1260
19700         IF (ITCT.GT.ITN) GOTO 1220
19800         IF (IT.LE.20) GOTO 110
19900         C             RETURN FOR FAILURE TO CONVERGE USING LOCAL
20000         C %             COUNTER "IT"
20100             NSW=ITRUE
20200             NSFLOW=IFALSE
20300         C             GO TO 20
20400             LGTO20=.TRUE.
20500         C             WRITE(LP,1201)
20600         C1201             FORMAT(1X,'LGTO20=.TRUE. RETURN FROM ITT')
20700             RETURN
20800         C
20900         1220         MARKN=ITRUE
21000         C             WRITE(LP,1241)
21100         C1241             FORMAT(1X,'MARKN=1 RETURN FROM ITT')
21200             RETURN
21300         C
21400         1260         CONTINUE
21500         C             WRITE(LP,1281)
21600         C1281             FORMAT(1X,'DGSUM.LT. 0.002 RETURN FROM ITT')
21700             RETURN
21800         C
21900         END
```

```

100      SUBROUTINE RESIST
200      C      111111111122222222223333333333444444444455555555556666666666777
300      C23456789012345678901234567890123456789012345678901234567890123456789012
400      C
500      C      "RESIST" CALCULATES RESISTANCE OF REGULATORS
600      C      %      AND WRITES NETWORK DATA AFTER ONE
700      C      %      PASS THRU THE NETWORK SECTION.
800      C
900      C      DATA DIVISION.
1000     C      COMMON SECTION.
1100     C
1200     C      INCLUDE 'CTPAM.COM'
1300     C      INCLUDE 'CTCONN.COM'
1400     C      COMMON/SCLR1/ADDT, BI, COR, DIFCH4, FRO, I, ITN, K, MRC, NM, PI, RN, SUMAIR,
1500     C      1TDM, TOLD, X, ARGMT, CH4JS, CP, DIFPR, FX, ICFTM, J, L, MSTART, NREC, POT,
1600     C      2RTCNT, SUMCH4, TFS, TR, AVRCH4, COAGE, CRITGS, DIFTRD, HC, INFLOW, JX, LP,
1700     C      3N, NSTART, PROPJS, SRCH4, SUMHT, TIME, VART, AVRPR, CONTAM, CRITHT, DR,
1800     C      4HEATAD, ISTART, JY, M, NB, NTEMP, QIN, SRPR, SUMPR, TJS, VISC, AVTRD, CONTG,
1900     C      5CRITSM, FD, HKA, ITCT, JZ, MARKC, NJ, OLADDT, QREC, STRD, SUMT, TM, WT,
2000     C      6AX, HSU, ID, NFNUM, NT, ONVP, TO, FACT, H, MADJC, MENDW, NADBC, NSFLOW,
2100     C      7OX, T1, ZDOWN, FNTM, MNO, NSNVP, NVPN, ZUP, INDEX, LX, MARKD, NCONC,
2200     C      8NNVP, NX, ZO, DNVP, KX, MARKN, NETW, NOX, NSW, TSU, Z1, MADJ, MBEGW,
2300     C      9ITRUE, IFALSE
2400     C      COMMON/NETWK/KNUM, JBM, NBL, JEM, KB, NBU, NK, NRETU, NO, Q1, IND,
2500     C      1KCO, MESC, N1, KE, NMIN, NUC, MMIN
2600     C      COMMON/ITTCOM/DQSUM, QBL, ADEN, IT, PART, QBR, RQSUM, ANUM, DP,
2700     C      1NBDR, RG2, TABF, DPSUM, FANP, LL, DG, FANG, NPTS, NABF
2800     C      COMMON/RESCOM/NWRN
2900     C      COMMON/LEAST/ATA(3,3), ATY(3), CL(40,6), LK(5), MQ(5), IFAN
3000     C
3100     C      PROCEDURE DIVISION WITH ENTRY POINT RESIST.
3200     C
3300     C RESIST.
3400     C
3500     C      WRITE(LP, 101)
3600     C101      FORMAT(1X, 'ENTERING RESIST')
3700     C
3800     C CALCULATE-RESISTANCE-OF-REGULATORS.
3900     C
4000     C      MBEGW=1
4100     C      DO 330 K=1, MNO
4200     C          DPSUM=0.
4300     C          MENDW=MEND(K)
4400     C          NX=IABS(MSL(MBEGW))
4500     C          IF (NWTYP(NX).GE.0) GOTO 320
4600     C          M=MBEGW+1
4700     C          DO 270 J=M, MENDW
4800     C              MESSAGE "R" FOR MESH AROUND "STATIC-Q" AIRWAY:
4900     C              %      A STATIC-Q AIRWAY IS CALLED A REGULATOR
5000     C                  N=MSL(J)
5100     C                  FACT=1.
5200     C                  IF (N.GE.0) GOTO 220
5300     C                  N=-N
5400     C                  FACT=-1.
5500     C220      IF (NWTYP(N).LE.0) GOTO 250
5600     C                  DP=-R(N)
5700     C                  GO TO 260
5800     C250      DP=R(N)*Q(N)*ABS(Q(N))
5900     C260      DPSUM=DPSUM+DP*FACT
6000     C270      CONTINUE
6100     C      IF (NVPN.EQ.ITRUE) DPSUM=DPSUM-FNVP(K)
6200     C      RSTD(NX) =-DPSUM/(Q(NX))*2
6300     C      R(NX)=RSTD(NX)

```

```

6400          NWTYP(NX)=0
6500 320      MBEGW=MENDW+1
6600 330      CONTINUE
6700 C
6800 C OUTPUT-OF-NETWORK.
6900 C
7000          DO 400 L=1,NB
7100          IF (NWTYP(L).GT.0) GOTO 380
7200          RQ(L)=R(L)*Q(L)*ABS(Q(L))
7300          GO TO 390
7400 380      RQ(L)=R(L)
7500 390      CONTINUE
7600 400      CONTINUE
7700          WRITE (LP,421)
7800 421      FORMAT (1H1,'          ORDINARY AIRFLOW AND PRESSURE DISTRIBUTION BEFORE EVENT (BASED ON THE LISTED INPUT DATA)')
7900 %
8000          WRITE (LP,441)
8100 441      FORMAT (1H0,T40,'REGULAR AIRWAYS'///' AIRWAY FROM TO ',
8200 1          ' AIRFLOW PRESSURE LOSS LENGTH AREA ',
8300 2          ' RESISTANCE K PERIMETER')
8400          L=0
8500          DO 540 K=1,NB
8600          IF (NWTYP(K).LE.0) GOTO 500
8700          L=L+1
8800          GO TO 530
8900 500      Q(K)=Q(K)*100000.
9000          WRITE(LP,521) NO(K), JS(K), JF(K), Q(K), RQ(K), LA(K), A(K),
9100 %          R(K), KF(K), O(K)
9200 521      FORMAT (15, I7, I7, F13. 0, F13. 3, 8X, I7, F10. 3, F13. 3, I7, F10. 3)
9300 530      CONTINUE
9400 540      CONTINUE
9500          IF (L.GT.0) GOTO 590
9600          WRITE (LP,571)
9700 C          IF YOU INTEND TO HAVE FANS AND YOU GET THIS MESSAGE,
9800 C %          MAKE SURE THAT ALL YOUR AIRWAYS WITH FANS IN THEM
9900 C %          HAVE NWTYP=1 IN YOUR NETWORK AIRWAY CARDS
10000 571      FORMAT (/////' NETWORK CONTAINS NO FANS')
10100          GO TO 770
10200 590      WRITE (LP,601)
10300 601      FORMAT (1H0,T20,'FANS'///' AIRWAY FROM TO AIRFLOW ',
10400 %          ' FAN PRESSURE')
10500          DO 670 K=1,NB
10600          IF (NWTYP(K).LE.0) GOTO 660
10700          Q(K)=Q(K)*100000.
10800          WRITE (LP,651) NO(K), JS(K), JF(K), Q(K), RQ(K)
10900 651      FORMAT (15, I7, I7, F13. 0, F13. 3)
11000 660      CONTINUE
11100 670      CONTINUE
11200          IF (NFNUM.LE.0) GOTO 760
11300          WRITE (LP,701) (NOF(K), K=1, NFNUM)
11400 701      FORMAT(////,' THESE CHARACTERISTICS WERE STORED FOR FANS',
11500 %          10I6)
11600          DO 750 K=1, NFNUM
11700          L=MPTS(K)
11800          WRITE (LP,741) (QF(K, I), PF(K, I), I=1, L)
11900 741      FORMAT (//5(F10. 0, F6. 2)/5(F10. 0, F6. 2))
12000 750      CONTINUE
12100          IF(IFAN.EQ.0) GO TO 2300
12200          WRITE(LP,2000)
12300 2000      FORMAT(//10X,'LINEAR LEAST SQUARES FIT TO FAN DATA')
12400          DO 752 K=1, NFNUM
12500          WRITE(LP,754) K, (CL(K, IK), IK=1, 3)
12600 754      FORMAT(//10X,'K=', I4, 7X, 'CL(K, IK)=', 5(4X, E12. 5))

```

```
12700 752 CONTINUE
12800 2300 CONTINUE
12900 760 CONTINUE
13000 770 WRITE (LP,781) NB,NJ
13100 781 FORMAT (///// ' THE STATED NUMBER OF AIRWAYS WAS', I7, ' THE',
13200 % ' STATED NUMBER OF JUNCTIONS WAS', I7)
13300 DO 830 K=1,NFNUM
13400 NWRN=NFCW(K)
13500 IF (NWRN.EQ. ITRUE) WRITE (LP,821)NOF(K)
13600 821 FORMAT(///// ' THE FAN CHARACTERISTIC IS EXCEEDED FOR FAN NO',
13700 % I5)
13800 830 CONTINUE
13900 C
14000 C RESIST-EXIT.
14100 C
14200 C WRITE(LP,851)
14300 C851 FORMAT(1X, 'RETURN FROM RESIST')
14400 C RETURN
14500 C
14600 C END
```

```

100      SUBROUTINE RDCONC
200      C          1111111111222222222233333333333444444444455555555556666666666777
300      C23456789012345678901234567890123456789012345678901234567890123456789012
400      C
500      C          _RDCONC_ READS DATA FOR THE SCENARIO FOR THIS PARTICULAR MINE
600      C          NETWORK AND INITIALIZES THE CURRENT SCENARIO.
700      C
800      C
900      C
1000     C          DATA DIVISION.
1100     C          COMMON SECTION.
1200     C          INCLUDE 'CTPAM.COM'
1300     C          INCLUDE 'CTCDNN.COM'
1400     C          COMMON/SCLR1/ADDT, BI, COR, DIFCH4, FRO, I, ITN, K, MRC, NM, PI, RN, SUMAIR,
1500     C          1TDM, TOLD, X, ARGMT, CH4JS, CP, DIFPR, FX, ICFTM, J, L, MSTART, NREC, POT,
1600     C          2RTCONT, SUMCH4, TFS, TR, AVRCH4, CDAGE, CRITGS, DIFTRD, HC, INFLOW, JX, LP,
1700     C          3N, NSTART, PROPCS, SRCH4, SUMHT, TIME, VART, AVRPR, CONTAM, CRITHT, DR,
1800     C          4HEATD, ISTART, JY, M, NB, NTEMP, QIN, SRPR, SUMPR, TJS, VISC, AVTRD, CONTQ,
1900     C          5CRITSM, FO, HKA, ITCT, JZ, MARKC, NJ, OLADDT, QREC, STRD, SUMT, TM, WT,
2000     C          6AX, HSU, ID, NFNUM, NT, DNVP, TO, FACT, H, MADJC, MENDW, NADBC, NSFLOW,
2100     C          7OX, T1, ZDOWN, FNTM, MNO, NSNVP, NVPN, ZUP, INDEX, LX, MARKD, NCONC,
2200     C          8NNVP, NX, ZO, DNVP, KX, MARKN, NETW, NOX, NSW, TSU, Z1, MADJ, MBEGW,
2300     C          9ITRUE, IFALSE
2400     C          COMMON/NETWK/KNUM, JBM, NBL, JEM, KB, NBU, NK, NRETU, NO, Q1, IND,
2500     C          1KCO, MESC, N1, KE, NMIN, NUC, MMIN
2600     C          COMMON/ITTCOM/DQSUM, QBL, ADEN, IT, PART, QBR, RQSUM, ANUM, DP,
2700     C          1NBDR, RG2, TABF, DPSUM, FANP, LL, DG, FANG, NPTS, NABF
2800     C          COMMON/RESCOM/NWRN
2900     C          COMMON/WRTCOM/MINREV, JFF, NRCT, MEMI, WRNHT, WRNPR, WRNSM,
3000     C          1WRNSUM, WRNGS
3100     C          COMMON/RDCCOM/AAVR, CH4CX, CH4VX, ES, HAX, HKX, KFAVR, CH4F,
3200     C          1JNOX, NAV, NCH4C, JSTART, CH4PAX, DZRD, NDIM, OAVR, CH4S,
3300     C          2HAAVR, HKA, LAADR, LAADR, MAXJ, TSTART, TRF, TROCKX, TAVR, TRS, EF
3400     C          COMMON/RTMCOM/MRKL
3500     C
3600     C          PROCEDURE DIVISION
3700     C          WITH ENTRY POINT RDCONC.
3800     C
3900     C
4000     C          CONCENTRATION PART OF PROGRAM
4100     C
4200     C RDCONC.
4300     C
4400     C          WRITE(LP, 101)
4500     C101          FORMAT(1X, 'ENTERING RDCONC')
4600     C          PI=3.141593
4700     C          NSFLOW=IFALSE
4800     C          ITCT=0
4900     C
5000     C READ-AND-COMplete-INPUT-DATA.
5100     C
5200     C          READ ONE CONCENTRATION-CONTROL CARD
5300     C          READ(ID, 151) NDIM, NCH4C, NAV, MAXJ, INFLOW, JSTART, TSTART, TIME, CRITSM,
5400     C          ;          CRITGS, CRITHT, WRNPR, WRNSM, WRNGS, WRNHT
5500     C151          FORMAT (6I5, F5. 1, F8. 2, F7. 5, F5. 3, F6. 3, F4. 2, F6. 4, F4. 1, F5. 0)
5600     C          IF (NAV.NE. IFALSE)NAV=ITRUE
5700     C          IF(NAV)READ ONE CONCENTRATION AVERAGE-VALUE CARD
5800     C          IF(NAV.EQ. ITRUE)READ (ID, 181) TAVR, HAAVR, HKA, KFAVR,
5900     C          ;          LAADR, AADR, OADR
6000     C181          FORMAT (3F10. 5, 2I10, 2F10. 2)
6100     C          IF (NDIM.LE. 0)GOTO 430
6200     C          L=0
6300     C          DO 370 I=1, NDIM

```

```

6400 C          IF (NDIM. GT. 0) READ CONCENTRATION AIRWAY CARDS
6500          READ (IO, 231) NOX, CH4VX, CH4PAX, TROCKX, HAX, HKX, DZRDX
6600 231          FORMAT (I5, F10. 2, 4F10. 5, F10. 1)
6700          DO 260 J=1, NB
6800          IF (NOX. EQ. NO(J)) GOTO 280
6900 260          CONTINUE
7000          GO TO 360
7100 280          L=L+1
7200          CH4V(J)=CH4VX
7300          RDCH4(J)=CH4PAX
7400          TROCK(J)=TROCKX
7500          HA(J)=HAX
7600          HK(J)=HKX
7700          DZRDX(J)=DZRDX
7800          NO(J)=-NO(J)
7900 360          CONTINUE
8000 370          CONTINUE
8100          IF (NDIM. EQ. L) GOTO 420
8200          WRITE (LP, 401)
8300 C          HERE% WRONG NUMBER OF CONCENTRATION AIRWAY CARDS OR
8400 C          ;          AT LEAST ONE _NOX_ IS NOT (REPEAT% NOT )
8500 C          ;          INCLUDED IN (NO(I), I=1, NB)
8600 401          FORMAT (/////, ' MISTAKE IN CONCENTRATION AIRWAY CARDS%',
8700          ;          /, ' INVALID AIRWAY NUMBER OR WRONG NUMBER OF ',
8800          ;          ' AIRWAY CONCENTRATION CARDS. '
8900          ;          /, 10X, ' RUN ABORTED. ', //, 10X, ' END OF RUN. ')
9000          STOP
9100 C
9200 420          CONTINUE
9300          MRKL=0
9400 430          DO 720 I=1, NB
9500 C          THIS DO-LOOP STICKS AVERAGE VALUES IN AIRWAY DATA
9600 C          ;          NOT GREATER THAN 0
9700          IF (NO(I). LT. 0) GOTO 550
9800          IF (NETW. EQ. ITRUE. AND. NTEMP. EQ. ITRUE. AND. NCONC. EQ. ITRUE)
9900          ;          GOTO 470
10000          IF (NCONC. EQ. ITRUE) GOTO 710
10100 470          IF (NAV. EQ. ITRUE) GOTO 510
10200          WRITE (LP, 491)
10300 491          FORMAT (/////////, ' INSUFFICIENT DESCRIPTION OF AIRWAY',
10400          1          ' PROPERTIES' //, 6X, '(AVERAGE-VALUE CARD ',
10500          2          ' REQUIRED FOR AIRWAYS NOT ON CONCENTRATION'
10600          3          ' AIRWAY CARDS)' //, 10X, ' RUN ABORTED. ',
10700          4          //, 10X, ' END OF RUN. '//)
10800          STOP
10900 C
11000 510          NO(I)=-NO(I)
11100          HA(I)=HA AVR
11200          HK(I)=HK AVR
11300          GO TO 580
11400 550          IF (NAV. NE. ITRUE) GOTO 620
11500          IF (HA(I). LE. 0. 0) HA(I)=HA AVR
11600          IF (HK(I). LE. 0. 0) HK(I)=HK AVR
11700 580          IF (KF(I). LE. 0) KF(I)=KFAVR
11800          IF (LA(I). LE. 0) LA(I)=LA AVR
11900          IF (LA(I). LE. 0) MRKL=MRKL+1
12000          IF (A(I). LE. 0) MRKL=MRKL+1
12100          IF (A(I). LE. 0. 0) A(I)=AAVR
12200          IF (O(I). LE. 0. 0) O(I)=O AVR
12300 620          IF (TROCK(I). GT. 0. 0) GOTO 700
12400          IF (NVPN. EQ. ITRUE) GOTO 670
12500          IF (NAV. NE. ITRUE) GOTO 690
12600          TROCK(I)=TA VR

```

```

12700          GO TO 680
12800      670          NO(I)=-NO(I)
12900      680          CONTINUE
13000      690          CONTINUE
13100      700          CONTINUE
13200      710          CONTINUE
13300      720          CONTINUE
13400          DO 1040 J=1,NB
13500      C          THIS DO-LOOP COMPUTES _TROCK_S NOT ON YOUR CONCENTRATION
13600      C ;          AIRWAY CARDS FROM JUNCTION DATA% IF JUNCTION DTAT IS
13700      C ;          NOT AVAILABLE, THEN AVERAGE _TROCK_ FROM
13800      C ;          _TAVR_ IS USED
13900          IF (NO(J).GT.0) GOTO 770
14000          NO(J)=-NO(J)
14100          GO TO 1030
14200      770          ES=0.0
14300          EF=0.0
14400          TRS=0.0
14500          TRF=0.0
14600          L=IFALSE
14700          M=IFALSE
14800          DO 950 I=1,NJ
14900          IF (JS(J).NE.JNO(I)) GOTO 890
15000          ES=PROP(I)
15100          TRS=T(I)
15200          L=ITRUE
15300          GO TO 940
15400      890          IF (JF(J).NE.JNO(I)) GOTO 930
15500          EF=PROP(I)
15600          TRF=T(I)
15700          M=ITRUE
15800          CONTINUE
15900      940          IF (L.EQ.ITRUE.AND.M.EQ.ITRUE) GOTO 970
16000      950          CONTINUE
16100      C
16200      C          END DO((I), I=1,NJ);
16300          GO TO 1010
16400      970          IF (DZRD(J).EQ.0.0) DZRD(J)=EF-ES
16500      C          _X_ EQUATION% MIDDLE OF PAGE 29.
16600          X=0.014*D(J)/(A(J)**0.8*(ABS(G(J)))**0.2)
16700      C          _TROCK_ EQUATION% BOTTOM OF PAGE 29%
16800      C ;          _TRF_ IS _T2_, _TRS_ IS _T1_
16900      C          TROCK(J)=(TRF-TRS*EXP(-X*LA(J))+DZRD(J)/187.)/(1.-EXP
17000      C ;          (-X*LA(J))-DZRD(J)/(2.*187.))
17100          XLA=X*FLOAT(LA(J))
17200          TROCK(J)=(TRF-TRS*EXP(-XLA)+DZRD(J)/187.)/(1.-EXP
17300      1          (-XLA))-DZRD(J)/(2.*187.))
17400          IF (TROCK(J).GT.0.0)GOTO 1020
17500      1010          TROCK(J)=TAVR
17600      1020          CONTINUE
17700      1030          CONTINUE
17800      1040          CONTINUE
17900      C
18000      C SET-UP-JNO-LIST.
18100      C
18200          IF (NVPN.EQ.ITRUE) GOTO 1210
18300          L=1
18400          DO 1150 I=1,MAXJ
18500          DO 1100 J=1,NB
18600          IF (JS(J).EQ.I) GOTO 1120
18700      1100          CONTINUE
18800          GO TO 1140
18900      1120          JNO(L)=JS(J)

```

```

19000          L=L+1
19100      1140      CONTINUE
19200      1150      CONTINUE
19300          IF (NJ.EQ.(L-1)) GOTO 1200
19400          WRITE (LP,1181)
19500      C          WRITE(5,1234) NJ,L
19600      C1234      FORMAT(2(4X, I4))
19700      C          LM1=L-1
19800      C1235      FORMAT(5(3X, I4))
19900      C          WRITE(2,1235) (JNO(J),J=1,LM1)
20000      C          WRITE(5,1235) (JNO(J),J=1,LM1)
20100      C          ALL JUNCTION NUMBERS MUST BE (JNO.LE.MAXJ), OR YOU
20200      C ;          WILL GET THIS MESSAGE ALSO, JUST AS IF YOU HAD
20300      C ;          ENTERED THE WRONG NUMBER IN _NJ_Z_ IN THIS
20400      C ;          CASE, ANY (JNO.GT.MAXJ) WILL NOT BE USED
20500      1181      FORMAT(/////,' STATED NUMBER OF JUNCTIONS IS WRONG AND ',
20600      ;          'HAS BEEN CORRECTED')
20700          NJ=L-1
20800      C
20900      C CALCULATE-METHANE-EVOLUTION.
21000      C
21100      1200      CONTINUE
21200      1210      IF (NCH4C.LE.0) GOTO 1360
21300          L=0
21400          DO 1330 I=1,NCH4C
21500      C          IF(NCH4C.GT.0)READ CONCENTRATION JUNCTION CARDS
21600          READ (IO,1251) JNOX,CH4CX
21700      1251      FORMAT (I5,T26,F5.2)
21800          DO 1280 J=1,NJ
21900          IF (JNOX.EQ.JNO(J)) GOTO 1300
22000      1280      CONTINUE
22100          GO TO 1320
22200      1300      PRCH4(J)=CH4CX
22300          L=L+1
22400      1320      CONTINUE
22500      1330      CONTINUE
22600          IF (NCH4C.NE.L) WRITE(LP,1351)
22700      1351      FORMAT (/////,' MISTAKE IN CONCENTRATION JUNCTION CARDS',
22800      ;          ',,6X,'(CHECK FOR VALID _JNO_ IN EACH CARD AND',
22900      ;          ' FOR RIGHT NUMBER OF CARDS). ')
23000      1360      DO 1580 I=1,NB
23100          IF (CH4V(I).GT.0.0) GOTO 1570
23200      C          IF(CH4V(I).LE.0)COMPUTE DEFAULT METHANE VOLUME
23300      C ;          PRODUCTION FOR THIS AIRWAY
23400      C          CH4V(I)=RDCH4(I)*LA(I)*O(I)
23500          CH4V(I)=RDCH4(I)*FLOAT(LA(I))*O(I)
23600          IF (CH4V(I).GT.0.0)GOTO 1560
23700          M=IFALSE
23800          N=IFALSE
23900
24000          DO 1500 L=1,NJ
24100          IF (JS(I).NE.JNO(L)) GOTO 1460
24200          CH4S=PRCH4(L)
24300          M=ITRUE
24400      1460      IF (JF(I).NE.JNO(L))GOTO 1490
24500          CH4F=PRCH4(L)
24600          N=ITRUE
24700      1490      IF (M.EQ.ITRUE.AND.N.EQ.ITRUE) GOTO 1530
24800      1500      CONTINUE
24900      C
25000      1510          CH4V(I)=0.0
25100          GO TO 1550
25200      1530      IF (CH4F.LE.CH4S) GOTO 1510

```

```

25300          CH4V(I)=(CH4F-CH4S)*Q(I)/100.0
25400 1550    CONTINUE
25500 1560    CONTINUE
25600 1570    CONTINUE
25700 1580    CONTINUE
25800 C
25900          NRCT=0
26000 C          IF(INFLOW.GT.0)READ CONTAMINATION CARDS
26100          IF (INFLOW.GT.0)READ (IO,1611) (NCENT(I),CONT(I),CONC(I),HEAT(I),
26200          ;          O2MIN(I),SMPO2(I),HTPO2(I),I=1,INFLOW)
26300 1611          FORMAT (I5,F10.0,F10.5,F10.2,3F10.5)
26400 C
26500 C WRITE-CONC-INPUT-DATA.
26600 C
26700          WRITE (LP,1631)
26800 1631          FORMAT(1H1,T21,'INPUT DATA FOR CONCENTRATION AND TEMPERATURE',
26900          1          ' CALCULATIONS'///'AIRWAY FROM          TO          ELEVATION DIFF',
27000          2          ' ROCK TEMP.          METHANE PROD.          CONDUCTIVITY          ',
27100          3          'DIFFUSIVITY')
27200          WRITE(LP,1651) (NO(I),JS(I),JF(I),DZRD(I),TROCK(I),CH4V(I),HK(I),
27300          ;          HA(I),I=1,NB)
27400 1651          FORMAT (I5,2I7,T25,F10.1,T40,F10.1,T56,F10.1,T72,F10.1,T89,
27500          ;          F10.4)
27600          WRITE (LP,1671) TIME
27700 1671          FORMAT (////,T20,' TIME AFTER BEGINNING OF EVENT',F7.2,' ',
27800          ;          'HOURS')
27900          WRITE (LP,1691) TSTART,JSTART
28000 1691          FORMAT (////,T20,' A TEMPERATURE OF',F6.1,' WAS ASSIGNED TO',
28100          ;          ' JUNCTION NO',I7)
28200          IF (INFLOW.LE.0) GOTO 1760
28300          WRITE (LP,1721)
28400 1721          FORMAT(////,T25,' THE FOLLOWING CONTAMINATION WAS ASSUMED',
28500          1          '//,T18,'CONTAMINATION',T43,'OXYGEN CONCENTRATION',T67,
28600          2          'PRODUCTION PER CU FT OXYGEN',/,,'AIRWAY FLOWRATE ',
28700          3          'CONCENTRAT.          HEAT          BEHIND FIRE          ',
28800          4          'SMOKE          HEAT')
28900          WRITE(LP,1741) (NCENT(I),CONT(I),CONC(I),HEAT(I),O2MIN(I),
29000          ;          SMPO2(I),HTPO2(I),I=1,INFLOW)
29100 1741          FORMAT (I6,F11.3,F11.3,F12.3,9X,F6.2,10X,F8.3,7X,F8.3)
29200          GO TO 1780
29300 1760          WRITE (LP,1771)
29400 1771          FORMAT (/////,T20,' NO CONTAMINATION WAS SPECIFIED')
29500 1780    CONTINUE
29600 C          WRITE(LP,1801)
29700 C1801          FORMAT(1X,'RETURN FROM RDCONC')
29800          RETURN
29900 C
30000          END

```

```

200      SUBROUTINE FLOWSK
300      C      111111111122222222223333333333444444444455555555556666666666777
400      C23456789012345678901234567890123456789012345678901234567890123456789012
500      C
600      C      "FLOWSK" RECORDS AIRFLOW-REVERSALS IN "NRCT" VECTOR
700      C      %      GENERATES FLOWScheme IN "INU", "KJS", "KJF", "KNO",
800      C      %      AND "JNOL" LISTS, AND SELECTS INITIAL
900      C      %      JUNCTION FROM "JSTART".
1000     C
1100     C      DATA DIVISION.
1200     C      COMMON SECTION.
1300     C
1400     C      INCLUDE 'CTPAM.COM'
1500     C      INCLUDE 'CTCONN.COM'
1600     C      COMMON/SCLR1/ADDT, BI, COR, DIFCH4, FRO, I, ITN, K, MRC, NM, PI, RN, SUMAIR,
1700     C      1TDM, TOLD, X, ARGMT, CH4JS, CP, DIFPR, FX, ICFTM, J, L, MSTART, NREC, POT,
1800     C      2RTCONT, SUMCH4, TFS, TR, AVRCH4, CDAGE, CRITGS, DIFTRD, HC, INFLOW, JX, LP,
1900     C      3N, NSTART, PROPJS, SRCH4, SUMHT, TIME, VART, AVRPR, CONTAM, CRITHT, DR,
2000     C      4HEATAD, ISTART, JY, M, NB, NTEMP, QIN, SRPR, SUMPR, TJS, VISC, AVTRD, CONTQ,
2100     C      5CRITSM, FO, HKA, ITCT, JZ, MARKC, NJ, OLADDT, GREC, STRD, SUMT, TM, WT,
2200     C      6AX, HSU, IO, NFNUM, NT, DNVP, TO, FACT, H, MADJC, MENDW, NADBC, NSFLOW,
2300     C      7OX, T1, ZDOWN, FNTM, MNO, NSNVP, NVPN, ZUP, INDEX, LX, MARKD, NCONC,
2400     C      8NNVP, NX, ZO, DNVP, KX, MARKN, NETW, NOX, NSW, TSU, Z1, MADJ, MBEGW,
2500     C      9ITRUE, IFALSE
2600     C      COMMON/NETWK/KNUM, JBM, NBL, JEM, KB, NBU, NK, NRETU, NO, Q1, IND,
2700     C      1KCO, MESC, N1, KE, NMIN, NUC, MMIN
2800     C      COMMON/ITTCOM/DGSUM, QBL, ADEN, IT, PART, QBR, RQSUM, ANUM, DP,
2900     C      1NBDR, RG2, TABF, DPSUM, FANP, LL, DQ, FANG, NPTS, NABF
3000     C      COMMON/RESCOM/NWRN
3100     C      COMMON/WRTCOM/MINREV, JFF, NRCT, MEMI, WRNHT, WRNPR, WRNSM,
3200     C      1WRNSUM, WRNGS
3300     C      COMMON/RDCCOM/AAVR, CH4CX, CH4VX, ES, HAX, HKX, KFAVR, CH4F,
3400     C      1JNOX, NAV, NCH4C, JSTART, CH4PAX, DZRD, NDIM, DAVR, CH4S,
3500     C      2HAAVR, HKA, LA, LAVR, MAXJ, TSTART, TRF, TROCKX, TAVR, TRS, EF
3600     C      COMMON/FLOCOM/MM
3700     C
3800     C      PROCEDURE DIVISION WITH ENTRY POINT FLOWScheme.
3900     C
4000     C      FLOWScheme.
4100     C      WRITE(LP, 111)
4200     C111      FORMAT(1X, 'ENTERING FLOWSK')
4300     C
4400     C      CHECK-FOR-AIRFLOW-REVERSALS.
4500     C
4600     C      NSFLOW=ITRUE
4700     C      DO 320 I=1, NB
4800     C          IF (Q(I).GE.0) GOTO 310
4900     C          NSFLOW=IFALSE
5000     C          J=JS(I)
5100     C          JS(I)=JF(I)
5200     C          JF(I)=J
5300     C          Q(I)=-Q(I)
5400     C          DZRD(I)=-DZRD(I)
5500     C          IF (NRCT.LE.0)GOTO 280
5600     C          DO 270 L=1, NRCT
5700     C              IF (NREV(L).NE.I) GOTO 260
5800     C              NREV(L)=0
5900     C              GO TO 300
6000     C          CONTINUE
6100     C          CONTINUE
6200     C          NRCT=NRCT+1
6300     C          NREV(NRCT)=I
6400     C          CONTINUE

```

```

6500 310      CONTINUE
6600 320      CONTINUE
6700 C
6800 C PACK-AIRFLOW-REVERSALS-IN-NREV.
6900 C
7000      IF (NRCT. LE. 0)GOTO 420
7100      L=0
7200      DO 400 I=1, NRCT
7300          IF (NREV(I). LE. 0)GOTO 390
7400          L=L+1
7500          NREV(L)=NREV(I)
7600 390      CONTINUE
7700 400      CONTINUE
7800      NRCT=L
7900 C
8000 C MAKE-INU-KJS-KJF-KNO-JNOL-LIST.
8100 C
8200 420      L=0
8300          M=0
8400          N=1
8500      DO 660 I=1, MAXJ
8600          K=L
8700          DO 520 J=1, NB
8800              IF (JS(J). NE. I) GOTO 510
8900 C          AIRWAY "J" LEAVES JUNCTION "I": STICK IN "INU" LIST
9000          L=L+1
9100          INU(L)=J
9200 C          WRITE(2, 1234) I, L, JS(J), INU(L)
9300 C1234          FORMAT(4X, 'I, L, JS(J), INU(L)', 4(3X, I4))
9400 510      CONTINUE
9500 520      CONTINUE
9600 C          "KJS(N)" GETS LAST "L" IN "INU" LIST
9700 C %      FOR AIRWAYS LEAVING JUNCTION "I"
9800          KJS(N)=L
9900 C          WRITE(2, 1235) N, KJS(N)
10000 C1235          FORMAT(4X, 'N, KJS(N)', 2(3X, I4))
10100          MM=M
10200      DO 600 J=1, NB
10300          IF (JF(J). NE. I) GOTO 590
10400 C          AIRWAY "J" ENTERS JUNCTION "I": STICK IN "KJF" LIST
10500          M=M+1
10600          KJF(M)=J
10700 C          WRITE(2, 1236) I, M, JF(J), KJF(M)
10800 C1236          FORMAT(4X, 'I, M, JF(J), KJF(M)', 4(3X, I4))
10900 590      CONTINUE
11000 600      CONTINUE
11100 C          "KNO(N)" GETS LAST "L" IN "KJF" LIST
11200 C %      FOR AIRWAYS LEAVING JUNCTION "I"
11300          KNO(N)=M
11400          IF ((MM. EQ. M). AND. (K. EQ. L)) GO TO 650
11500 C          IF THIS JUNCTION IS USED, THEN "JNOL(N)"
11600 C %      ("N" IS THE SAME SUBSCRIPT FOR "KJS" AND "KNO")
11700 C %      GETS AIRWAY NUMBER FROM "I"
11800          JNOL(N)=I
11900          N=N+1
12000 650      CONTINUE
12100 660      CONTINUE
12200 C
12300 C RELATE-JND-AND-JNOL-LISTS.
12400 C
12500 C          WRITE(2, 889) (JND(IK), IK=1, NJ)
12600 C          WRITE(2, 889) (JNOL(IK), IK=1, NJ)
12700 C889          FORMAT(5(3X, I4))

```

```

12800      DO 740 I=1,NJ
12900          PROP(I)=0.0
13000          PRCH4(I)=0.0
13100          DO 720 J=1,NJ
13200              IF (JNOL(I).EQ.JND(J)) GOTO 730
13300      720      CONTINUE
13400      C          "JLR" CONTAINS THE "JNO" SUBSCRIPT FOR
13500      C      %          THE CURRENT "JNOL"
13600      730      JLR(I)=J
13700      740      CONTINUE
13800      C
13900      C INDICES-OF-STARTING-JUNCTION.
14000      C
14100      C          GENERATE "MSTART" AND RELATED VARIABLES
14200      C          NOTE: PROPOSED CHANGES FOR DEFAULT "JSTART" HAVE BEEN
14300      C      %          COMMENTED-OUT BECAUSE THERE WAS NO TIME TO TEST THEM
14400      C          LSTART=ITRUE
14500          DO 770 I=1,NJ
14600              IF (JNOL(I).EQ.JSTART) GOTO 780
14700      770      CONTINUE
14800      C          I=1
14900      C          LSTART=IFALSE
15000      780      MSTART=I
15100          ISTART=JLR(I)
15200          T(ISTART)=TSTART
15300      C          IF(LSTART.NE.ITRUE)WRITE(LP,805)JNOL(I)
15400      C805          FORMAT(3X,'INVALID JUNCTION NUMBER IN "JSTART": ',
15500      C      %          'DEFAULT IS',I4)
15600      C          WRITE(LP,821)
15700      C821          FORMAT(1X,'RETURN FROM FLOWSK')
15800      C          RETURN
15900      C          END

```

```

200      SUBROUTINE ROADWY
300      C      1111111111222222222233333333333444444444455555555556666666666777
400      C23456789012345678901234567890123456789012345678901234567890123456789012
500      C
600      C      "ROADWY" DOES THE ITERATIONS FOR WHAT HAPPENS AT THE
700      C      ROADWAY JUNCTIONS DURING OUR DISASTER SCENE
800      C
900      C      DATA DIVISION.
1000     C      COMMON SECTION.
1100     C
1200     C      INCLUDE 'CTPAM.COM'
1300     C      INCLUDE 'CTCDNN.COM'
1400     C      COMMON/SCLR1/ADDT, BI, CDR, DIFCH4, FRO, I, ITN, K, MRC, NM, PI, RN, SUMAIR,
1500     C      1TDM, TOLD, X, ARGMT, CH4JS, CP, DIFPR, FX, ICFTM, J, L, MSTART, NREC, POT,
1600     C      2RTCONT, SUMCH4, TFS, TR, AVRCH4, COAGE, CRITGS, DIFTRD, HC, INFLOW, JX, LP,
1700     C      3N, NSTART, PROPJS, SRCH4, SUMHT, TIME, VART, AVRPR, CONTAM, CRITHT, DR,
1800     C      4HEATAD, ISTART, JY, M, NB, NTEMP, QIN, SRPR, SUMPR, TJS, VISC, AVTRD, CONTG,
1900     C      5CRITSM, FO, HKA, ITCT, JZ, MARKC, NJ, OLADDT, GREC, STRD, SUMT, TM, WT,
2000     C      6AX, HSU, IO, NFNUM, NT, ONVP, TO, FACT, H, MADJC, MENDW, NADBC, NSFLOW,
2100     C      7DX, T1, ZDOWN, FNTM, MNO, NSNVP, NVPN, ZUP, INDEX, LX, MARKD, NCONC,
2200     C      8NNVP, NX, ZO, DNVP, KX, MARKN, NETW, NOX, NSW, TSU, Z1, MADJ, MBEGW,
2300     C      9ITRUE, IFALSE
2400     C      COMMON/NETWK/KNUM, JBM, NBL, JEM, KB, NBU, NK, NRETU, NO, Q1, IND,
2500     C      1KCO, MESC, N1, KE, NMIN, NUC, MMIN
2600     C      COMMON/ITTCOM/DGSUM, GBL, ADEN, IT, PART, QBR, RGSUM, ANUM, DP,
2700     C      1NBDR, RQ2, TABF, DPSUM, FANP, LL, DQ, FANG, NPTS, NABF
2800     C
2900     C      WORKING-STORAGE SECTION.
3000     C      INTEGER LTEMP, IKJS
3100     C      REAL XDUM, CONTM1, DENOM, DENOM1, DENOM2
3200     C      LABEL ICKY
3300     C
3400     C      PROCEDURE DIVISION WITH ENTRY POINT ROADWY.
3500     C
3600     C ROADWY.
3700     C
3800     C      MRC=0
3900     C      MARKC=IFALSE
4000     C
4100     C CONDITIONS-AT-ALL-ROADWAY-ENDS.
4200     C
4300     C      100  L=ISTART
4400     C      NSTART=MSTART
4500     C
4600     C CONDITIONS-SELECTED-ROAD-ENDS.
4700     C
4800     C      120  CONTINUE
4900     C      130  PROPJS=PROP(L)
5000     C      JX=L
5100     C      CH4JS=PRCH4(L)
5200     C      JND(L)=-JND(L)
5300     C      JY=1
5400     C      "JY" IS SUBSCRIPT FOR THE FIRST AIRWAY
5500     C      %      (IN "INU(JY)") LEAVING THE JUNCTION IN "JNOL(NSTART)"
5600     C      IF(NSTART.GT.1)JY=KJS(NSTART-1)+1
5700     C      "JZ" IS SUBSCRIPT FOR THE LAST AIRWAY
5800     C      %      (IN "INU(JZ)") LEAVING THE JUNCTION IN "JNOL(NSTART)"
5900     C      JZ=KJS(NSTART)
6000     C      WRITE(LP, 211) JY, JZ, NSTART, MSTART, L, (KJS(IKJS), IKJS=1, 80)
6100     C211     C      FORMAT(1X, 'ROADWYL211: JY, JZ, NSTART, MSTART, L, KJS=', 5I3, 2(/40I3))
6200     C      WRITE(LP, 231) (JLR(IKJS), IKJS=1, 80)
6300     C231     C      FORMAT(5X, 'JLR ='2(/40I3))
6400     C      DO 280 K=JY, JZ

```

```

6500 C      PERFORM CK-CONC-CHANGE-AND-ADDED-HEAT THRU AIRWAY-BOOGIE
6600 C      %      VARYING K FROM JY BY 1 UNTIL K > JZ.
6700 C      THIS "PERFORM" LOOP CRUNCHES TEMPERATURES AND
6800 C      %      CONCENTRATION CHANGES FOR ALL AIRWAYS LEAVING
6900 C      %      JUNCTION "JNOL(NSTART)"
7000 C      IF(JY.EQ.JZ) WRITE(5,1234) JY,JZ,NSTART,INU(JY)
7100 C      1 ,JNOL(NSTART)
7200 C1234 FORMAT(5(4X,I4))
7300 C      IF(JY.EQ.JZ) STOP
7400 C      ASSIGN 270 TO ICKY
7500 C      GOTO 1660
7600 270    CONTINUE
7700 280    CONTINUE
7800 C
7900 C      CONDITIONS-IN-JUNCTIONS.
8000 C
8100 C      COMPUTE "PROP", "PRCH4", AND "T" FOR NEXT JUNCTION FROM
8200 C      %      AIRWAYS ENTERING JUNCTION. CHOOSE NEXT
8300 C      %      JUNCTION FOR TEMPERATURE AND CONC. CHANGES ON
8400 C      %      AIRWAYS LEAVING IT
8500 C      DO 570 I=1,NJ
8600 C      L=JLR(I)
8700 C      IF (JND(L).LT.0)GOTO 560
8800 C      "JND" GETS FLAGGED NEGATIVE JUST BEFORE THE
8900 C      %      "PERFORM" LOOP TO COMPUTE TEMPERATURE AND CONC.
9000 C      %      CHANGES ON AIRWAYS LEAVING IT
9100 C      JY=1
9200 C      IF(I.NE.1)JY=KND(I-1)+1
9300 C      JZ=KND(I)
9400 C      SUMAIR=0.0
9500 C      SUMPR=0.0
9600 C      SUMCH4=0.0
9700 C      SUMHT=0.0
9800 C      DO 460 K=JY,JZ
9900 C      "KJF" IS AIRWAY ENTERING JUNCTION: HUNT FOR
10000 C      %      TEMPERATURE AND CONC. CHANGES FOR ALL AIRWAYS
10100 C      %      ENTERING THIS JUNCTION
10200 C      J=KJF(K)
10300 C      IF(JF(J).GE.0)GOTO 550
10400 C      "JF" GETS FLAGGED NEGATIVE IN "AIRWAY-BOOGIE" AT
10500 C      %      THE TAIL END OF THE "PERFORM" LOOP TO COMPUTE
10600 C      %      TEMPERATURE AND CONC. CHANGES FOR AIRWAYS
10700 C      SUMAIR=SUMAIR+Q(J)
10800 C      SUMPR=SUMPR+RDPROP(J)*Q(J)
10900 C      SUMCH4=SUMCH4+RDCH4(J)*Q(J)
11000 C      SUMHT=SUMHT+TRD(J)*Q(J)*(0.2376+0.000024*TRD(J))
11100 460    CONTINUE
11200 C      IF YOU FALL THRU TO HERE, YOU HAVE FOUND A
11300 C      %      JUNCTION WHICH HAS TEMPERATURE AND CONC.
11400 C      %      COMPUTED FOR ALL AIRWAYS ENTERING (BUT
11500 C      %      NOT ALL AIRWAYS LEAVING) IT:
11600 C      %      GET "PROP", "PRCH4", AND "T" FOR THIS JUNCTION
11700 C      %      AND THEN GO BACK TO "CONDITIONS-SELECTED-
11800 C      %      ROAD-ENDS" FOR THE NEXT JUNCTION
11900 C      NSTART=I
12000 C      PROP(L)=SUMPR/SUMAIR
12100 C      PRCH4(L)=SUMCH4/SUMAIR
12200 C      RTCONT=4950.**2.+SUMHT/(SUMAIR*0.000024)
12300 C      T(L)=-4950.+SQRT(RTCONT)
12400 C      WRITE(LP,531) L,JND(L)
12500 C531    FORMAT(1X,'ROADWYL531:HERE FROM JND(L).GE.0:L,JND(L)='',2I5)
12600 C      GO TO 130
12700 C

```

```

12800 550      CONTINUE
12900 560      CONTINUE
13000 570      CONTINUE
13100 C          DNCE YOU GET HERE, EACH JUNCTION HAS:
13200 C %          (1) TEMPERATURE AND CONC. CHANGES COMPUTED FOR ALL
13300 C %          AIRWAYS LEAVING IT, .OR. (2) TEMPERATURE AND CONC.
13400 C %          CHANGES COMPUTED FOR NOT ALL AIRWAYS
13500 C %          ENTERING IT
13600      NREC=1
13700 C
13800 C RECIRCULATION-FIRST-APPROXIMATION.
13900 C
14000 590      CONTINUE
14100 C          REPEAT UNTIL (L. GE. NJ);
14200      L=0
14300      DO 930 I=1, NJ
14400          IF(JND(I). GT. 0)GOTO 640
14500          L=L+1
14600          GO TO 920
14700 640      CONTINUE
14800 C          THIS JUNCTION DID NOT GET TEMPERATURE AND CONC.
14900 C %          CHANGES COMPUTED FOR ITS EXITING AIRWAYS
15000      N=0
15100      M=0
15200      SRPR=0. 0
15300      SRCH4=0. 0
15400      STRD=0. 0
15500      QIN=0. 0
15600      GREC=0. 0
15700      DO 850 J=1, NB
15800          IF(JND(I)+JF(J). NE. 0)GOTO 790
15900 C          HERE: AIRWAY "J" GOT ITS TEMPERATURE AND CONC.
16000 C %          CHANGE COMPUTED
16100          N=N+1
16200          SRPR=SRPR+RDPROP(J)*Q(J)
16300          SRCH4=SRCH4+RDCH4(J)
16400          STRD=STRD+TRD(J)
16500          QIN=QIN+Q(J)
16600          GD TO 840
16700 790      IF(JND(I). NE. JF(J))GOTO 830
16800 C          HERE: AIRWAY "J" DID NOT GET ITS TEMPERATURE AND
16900 C %          CONC. CHANGE COMPUTED: STICK IT IN "MEMREC"
17000          M=M+1
17100          MEMREC(M)=J
17200          GREC=GREC+Q(J)
17300 830      CONTINUE
17400 840      CONTINUE
17500 850      CONTINUE
17600          IF(N. LE. 0)GOTO 910
17700          AVRPR=SRPR/QIN
17800          AVRCH4=SRCH4/N
17900          AVTRD=STRD/N
18000 C          COOL IT! "GREC/QIN" GETS LARGER FOR CONVERGENCE
18100 C %          AND SMALLER FOR DIVERGENCE (NO, THIS IS NOT A
18200 C %          TYPD!); JUST IN CASE "GREC/QIN" IS TOO
18300 C %          SMALL, THIS COMPUTES "AVRPR", "AVRCH4", AND
18400 C %          "AVTRD" FOR A RECIRCULATION TRY
18500          IF(GREC*2. 0/QIN. LT. NREC)GOTO 950
18600 C
18700 910      CONTINUE
18800 920      CONTINUE
18900 930      CONTINUE
19000 C          IF(L. GE. NJ), ALL JUNCTIONS GOT TEMPERATURE AND CONC.

```

```

19100 C % CHANGES COMPUTED FOR THEIR EXITING AIRWAYS
19200 IF (L. GE. NJ)GOTO 1380
19300 NREC=NREC+1
19400 GO TO 590
19500 C END REPEAT(N. GE. NJ);
19600 C
19700 C RECIRC-COMPUTE-MRCS-AND-NSTART.
19800 C
19900 950 CONTINUE
20000 C IF THE PROGRAM COMES TO THIS PARAGRAPH, IT IS FIXING TO FIND
20100 C % ANOTHER "NSTART" FOR A NEW JUNCTION AND THEN GO BACK
20200 C % TO "CONDITIONS-SELECTED-ROAD-ENDS" TO COMPUTE CONDITIONS
20300 C % FOR AIRWAYS LEAVING THIS NEW JUNCTION
20400 C HERE: GENERATE "ESTPR(MRC)", "ESTCH4(MRC)", "ESTTR(MRC)",
20500 C % "RDPROP(K)", "RDCH4(K)", AND "TRD(K)"
20600 DO 1060 L=1,M
20700 MRC=MRC+1
20800 K=MEMREC(L)
20900 C MOVE DELINQUENT AIRWAYS (I. E., AIRWAYS WHICH DID NOT
21000 C % GET TEMPERATURE AND CONC. CHANGES COMPUTED) FROM
21100 C % "MEMREC" TO "NOREC"
21200 NOREC(MRC)=K
21300 ESTPR(MRC)=AVRPR
21400 RDPROP(K)=ESTPR(MRC)
21500 ESTCH4(MRC)=AVRCH4
21600 RDCH4(K)=ESTCH4(MRC)
21700 ESTTR(MRC)=AVTRD
21800 TRD(K)=ESTTR(MRC)
21900 JF(K)=-JF(K)
22000 1060 CONTINUE
22100 C HERE: GENERATE "NSTART" AND RELATED VARIABLES PERTINENT TO
22200 C % THE NEW JUNCTION BEFORE GOING BACK TO
22300 C % "CONDITIONS-SELECTED-ROAD-ENDS"
22400 DO 1090 J=1,NJ
22500 C IF "JNO(I).GT.0", THEN THIS JUNCTION DID NOT GET
22600 C % TEMPERATURE AND CONC. CHANGES COMPUTED FOR ITS
22700 C % EXITING AIRWAYS: SHAME, SHAME! "I" IS LEFT-OVER
22800 C % FROM "RECIRCULATION-FIRST-APPROXIMATION", WHERE
22900 C % THIS DELINQUENT JUNCTION WAS FOUND
23000 IF(JNO(I).EQ.JNOL(J))GOTO 1100
23100 1090 CONTINUE
23200 1100 JY=1
23300 IF(J. NE. 1)JY=KNO(J-1)+1
23400 JZ=KNO(J)
23500 SUMAIR=0.0
23600 SUMPR=0.0
23700 SUMCH4=0.0
23800 SUMHT=0.0
23900 DO 1250 K=JY, JZ
24000 C GET "SUMAIR", ETC. FROM AIRWAYS ENTERING "JNOL(J)"
24100 M=KJF(K)
24200 SUMAIR=SUMAIR+Q(M)
24300 SUMPR=SUMPR+RDPROP(M)*Q(M)
24400 SUMCH4=SUMCH4+RDCH4(M)*Q(M)
24500 SUMHT=SUMHT+TRD(M)*Q(M)*(0.2376+0.000024*TRD(M))
24600 C WRITE(LP,1241) K, M, Q(M), SUMAIR, RTCONT
24700 C1241 FORMAT(1X, 'ROADWY1241: K, M, Q(M), SUMAIR, RTCONT=', 2I3, 3F13.3)
24800 1250 CONTINUE
24900 NSTART=J
25000 L=I
25100 C WRITE(LP,1291) SUMAIR, RTCONT
25200 C1291 FORMAT(5X, 'ROADWY AFTER END-DO-1250: SUMAIR, RTCONT=', 2F13.3)
25300 PROP(L)=SUMPR/SUMAIR

```

```

25400      PRCH4(L)=SUMCH4/SUMAIR
25500      RTCONT=4950.**2.+SUMHT/(SUMAIR*0.000024)
25600      T(L)=-4950.+SQRT(RTCONT)
25700      GO TO 120
25800      C
25900      C RECIRCULATION-PREPARATION-FOR-ITERATION.
26000      C
26100      1380 CONTINUE
26200      C          CHECK "DIFPR", "DIFCH4", AND "DIFTRD" FOR CONVERGENCE:
26300      C      %          IF WITHIN LIMITS, THEN CONGRATULATIONS, YOU CAN
26400      C      %          EXIT "ROADWY"!
26500      DO 1390 I=1,NB
26600      1390      JF(I)=IABS(JF(I))
26700      DO 1410 I=1,NJ
26800      1410      JND(I)=IABS(JND(I))
26900      LAGAIN=IFALSE
27000      IF(MRC.EQ.0)GOTO 1620
27100      DO 1560 I=1,MRC
27200      C          ONLY DELINQUENT AIRWAYS FROM "NOREC" ARE CHECKED
27300      C      %          FOR CONVERGENCE
27400      K=NOREC(I)
27500      DIFPR=ESTPR(I)-RDPROP(K)
27600      DIFCH4=ESTCH4(I)-RDCH4(K)
27700      DIFTRD=ESTTR(I)-TRD(K)
27800      IF (ABS(DIFPR).GE.CRITSM/100.) LAGAIN=ITRUE
27900      IF (ABS(DIFCH4).GE.CRITGS/100.) LAGAIN=ITRUE
28000      IF (ABS(DIFTRD).GE.CRITHT) LAGAIN=ITRUE
28100      ESTPR(I)=RDPROP(K)
28200      ESTCH4(I)=RDCH4(K)
28300      ESTTR(I)=TRD(K)
28400      JF(K)=-JF(K)
28500      1560 CONTINUE
28600      ITCT=ITCT+1
28700      IF (LAGAIN.NE.ITRUE)GOTO 1610
28800      IF (ITCT.LE.ITN)GOTO 100
28900      C
29000      MARKC=ITRUE
29100      C          NOTE: "MARKC=ITRUE" RETURN MEANS THAT "ROADWY" DID
29200      C      %          NOT CONVERGE WITHIN "ITN" TRIES ON INTERMEDIATE
29300      C      %          ITERATION COUNTER "ITCT": SUBROUTINE "WRITR"
29400      C      %          CHECKS "MARKC"
29500      C
29600      C ROADWY-BOOGIE.
29700      C
29800      1610 CONTINUE
29900      1620 CONTINUE
30000      IF(NTEMP.NE.ITRUE)WRITE (LP,1641)
30100      1641      FORMAT(////,' NO TEMPERATURE DETERMINATION WAS DEMANDED')
30200      RETURN
30300      C
30400      C          MAIN-LINE CODE FOR SUBROUTINE "ROADWY" ENDS HERE
30500      C
30600      C*****
30700      C
30800      C          PARAGRAPHS PERFORMED FROM MAIN-LINE CODE
30900      C          WITHIN "ROADWY" START HERE
31000      C
31100      C
31200      C CK-CONC-CHANGE-AND-ADDED-HEAT.
31300      C
31400      1660 CONTINUE
31500      C          DETERMINE IF THIS AIRWAY HAS CONCENTRATION CHANGES,
31600      C      %          ADDED CONTAMINATION, OR ADDED HEAT

```

```

31700      ICFTM=IFALSE
31800      C      "I" IS CURRENT AIRWAY LEAVING THIS JUNCTION
31900      I=INU(K)
32000      NM=IFALSE
32100      DO 1730 LTEMP=1, INFLOW
32200      L=LTEMP
32300      C      SUBROUTINE "RDCONC" READS: (NCENT(L), CONT(L), CONC(L),
32400      C      %      HEAT(L), O2MIN(L), SMPD2(L), HTPD2(L), L=1, INFLOW),
32500      C      %      ALL IN ONE WHACK IN ONE STATEMENT: THESE ARE COMPANION
32600      C      %      VARIABLES ALL WITH THE SAME SUBSCRIPT
32700      C      ALL VALUES SUBSCRIPTED "L" FROM HERE THRU "AIRWAY-BOOGIE"
32800      C      %      ARE CHOSEN BY THIS "IF(NCENT(L).EQ.NO(J))"
32900      IF (NCENT(L).EQ.NO(I))GOTO 1790
33000      1730    CONTINUE
33100      CONTAM=0.0
33200      CONTG=0.0
33300      HEATAD=0.0
33400      TFS=0.0
33500      GO TO 2020
33600      C
33700      C CONC-CHANGE-AND-ADDED-HEAT.
33800      C
33900      1790    CONTINUE
34000      C      COMPUTE CONCENTRATION CHANGES, ADDED CONTAMINATION,
34100      C      %      AND ADDED HEAT
34200      NM=ITRUE
34300      IF (CONT(L).EQ.0.0)GOTO 1870
34400      C      EQUATIONS FOR "CONTAM", "CONTG", "HEATAD":
34500      C      %      SEE 4.2.8.2, SECTION 1, PAGE 36
34600      CONTM1=CONT(L)*CONC(L)
34700      CONTAM=CONTM1/100.
34800      C      WRITE(LP,1841) CONTAM, CONTM1
34900      C1841    FORMAT(1X,25HROADWY1841:CONTM1,CONTAM=,2F13.3)
35000      CONTG=CONT(L)
35100      GO TO 1890
35200      1870    CONTAM=0.0
35300      CONTG=0.0
35400      1890    IF (HEAT(L).EQ.0.0)GOTO 1920
35500      HEATAD=HEAT(L)
35600      GO TO 1930
35700      1920    HEATAD=0.0
35800      1930    IF (O2MIN(L).LE.0.0)GOTO 1970
35900      C      EQUATIONS FOR "CONTAM", "CONTG", "HEATAD":
36000      C      %      SEE 4.2.8.2, SECTION 2, PAGE 36
36100      CONTAM=(0.21-PROPS-O2MIN(L)/100.)*Q(I)
36200      CONTG=0.0
36300      HEATAD=CONTAM*437.
36400      1970    IF (SMPD2(L).LE.0.0)GOTO 2010
36500      C      EQUATIONS FOR "CONTAM", "CONTG", "HEATAD":
36600      C      %      SEE 4.2.8.2, SECTION 3, PAGE 36
36700      CONTAM=(0.21-PROPS)*Q(I)*SMPD2(L)
36800      CONTG=0.0
36900      HEATAD=(0.21-PROPS)*Q(I)*HTPD2(L)
37000      2010    CONTINUE
37100      C
37200      C MAKE-CHANGES-IN-EXIT-AIRWAYS.
37300      C
37400      2020    CONTINUE
37500      XDUM=10.0
37600      C      WRITE(LP,2041) XDUM
37700      C2041    FORMAT(1X,17HROADWY,L2041:XDUM=,F13.3)
37800      C      EQUATIONS FOR "RDCH4", "RDPROP":
37900      C      %      SEE 4.2.8.2, SECTION 3, PAGE 37

```

```

38000      DENOM=G(I)+CH4V(I)
38100      C      WRITE(LP,2071) K, I, Q(I), CH4V(I), DENOM
38200      C2071      FDMAT(1X,34HROADWY2071:K, I, Q(I), CH4V(I), DENOM= ,2I3,3F13.3)
38300      RDCH4(I)=(CH4JS*Q(I)+CH4V(I))/DENOM
38400      C      WRITE(LP,2071) K, I, Q(I), CH4V(I), DENOM
38500      RDPROP(I)=PROPJS*(Q(I)-CONTG)/Q(I)+CONTAM/Q(I)
38600      C      WRITE(LP,2071) K, I, Q(I)
38700      IF (NTEMP.EQ. ITRUE)GOTO 2150
38800      TRD(I)=0.0
38900      GO TO 2850
39000      C
39100      C TEMPERATURE-CALC-FOR-AIRWAY-I.
39200      C
39300      C      SEE 4.2.8.3 FOR EQUATIONS FROM HERE THRU "AIRWAY-BOOGIE"
39400      2150 CONTINUE
39500      TJS=T(JX)
39600      IF (NM.NE. ITRUE)GOTO 2250
39700      IF (HEATAD.NE. 0.0)GOTO 2220
39800      TFSI(L)=TJS
39900      GO TO 2240
40000      2220      VART=(4950. -TJS/2. )**2+9900. *TJS+HEATAD/(Q(I)*0.000024*DR)
40100      C      "TFS" EQUATIONS (NOTE: "TFS" IS "T" IN THE BOOK):
40200      C      %      LAST TWO ON PAGE 37 IN 4.2.8.3
40300      TFS=-4950. -TJS/2. +SQRT(VART)+TJS
40400      TJS=TFS
40500      TFSI(L)=TFS
40600      2240 CONTINUE
40700      2250 IF (ICFTM.EQ. ITRUE)GOTO 2280
40800      TM=(TJS+TROCK(I))/2.
40900      GO TO 2370
41000      C
41100      C TEMPERATURE-ITERATE-TDM-GR-T-50.
41200      C
41300      2280 CONTINUE
41400      2290 CONTINUE
41500      C      EQUATIONS FOR "TM": TOP OF PAGE 38 ("TM" IS "T" IN BOOK)
41600      ARGMT=(TJS-TROCK(I))/(TRD(I)-TROCK(I))
41700      IF (ARGMT.GT. 1.0)GOTO 2340
41800      TM=(TJS+TRD(I))/2.
41900      GO TO 2360
42000      C      "X" EQUATION: JUST BELOW MIDDLE OF PAGE 41.
42100      C2340      X=ALOG(ARGMT)/LA(I)
42200      2340      X=ALOG(ARGMT)/FLOAT(LA(I))
42300      C      THIS "TM" EQUATION: JUST BELOW MIDDLE OF PAGE 41
42400      C      TM=TROCK(I)+(TJS-TROCK(I))*(1.0-EXP(-X*LA(I)))/
42500      C      %      (X*LA(I))
42600      XLA=X*FLOAT(LA(I))
42700      TM=TROCK(I)+(TJS-TROCK(I))*(1.0-EXP(-XLA))/
42800      %      XLA
42900      C
43000      C TEMPERATURE-MAIN-TDM-ITERATION.
43100      C
43200      2360 CONTINUE
43300      C      "VISC", "WT" EQUATIONS: CLOSE TO BOTTOM OF PAGE 40
43400      2370 WT=DR*(TR+460.)/(TM+460.)
43500      VISC=0.000145*((460.+TM)/492. )**1.75
43600      C      "CP" IS USED IN THE MIDDLE OF PAGE 37
43700      CP=0.2376+0.000024*TM
43800      C      "HKA" EQUATION: JUST BELOW MIDDLE OF PAGE 40
43900      HKA=0.014*((460.+TM)/492. )**0.81
44000      DENOM1=15.*WT*Q(I)*VISC
44100      C      "RN" EQUATION: TOP OF PAGE 41
44200      RN=G(I)*DR/(15.*WT*Q(I)*VISC)

```

```

44300      DENOM2=RN**0.237
44400      C      WRITE(LP,2451) WT, O(I), VISC, DENOM1, RN, DENOM2
44500      C2451      FORMAT(1X,41HROADWY2451:WT, O(I), VISC, DENOM1, RN, DENOM2=, 6F13.3)
44600      C      "FRO" EQUATION: MIDDLE OF PAGE 40
44700      FRO=0.0032+0.221/RN**0.237
44800      C      "COR" EQUATION: SECOND GROUP ON PAGE 40
44900      POT=(100./RN)**0.125
45000      COR=((FLOAT(KF(I))*0.075)/(809*DR*FRO))**POT
45100      C      "HC" EQUATION: TOP OF PAGE 40
45200      HC=0.005*HKA*O(I)*RN**0.8*COR/A(I)
45300      C      "FO", "BI" EQUATIONS: TOP OF PAGE 39
45400      FO=TIME*HA(I)*O(I)**2/(4.*A(I)**2)
45500      BI=HC*2.*A(I)/(O(I)*HK(I))
45600      C      "X" EQUATION: MIDDLE OF PAGE 39
45700      X=(0.375+BI)*SQRT(FO)
45800      IF (X.GE.2.5)GOTO 2630
45900      N=0
46000      SUMT=0.0
46100      ADDT=X
46200      2570      CONTINUE
46300      C      REPEAT UNTIL (ABS(ADDT).LT. 0.00001);
46400      C      "SUMT" EQUATION: NEXT-TO-LAST ON PAGE 39
46500      C      %      ("SUMT" IS "PHI(X)" IN BOOK) (FOR "X".LE. 2.5)
46600      SUMT=SUMT+ADDT
46700      N=N+1
46800      C      ADDT=-ADDT*X**2*(2*N-1)/(N*(2*N+1))
46900      X1N=FLOAT(N)
47000      X2N=(2.*X1N-1.)/(X1N*(2.*X1N+1.))
47100      ADDT=-ADDT*X**2*X2N
47200      IF (ABS(ADDT).GE.0.00001)GOTO 2570
47300      C      END REPEAT (ABS(ADDT).LT. 0.00001);
47400      FX=1.0-(EXP(X**2))*(1.0-(2.0/SQRT(PI))*SUMT)
47500      GO TO 2730
47600      2630      N=0
47700      SUMT=0.0
47800      ADDT=1.0
47900      C
48000      2660      CONTINUE
48100      C      REPEAT WHILE (ABS(ADDT).GE.0.00001
48200      C      %      .AND. ABS(OLADDT).GT.ABS(ADDT));
48300      SUMT=SUMT+ADDT
48400      C      "SUMT" EQUATIONS ("X".GT. 2.5): BOTTOM OF PAGE 39
48500      N=N+1
48600      OLADDT=ADDT
48700      X1N=FLOAT(N)
48800      ADDT=-ADDT*(2*X1N-1)/(2.0*X**2)
48900      IF (ABS(ADDT).GE.0.00001 .AND.
49000      %      ABS(OLADDT).GT.ABS(ADDT))GOTO 2660
49100      C      END REPEAT (ABS(ADDT).GE.0.00001
49200      C      %      .AND. ABS(OLADDT).GT.ABS(ADDT));
49300      C
49400      FX=1.0-1.0*SUMT/(SQRT(PI)*X)
49500      C
49600      C TEMPERATURE-FINISH-TDM-ITERAT.
49700      C
49800      2730      CONTINUE
49900      C      WHEN THIS ITERATION ON "TDM" IS FINISHED, A FAIRLY CONVERGENT
50000      C      %      "TRD(I)" FOR AIRWAY "I" WILL HAVE BEEN COMPUTED
50100      COAGE=BI-FX*BI**2/(0.375+BI)
50200      C      "XNEW" EQUATION: BOTTOM OF PAGE 41 AND TOP OF PAGE 42
50300      C      %      (RIGHT SIDE OF EQUATION MENTIONED JUST BELOW
50400      C      %      MIDDLE OF PAGE 38)
50500      XNEW(I)=HK(I)*FLOAT(LA(I))*O(I)**2.*COAGE/(120.*DR*Q(I)*CP*A(I))

```

```
50600      IF (ICFTM.EQ. ITRUE)GOTO 2780
50700      TOLD=TROCK(I)
50800      GO TO 2790
50900 2780  TOLD=TRD(I)
51000 C      "TRD" EQUATION: MIDDLE OF PAGE 41
51100 C      %      (ALSO MENTIONED ON BOTTOM OF PAGE 38)
51200 2790 TRD(I)=TROCK(I)+(TJS-TROCK(I))*EXP(-XNEW(I))-(DZRD(I)/(2.*
51300 %      778.26*CP))*(1.+EXP(-XNEW(I)))
51400      TDM=ABS(TOLD-TRD(I))
51500      IF (TDM.LE. 50.0)GOTO 2840
51600      ICFTM=ITRUE
51700      GO TO 2290
51800 C
51900 C
52000 C AIRWAY-BOOGIE.
52100 C
52200 2840 CONTINUE
52300 2850 CONTINUE
52400      JF(I)=-IABS(JF(I))
52500 C      WRITE(5,4321) I,JF(I),TDM,TRD(I)
52600 C4321  FORMAT(2(4X,I4),2(4X,E12.5))
52700      GOTO ICKY
52800      END
```

```

200      SUBROUTINE NATVP1
300      C
400      C      "NATVP1" COMPUTES "FRNVP" FOR USE IN "NATURAL-VENTILATION-
500      C      %      PRESSURE-2" IN PROGRAM DRIVER, AND ADJUSTS "R" FOR ALL
600      C      %      REGULAR AIRWAYS AND "STATIC-Q" AIRWAYS
700      C
800      C
900      C      DATA DIVISION.
1000     C      COMMON SECTION.
1100     C
1200     C      INCLUDE 'CTPAM.COM'
1300     C      INCLUDE 'CTCONN.COM'
1400     C      COMMON/SCLR1/ADDT, BI, COR, DIFCH4, FRO, I, ITN, K, MRC, NM, PI, RN, SUMAIR,
1500     C      1TDM, TOLD, X, ARGMT, CH4JS, CP, DIFPR, FX, ICFTM, J, L, MSTART, NREC, POT,
1600     C      2RTCONT, SUMCH4, TFS, TR, AVRCH4, COAGE, CRITGS, DIFTRD, HC, INFLOW, JX, LP,
1700     C      3N, NSTART, PROPJS, SRCH4, SUMHT, TIME, VART, AVRPR, CONTAM, CRITHT, DR,
1800     C      4HEATAD, ISTART, JY, M, NB, NTEMP, QIN, SRPR, SUMPR, TJS, VISC, AVTRD, CONTQ,
1900     C      5CRITSM, FO, HKA, ITCT, JZ, MARKC, NJ, OLADDT, GREC, STRD, SUMT, TM, WT,
2000     C      6AX, HSU, IO, NFNUM, NT, DNVP, TO, FACT, H, MADJC, MENDW, NADBC, NSFLOW,
2100     C      7OX, T1, ZDOWN, FNTM, MNO, NSNVP, NVPN, ZUP, INDEX, LX, MARKD, NCONC,
2200     C      8NNVP, NX, ZO, DNVP, KX, MARKN, NETW, NOX, NSW, TSU, Z1, MADJ, MBEGW,
2300     C      9ITRUE, IFALSE
2400     C      COMMON/NETWK/KNUM, JBM, NBL, JEM, KB, NBU, NK, NRETU, NO, Q1, IND,
2500     C      1KCO, MESC, N1, KE, NMIN, NUC, MMIN
2600     C      COMMON/ITTCOM/DQSUM, GBL, ADEN, IT, PART, QBR, RQSUM, ANUM, DP,
2700     C      1NBDR, RQ2, TABF, DPSUM, FANP, LL, DQ, FANG, NPTS, NABF
2800     C      COMMON/RESCOM/NWRN
2900     C      COMMON/WRTCOM/MINREV, JFF, NRCT, MEMI, WRNHT, WRNPR, WRNSM,
3000     C      1WRNSUM, WRNGS
3100     C      COMMON/RDCCOM/AAVR, CH4CX, CH4VX, ES, HAX, HKX, KFAVR, CH4F,
3200     C      1JNOX, NAV, NCH4C, JSTART, CH4PAX, DZRD, NDIM, QAVR, CH4S,
3300     C      2HAAVR, HKA, LA, LAVR, MAXJ, TSTART, TRF, TROCKX, TAVR, TRS, EF
3400     C      COMMON/FLOCOM/MM
3500     C      COMMON/NATCOM/E, B, G, GX, GXX, TMRD, TMSQR, TRA
3600     C
3700     C      PROCEDURE DIVISION WITH ENTRY POINT NATVP1.
3800     C
3900     C      NATVP1.
4000     C
4100     C      CALCULATION OF NATURAL VENTILATION PRESSURE
4200     C      DO 320 I=1, NB
4300     C      DO 140 J=1, NJ
4400     C      IF (JS(I).EQ.JNO(J)) GO TO 150
4500     C      140      CONTINUE
4600     C      150      T1=T(J)
4700     C      DO 180 K=1, INFLOW
4800     C      IF (NCENT(K).EQ.NO(I)) GO TO 200
4900     C      180      CONTINUE
5000     C      GO TO 210
5100     C      200      T1=TFSI(K)
5200     C      210      CP=0.2376+0.000012*(TRD(I)+T1)
5300     C      "E" EQUATION: TOP OF PAGE 46.
5400     C      E=DZRD(I)/(2.*77B.26*CP)
5500     C      B=T1-TROCK(I)
5600     C      G=XNEW(I)
5700     C      GX=EXP(-G)
5800     C      GXX=EXP(-2.*G)
5900     C      TRA=TROCK(I)+440.*E
6000     C      "TMRD" IS "T(M)" IN EQUATION IN MIDDLE OF PAGE 46.
6100     C      TMRD=TROCK(I)-(B-E)*(GX-1.)/G
6200     C      FRNVP(I)=TMRD*DZRD(I)
6300     C      TMSQR=(TRA-E)**2.+E**2./3.-(B-E)*(GXX-1.)/(2.*G)-2.*TRA*
6400     C      %      (B-E)*(GX-1.)/G+4.*E*(B-E)*(GX*(1.+G)-1.)/G**2.

```

```
6500      IF (NWTYP(I).LE.0) R(I)=RSTD(I)*TMSQR/(460.+TR)**2.  
6600 320      CONTINUE  
6700      RETURN  
6800      END
```

```

200      SUBROUTINE SGRS(LY, NP)
300      C      111111111122222222223333333333444444444455555555556666666666777
400      C23456789012345678901234567890123456789012345678901234567890123456789012
500      C
600      C
850      C      LEAST SQUARES FIT OF FAN DATA
900      C
1000     C
1100     C      DATA DIVISION.
1200     C      COMMON SECTION.
1300     C      IMPLICIT DOUBLE PRECISION(A-H, O-Z)
1400     C      INCLUDE 'CTPAM.COM'
1500     C      INCLUDE 'CTCONN.COM'
1600     C      COMMON/SCLR1/ADDT, BI, COR, DIFCH4, FRO, I, ITN, K, MRC, NM, PI, RN, SUMAIR,
1700     C      1TDM, TOLD, X, ARGMT, CH4JS, CP, DIFPR, FX, ICFTM, J, L, MSTART, NREC, POT,
1800     C      2RTCONT, SUMCH4, TFS, TR, AVRCH4, COAGE, CRITGS, DIFTRD, HC, INFLOW, JX, LP,
1900     C      3N, NSTART, PROPJS, SRCH4, SUMHT, TIME, VART, AVRPR, CONTAM, CRITHT, DR,
2000     C      4HEATAD, ISTART, JY, M, NB, NTEMP, QIN, SRPR, SUMPR, TJS, VISC, AVTRD, CONTG,
2100     C      5CRITSM, FO, HKA, ITCT, JZ, MARKC, NJ, OLADDT, QREC, STRD, SUMT, TM, WT,
2200     C      6AX, HSU, IQ, NFNUM, NT, DNVP, TO, FACT, H, MADJC, MENDW, NADBC, NSFLOW,
2300     C      7OX, T1, ZDOWN, FNTM, MNO, NSNVP, NVPN, ZUP, INDEX, LX, MARKD, NCONC,
2400     C      8NNVP, NX, ZO, DNVP, KX, MARKN, NETW, NOX, NSW, TSU, Z1, MADJ, MBEGW,
2500     C      9ITRUE, IFALSE
2600     C      COMMON/NETWK/KNUM, JBM, NBL, JEM, KB, NBU, NK, NRETU, NO, Q1, IND,
2700     C      1KCO, MESC, N1, KE, NMIN, NUC, MMIN
2800     C      COMMON/ITTCOM/DQSUM, QBL, ADEN, IT, PART, QBR, RQSUM, ANUM, DP,
2900     C      1NBDR, RQ2, TABF, DPSUM, FANP, LL, DQ, FANG, NPTS, NABF
3000     C      COMMON/RESCOM/NWRN
3100     C      COMMON/WRTCOM/MINREV, JFF, NRCT, MEMI, WRNHT, WRNPR, WRNSM,
3200     C      1WRNSUM, WRNGS
3300     C      COMMON/RDCCOM/AAVR, CH4CX, CH4VX, ES, HAX, HKX, KFAVR, CH4F,
3400     C      1JNOX, NAV, NCH4C, JSTART, CH4PAX, DZRD, NDIM, DAVR, CH4S,
3500     C      2HAAVR, HKA, LAADR, MAXJ, TSTART, TRF, TROCKX, TAVR, TRS, EF
3600     C
3700     C      COMMON/LEAST/ATA(3, 3), ATY(3), CL(40, 6), LK(5), MQ(5), IFAN
3800     C      DO 401 I=1, 6
3900     C      401 CL(LY, I)=0.
4000     C      DO 402 I=1, 3
4100     C      DO 402 J=1, 3
4200     C      402 ATA(I, J)=0.
4300     C      ATA(1, 1)=FLOAT(NP)
4400     C      DO 403 I=1, NP
4500     C      QF(LY, I)=QF(LY, I)/100000.
4600     C      ATA(1, 2)=ATA(1, 2)+QF(LY, I)
4700     C      ATA(1, 3)=ATA(1, 3)+QF(LY, I)*QF(LY, I)
4800     C      ATA(2, 2)=ATA(1, 3)
4900     C      ATA(2, 3)=ATA(2, 3)+QF(LY, I)*QF(LY, I)*QF(LY, I)
5000     C      ATA(3, 3)=ATA(3, 3)+QF(LY, I)*QF(LY, I)*QF(LY, I)*QF(LY, I)
5100     C      ATA(2, 1)=ATA(1, 2)
5200     C      ATA(3, 1)=ATA(1, 3)
5300     C      ATA(3, 2)=ATA(2, 3)
5400     C      QF(LY, I)=100000. *QF(LY, I)
5500     C      403 CONTINUE
5600     C      RETURN
5700     C      ENTRY SQRSS(LY, NP)
5800     C      DO 404 I=1, 3
5900     C      404 ATY(I)=0.
6000     C      DO 405 I=1, NP
6100     C      QF(LY, I)=QF(LY, I)/100000.
6200     C      ATY(1)=ATY(1)+PF(LY, I)
6300     C      ATY(2)=ATY(2)+QF(LY, I)*PF(LY, I)
6400     C      ATY(3)=ATY(3)+QF(LY, I)*QF(LY, I)*PF(LY, I)
6500     C      QF(LY, I)=100000. *QF(LY, I)

```

```
6600 405 CONTINUE
6700     DO 406 I=1,3
6800     DO 406 J=1,3
6900 406 CL(LY, I)=CL(LY, I)+ATA(I, J)*ATY(J)
7000     RETURN
7100     END
```

```

200      SUBROUTINE MINV(AAX,NV)
300      C      11111111112222222222333333333333444444444455555555556666666666777
400      C23456789012345678901234567890123456789012345678901234567890123456789012
500      C
800      C
850      C      LEAST SQUARES FIT OF FAN
900      C
1000     C
1100     C      DATA DIVISION.
1200     C      COMMON SECTION.
1300     C      IMPLICIT DOUBLE PRECISION(A-H, O-Z)
1400     C      INCLUDE 'CTPAM.COM'
1500     C      DIMENSION AAX(20)
1600     C      INCLUDE 'CTCONN.COM'
1700     C      COMMON/SCLR1/ADDT, BI, COR, DIFCH4, FRO, I, ITN, K, MRC, NM, PI, RN, SUMAIR,
1800     C      1TDM, TOLD, X, ARGMT, CH4JS, CP, DIFPR, FX, ICFTM, J, L, MSTART, NREC, PDT,
1900     C      2RTCONT, SUMCH4, TFS, TR, AVRCH4, COAGE, CRITGS, DIFTRD, HC, INFLOW, JX, LP,
2000     C      3N, NSTART, PROPJS, SRCH4, SUMHT, TIME, VART, AVRPR, CONTAM, CRITHT, DR,
2100     C      4HEATAD, ISTART, JY, M, NB, NTEMP, QIN, SRPR, SUMPR, TJS, VISC, AVTRD, CONTG,
2200     C      5CRITSM, FO, HKA, ITCT, JZ, MARKC, NJ, OLADDT, GREC, STRD, SUMT, TM, WT,
2300     C      6AX, HSU, IO, NFNUM, NT, DNVP, TO, FACT, H, MADJC, MENDW, NADBC, NSFLOW,
2400     C      7OX, T1, ZDOWN, FNTM, MND, NSNVP, NVPN, ZUP, INDEX, LX, MARKD, NCONC,
2500     C      BNNVP, NX, ZO, DNVP, KX, MARKN, NETW, NDX, NSW, TSU, Z1, MADJ, MBEGW,
2600     C      9ITRUE, IFALSE
2700     C      COMMON/NETWK/KNUM, JBM, NBL, JEM, KB, NBU, NK, NRETU, NO, Q1, IND,
2800     C      1KCO, MESC, N1, KE, NMIN, NUC, MMIN
2900     C      COMMON/ITTCOM/DGSUM, QBL, ADEN, IT, PART, QBR, RQSUM, ANUM, DP,
3000     C      1NBDR, RQ2, TABF, DPSUM, FANP, LL, DG, FANG, NPTS, NABF
3100     C      COMMON/RESCOM/NWRN
3200     C      COMMON/WRTCOM/MINREV, JFF, NRCT, MEMI, WRNHT, WRNPR, WRNSM,
3300     C      1WRNSUM, WRNGS
3400     C      COMMON/RDCCOM/A AVR, CH4CX, CH4VX, ES, HAX, HKX, KFAVR, CH4F,
3500     C      1JNOX, NAV, NCH4C, JSTART, CH4PAX, DZRDY, NDIM, DAVR, CH4S,
3600     C      2HAAVR, HKA VR, LAAVR, MAXJ, TSTART, TRF, TROCKX, TAVR, TRS, EF
3700     C
3800     C      COMMON/LEAST/ATA(3,3), ATY(3), CL(40,6), LK(5), MQ(5), IFAN
3900     C      DD=1.
4000     C      NKK=-NV
4100     C      DO 80 K=1, NV
4200     C      NKK=NKK+NV
4300     C      LK(K)=K
4400     C      MQ(K)=K
4500     C      KK=NKK+K
4600     C      BIGA=AAX(KK)
4700     C      DQ 20 J=K, NV
4800     C      IZ=NV*(J-1)
4900     C      DO 20 I=K, NV
5000     C      IJ=IZ+I
5100     C      10 IF (ABS(BIGA)-ABS(AAX(IJ))) 15, 20, 20
5200     C      15 BIGA=AAX(IJ)
5300     C      LK(K)=I
5400     C      MQ(K)=J
5500     C      20 CONTINUE
5600     C      J=LK(K)
5700     C      IF (J-K) 35, 35, 25
5800     C      25 KI=K-NV
5900     C      DO 30 I=1, NV
6000     C      KI=KI+NV
6100     C      HOLD=-AAX(KI)
6200     C      JI=KI-K+J
6300     C      AAX(KI)=AAX(JI)
6400     C      30 AAX(JI)=HOLD
6500     C      35 I=MQ(K)

```

```

6600      IF(I-K) 45, 45, 38
6700      38  JP=NV*(I-1)
6800      DO 40 J=1, NV
6900      JK=NKK+J
7000      JI=JP+J
7100      HOLD=-AAX(JK)
7200      AAX(JK)=AAX(JI)
7300      40  AAX(JI)=HOLD
7400      45  IF(BIGA) 48, 46, 48
7500      46  DD=0.
7600      RETURN
7700      48  DO 55 I=1, NV
7800      IF(I-K) 50, 55, 50
7900      50  IK=NKK+I
8000      AAX(IK)=AAX(IK)/(-BIGA)
8100      55  CONTINUE
8200      DO 65 I=1, NV
8300      IK=NKK+I
8400      HOLD=AAX(IK)
8500      IJ=I-NV
8600      DO 65 J=1, NV
8700      IJ=IJ+NV
8800      IF(I-K) 60, 65, 60
8900      60  IF(J-K) 62, 65, 62
9000      62  KJ=IJ-I+K
9100      AAX(IJ)=HOLD*AAX(KJ)+AAX(IJ)
9200      65  CONTINUE
9300      KJ=K-NV
9400      DO 75 J=1, NV
9500      KJ=KJ+NV
9600      IF(J-K) 70, 75, 70
9700      70  AAX(KJ)=AAX(KJ)/BIGA
9800      75  CONTINUE
9900      DD=DD*BIGA
10000     AAX(KK)=1./BIGA
10100     80  CONTINUE
10200     K=NV
10300     100 K=K-1
10400     IF(K) 150, 150, 105
10500     105 I=LK(K)
10600     IF(I-K) 120, 120, 108
10700     108 JG=NV*(K-1)
10800     JR=NV*(I-1)
10900     DO 110 J=1, NV
11000     JK=JG+J
11100     HOLD=AAX(JK)
11200     JI=JR+J
11300     AAX(JK)=-AAX(JI)
11400     110 AAX(JI)=HOLD
11500     120 J=MG(K)
11600     IF(J-K) 100, 100, 125
11700     125 KI=K-NV
11800     DO 130 I=1, NV
11900     KI=KI+NV
12000     HOLD=AAX(KI)
12100     JI=KI-K+J
12200     AAX(KI)=-AAX(JI)
12300     130 AAX(JI)=HOLD
12400     GO TO 100
12500     150 RETURN
12600     END

```

```

200      SUBROUTINE WRITR
300      C      111111111122222222223333333333444444444455555555556666666666777
400      C23456789012345678901234567890123456789012345678901234567890123456789012
500      C
600      C      "WRITR" WRITES OUTPUT OF RESULTS
700      C
800      C      DATA DIVISION.
900      C      COMMON SECTION.
1000     C
1100     C      INCLUDE 'CTPAM.COM'
1200     C      INCLUDE 'CTCONN.COM'
1300     C      COMMON/SCLR1/ADDT, BI, COR, DIFCH4, FRO, I, ITN, K, MRC, NM, PI, RN, SUMAIR,
1400     C      1TDM, TOLD, X, ARGMT, CH4JS, CP, DIFPR, FX, ICFTM, J, L, MSTART, NREC, POT,
1500     C      2RTCONT, SUMCH4, TFS, TR, AVRCH4, COAGE, CRITGS, DIFTRD, HC, INFLOW, JX, LP,
1600     C      3N, NSTART, PROPJS, SRCH4, SUMHT, TIME, VART, AVRPR, CONTAM, CRITHT, DR,
1700     C      4HEATAD, ISTART, JY, M, NB, NTEMP, QIN, SRPR, SUMPR, TJS, VISC, AVTRD, CONTG,
1800     C      5CRITSM, FO, HKA, ITCT, JZ, MARKC, NJ, DLADDT, QREC, STRD, SUMT, TM, WT,
1900     C      6AX, HSU, IO, NFNUM, NT, ONVP, TO, FACT, H, MADJC, MENDW, NADBC, NSFLOW,
2000     C      7DX, T1, ZDOWN, FNTM, MNO, NSNVP, NVPN, ZUP, INDEX, LX, MARKD, NCONC,
2100     C      8NNVP, NX, ZO, DNVP, KX, MARKN, NETW, NDX, NSW, TSU, Z1, MADJ, MBEGW,
2200     C      9ITRUE, IFALSE
2300     C      COMMON/NETWK/KNUM, JBM, NBL, JEM, KB, NBU, NK, NRETU, NO, Q1, IND,
2400     C      1KCD, MESC, N1, KE, NMIN, NUC, MMIN
2500     C      COMMON/ITTCOM/DQSUM, QBL, ADEN, IT, PART, GBR, RQSUM, ANUM, DP,
2600     C      1NBDR, RQ2, TABF, DPSUM, FANP, LL, DG, FANQ, NPTS, NABF
2700     C      COMMON/RESCOM/NWRN
2800     C      COMMON/WRTCOM/MINREV, JFF, NRCT, MEMI, WRNHT, WRNPR, WRNSM,
2900     C      1WRNSUM, WRNGS
3000     C
3100     C      WORKING-STORAGE SECTION.
3200     C      INTEGER LRCIRC
3300     C
3400     C      PROCEDURE DIVISION WITH ENTRY POINTS WRITR WRITS.
3500     C
3600     C
3700     C WRITR.
3800     C
3900     C      OUTPUT OF RESULTS
4000     C      DO 120 L=1, NB
4100     C      RQ(L)=R(L)
4200     C      IF(NWTYP(L).LE.0) RQ(L)=R(L)*(Q(L)/100000. )**2.
4300     C      120 CONTINUE
4400     C
4500     C WRITS.
4600     C
4700     C      ENTRY WRITS
4800     C      IF(MARKN.EQ.ITRUE) WRITE(LP, 151)
4900     C      151 FORMAT (/////, ' THE NETWORK CALCULATION WAS NOT COMPLETED. ',
5000     C      %      ' MORE ITERATIONS ARE REQUIRED ')
5100     C      IF(MARKC.EQ.ITRUE) WRITE (LP, 171)
5200     C      171 FORMAT (/////, ' THE CALCULATION OF CONCENTRATIONS AND TEMPE',
5300     C      %      ' RATURES WAS NOT COMPLETED. MORE ITERATIONS ARE REQUIRED ')
5400     C      WRITE (LP, 191)
5500     C      191 FORMAT (/////, T18, ' TEMPERATURES AND CONCENTRATIONS AT AIRWAY ',
5600     C      1      ' ENDS, PRESSURES IN AIRWAYS ', //, ' AIRWAY ', T10, ' FROM ', T18,
5700     C      2      ' TO ', T31, ' AIRFLOW ', T45, ' TEMPERATURE ', T63, ' SMOKE ',
5800     C      3      T77, ' METHANE ', T93, ' PRESSURE ', //)
5900     C      WRITE(LP, 211) (NO(I), JS(I), JF(I), Q(I), TRD(I), RDPROP(I), RDCH4(I),
6000     C      %      RQ(I), I=1, NB)
6100     C      211 FORMAT ( ' ', I5, T17, T30, OPF8. 0, T46, OPF7. 2, T60, 2PF8. 4, T77,
6200     C      %      2PF6. 2, T93, OPF6. 3)
6300     C      WRITE (LP, 231)
6400     C      231 FORMAT (/////, T18, ' TEMPERATURES AND CONCENTRATIONS OF SMOKE ',

```

```

6500      1      'AND METHANE IN JUNCTIONS', //, ' JUNCTION', T13, 'TEMPERA',
6600      2      'TURE', T28, 'SMOKE', T37, 'METHANE', T58, 'JUNCTION', T69,
6700      3      'TEMPERATURE', T82, 'SMOKE', T92, 'METHANE' //)
6800      WRITE (LP, 251) (JNO(I), T(I), PROP(I), PRCH4(I), I=1, NJ)
6900 251      FORMAT (I5, T15, OPF7. 2, T25, 2PF8. 4, T36, 2PF8. 4, T57, I5, T71, OPF7. 2,
7000      %      T79, 2PF8. 4, T91, 2PF8. 4)
7100      WRITE (LP, 271) MADJC
7200 271      FORMAT (////, T22, 'NUMBER OF ITERATIONS', I10)
7300      LRCIRC=IFALSE
7400      DO 360 I=1, NB
7500          IF (JF(I). GE. 0) GOTO 350
7600          JFF=IABS(JF(I))
7700          WRITE (LP, 331) NO(I), JFF
7800 331      FORMAT (' ', T18, 'WITH AIRWAY NO', I7, ' INTO JUNCTION NO',
7900      %      I5)
8000          LRCIRC=ITRUE
8100 350      CONTINUE
8200 360      CONTINUE
8300          IF (LRCIRC. EQ. ITRUE) WRITE (LP, 381)
8400 381      FORMAT (//, T18, 'A RECIRCULATION PATH IS BEING CLOSED')
8500      WRNSUM=WRNPR+WRNGS+WRNSM+WRNHT
8600      IF (WRNSUM. GT. 0) GOTO 440
8700      WRITE (LP, 421)
8800 421      FORMAT (//////, ' NO THRESHOLD LIMITS FOR CRITICAL STATES',
8900      %      ' WERE SPECIFIED')
9000      GO TO 850
9100      C
9200      C WRITE-CRITICAL-AIRWAYS.
9300      C
9400 440      J=IFFALSE
9500          DO 630 I=1, NB
9600              K=IFFALSE
9700              L=IFFALSE
9800              M=IFFALSE
9900              N=IFFALSE
10000         IF (100. *RDCH4(I). GE. WRNGS) K=ITRUE
10100         IF (100. *RDPROP(I). GE. WRNSM) L=ITRUE
10200         IF (TRD(I). GE. WRNHT) M=ITRUE
10300         IF (RQ(I). LT. WRNPR) N=ITRUE
10400         IF ((K+L+M+N) .LT. ITRUE) GOTO 620
10500         IF (J. EQ. ITRUE) GOTO 590
10600         WRITE (LP, 571) WRNGS, WRNSM, WRNHT, WRNPR
10700 571      FORMAT (//////, T23, 'IN THE FOLLOWING AIRWAYS EXIST ',
10800      1      'CRITICAL CONDITIONS', //, T27, '(THE STATED NUMBERS ',
10900      2      'REFER TO AIRWAY ENDS)', //, ' AIRWAY FROM TO ',
11000      3      'METHANE CONCENTRATION SMOKE CONCENTRATION TEMPE',
11100      4      'RATURE LOW VENTILAT. PRESSURE', //, T27, 'HIGHER THAN',
11200      5      ', T48, 'HIGHER THAN', T66, 'HIGHER THAN', T85,
11300      6      'LOWER THAN', //, T26, F4. 1, ' PERCENT', T46, F6. 3, ' PERC',
11400      7      'ENT', T65, F5. 0, ' DEGREES', T82, F5. 3, ' INCHES WG', //)
11500         J=ITRUE
11600 590      JFF=IABS(JF(I))
11700         WRITE (LP, 611) NO(I), JS(I), JFF, RDCH4(I), RDPROP(I), TRD(I), RQ(I)
11800 611      FORMAT (I5, I7, I7, T29, 2PF6. 2, T50, 2PF8. 4, T67, OPF7. 1, T87,
11900      %      OPF6. 3)
12000 620      CONTINUE
12100 630      CONTINUE
12200         IF (J. EQ. ITRUE) GOTO 680
12300         WRITE (LP, 661)
12400 661      FORMAT (//////, ' NO CRITICAL CONDITIONS AT AIRWAY ENDS OR',
12500      %      ' IN JUNCTIONS WERE DETECTED')
12600         GO TO 860
12700      C

```

```

12800 C WRITE-CRITICAL-JUNCTIONS.
12900 C
13000 680 J=IFALSE
13100      DO 840 I=1,NJ
13200          K=IFALSE
13300          L=IFALSE
13400          M=IFALSE
13500          IF (100.*PRCH4(I).GE.WRNGS) K=ITRUE
13600          IF (100.*PROP(I).GE.WRNSM) L=ITRUE
13700          IF (T(I).GE.WRNHT) M=ITRUE
13800          IF (K+L+M.LT. ITRUE)GOTO 830
13900          IF (J.EQ. ITRUE)GOTO 810
14000          WRITE (LP,791) WRNGS,WRNSM,WRNHT
14100 791      FORMAT (////,T24,' IN THE FOLLOWING JUNCTIONS EXIST ',
14200          1      'CRITICAL CONDITIONS',/, ' JUNCTION      METHANE ',
14300          2      'CONCENTRATION      SMOKE CONCENTRATIONS',16X,
14400          3      'TEMPERATURE',/,T15,'HIGHER THAN',F4.1,' PERCENT',
14500          4      '      HIGHER THAN',F6.3,' PERCENT      MORE ',
14600          5      'THAN',F6.1,' DEGREES',//)
14700          J=ITRUE
14800 810      WRITE (LP,821) JNO(I),PRCH4(I),PROP(I),T(I)
14900 821      FORMAT (I5,T23,2PF5.1,T52,2PF8.4,T86,OPF7.1)
15000 830      CONTINUE
15100 840      CONTINUE
15200 C
15300 C WRITE-AIRFLOW-REVERSALS.
15400 C
15500 850 CONTINUE
15600 860 CONTINUE
15700 C      "NRCT" IS NUMBER OF REVERSED AIRWAYS(COMPUTED IN "FLOWSK")
15800      IF(NRCT-1) 1090,880,930
15900 880 CONTINUE
16000 C      HERE IF ONLY ONE AIRWAY HAS AIRFLOW REVERSAL.
16100      WRITE(LP,1131)
16200      K=NREV(1)
16300      JFF=IABS(JF(K))
16400      WRITE(LP,1141) NO(K),JS(K),JFF
16500      GO TO 1100
16600 C
16700 930 CONTINUE
16800 C      HERE FOR MORE THAN ONE AIRWAY WITH AIRFLOW REVERSAL
16900      WRITE (LP,1131)
17000      L=0
17100 C
17200 950 CONTINUE
17300 C      REPEAT UNTIL (L.GT.NRCT);
17400 C      PICK LOWEST REMAINING AIRWAY NUMBER FOR NEXT WRITE
17500      MINREV=NREV(1)
17600      MEMI=1
17700      DO 1020 I=2,NRCT
17800          IF (MINREV.LE.NREV(I))GOTO 1010
17900          MINREV=NREV(I)
18000          MEMI=I
18100 1010 CONTINUE
18200 1020 CONTINUE
18300      L=L+1
18400 C      "L.GT.NRCT" TESTS FOR ALL AIRFLOW-REVERSALS WRITTEN
18500      IF (L.GT.NRCT)GOTO 1110
18600      JFF=IABS(JF(MINREV))
18700      WRITE (LP,1141) NO(MINREV),JS(MINREV),JFF
18800 C      STICK "NB+1" INTO CURRENT "NREV" TO MAKE IT TOO
18900 C      %      HIGH TO BE SELECTED FOR ANOTHER WRITE
19000      NREV(MEMI)=NB+1

```

```
19100          GO TO 950
19200 C          END REPEAT(L. GT. NRCT);
19300 C
19400 C WRITER-BOOGIE.
19500 C
19600 1090 CONTINUE
19700 1100 CONTINUE
19800 1110 CONTINUE
19900          RETURN
20000 C
20100 C          MAIN-LINE CODE FOR "WRITR" ENDS HERE
20200 C
20300 C*****
20400 C
20500 C          GLOBAL FORMATS
20600 C
20700 C          NOTE: THESE FORMAT STATEMENTS ARE HERE BECAUSE THEY ARE EACH
20800 C          REFERENCED BY MORE THAN ONE "WRITE" STATEMENT.
20900 C
21000 1131 FORMAT (//////,T18,'REVERSAL OF AIRFLOW HAS OCCURRED IN THE FOLLOWI
21100 1NG PLACES',//)
21200 1141 FORMAT (T18,'AIRWAY',I6,' IS NOW CARRYING AIR FROM',I6,' TO',I6)
21300          END
```

```

100      SUBROUTINE RTIME1
150      C      REAL TIME FUME SPREAD
200          INCLUDE 'CTPAM.COM'
300          DIMENSION NW(IAR), NWAR(IAR), NWAL(IAR), VEL(IAR), ISTT(20)
400          1, TOTEX(IJP), TOWEX(IJP), NGOUT(I
500          2AR), LOUT(IAR), NGIN(IAR), MIN(IAR)
600          INCLUDE 'CTCONN.COM'
700          COMMON/SCLR1/ADDT, BI, CDR, DIFCH4, FRO, I, ITN, K, MRC, NM, PI, RN, SUMAIR,
800          1TDM, TOLD, X, ARGMT, CH4JS, CP, DIFPR, FX, ICFTM, J, L, MSTART, NREC, POT,
900          2RTCNT, SUMCH4, TFS, TR, AVRCH4, COAGE, CRITGS, DIFTRD, HC, INFLOW, JX, LP,
1000         3N, NSTART, PROPJS, SRCH4, SUMHT, TIME, VART, AVRPR, CONTAM, CRITHT, DR,
1100         4HEATAD, ISTART, JY, M, NB, NTEMP, QIN, SRPR, SUMPR, TJS, VISC, AVTRD, CONTG,
1200         5CRITSM, FO, HKA, ITCT, JZ, MARKC, NJ, OLADDT, GREC, STRD, SUMT, TM, WT,
1300         6AX, HSU, IO, NFNUM, NT, ONVP, TO, FACT, H, MADJC, MENDW, NADBC, NSFLOW,
1400         7OX, T1, ZDOWN, FNTM, MNO, NSNVP, NVPN, ZUP, INDEX, LX, MARKD, NCONC,
1500         8NNVP, NX, ZO, DNVP, KX, MARKN, NETW, NOX, NSW, TSU, Z1, MADJ, MBEGW,
1600         9ITRUE, IFALSE
1700         COMMON/RDCCOM/AAVR, CH4CX, CH4VX, ES, HAX, HKX, KFAVR, CH4F,
1800         1JNOX, NAV, NCH4C, JSTART, CH4PAX, DZRDX, NDIM, DAVR, CH4S,
1900         2HAAVR, HKAVR, LAAVR, MAXJ, TSTART, TRF, TROCKX, TAVR, TRS, EF
2000         COMMON/RTNCOM/NACC, IDUR, INC, EPX, REP, SNRW, JSURF
2100         1
2200         2
2300         , ISCOB(IAR), IENDT(20), RTAC(IAR, 240, 4), RTJC(IAR, 2)
2400         COMMON/RTMCOM/MRKL
2500         EQUIVALENCE (INU, NGOUT), (KJS, LOUT), (KJF, NGIN), (KNO, MIN)
2600         EQUIVALENCE (PROP, TOWEX), (T, TOTEX), (NWTYP, NW), (NREV, NWAR), (KF, NWAL
2700         1), (TROCK, VEL), (NOF, ISTT)
2800      C
2900      C      REAL TIME CALCULATION
3000      C
3100      C
3200      C
3300      C ***** SUBROUTINE FOR READING IN CONTAMINATION CARDS AND DETERM-
3400      C      INING INTERNAL TIME INCREMENT FOR REAL TIME SIMULATION
3500          NWM=240
3600      C *** INITIALIZATION OF JUNCTIONS
3700          DO 2145 I=1, NJ
3800      C *** TOTAL EXPOSURE
3900          TOTEX(I)=0.0
4000      C *** CURRENT FUME CONCENTRATION IN AIRWAY I
4100          RTJC(I, 1)=0.0
4200      C *** TIME OF FIRST CONTAMINATION IN AIRWAY I
4300          RTJC(I, 2)=0.0
4400      2145 CONTINUE
4500          L=0
4600      C *** IF AIRWAY LENGTH AND AREA NOT SPECIFIED, SET EQUAL TO AVG VALUE
4700          DO 2175 I=1, NB
4800          IF (A(I)) 2150, 2150, 2160
4900      2150 IF (AAVR) 2180, 2180, 2155
5000      2155 A(I)=AAVR
5100          L=L+1
5200      2160 IF (LA(I)) 2165, 2165, 2175
5300      2165 IF (LAAVR) 2180, 2180, 2170
5400      2170 LA(I)=LAAVR
5500          L=L+1
5600      2175 CONTINUE
5700          GO TO 2185
5800      2180 WRITE (LP, 3105)
5900          GO TO 2800
6000      C *** READ INFORMATION FOR ADDITIONAL CONTAMINATION CARDS
6100      2185 ICDR=0
6200          READ (IO, 3115) NACC, IDUR, INC, EPX, REP, WRNSM, JSURF, CRITSM

```

```

6300      CRITSM=CRITSM/100.
6400      WRNSM=WRNSM/100.
6500      IF (NACC.GT.0) GO TO 2200
6600      IF(INFLOW) 2135,2135,2190
6700 2135  WRITE (LP,3100)
6800      GO TO 2800
6900 2190  DO 2195 I=1,INFLOW
7000      ISTT(I)=0
7100      IENDT(I)=IDUR
7200 2195  CONTINUE
7300      GO TO 2285
7400  C *** READ ADDITIONAL CONTAMINATION CARDS
7500 2200  DO 2265 I=1,NACC
7600      J=I+INFLOW-ICOR
7700      READ(IO,3125) NCENT(J),CONT(J),CONC(J),HEAT(J),O2MIN(J),SMPO2(J),H
7800      1TPO2(J),ISTT(J),IENDT(J)
7900      IF((IENDT(J).LE.0).OR.(IENDT(J).GT.IDUR).OR.(IENDT(J).LE.ISTT(J)))
8000      1IENDT(J)=IDUR
8100      IF((ISTT(J).LT.0).OR.(ISTT(J).GT.IDUR).OR.(ISTT(J).GE.IENDT(J)))IS
8200      1TT(J)=0
8300      SUMC1=0.
8400      SUMC2=0.
8500      IJ=J-1
8600      IF (IJ.GT.0) GO TO 2205
8700      NCENT(J)=-NCENT(J)
8800      GO TO 2265
8900  C *** CHECK IJ=J-1=I+INFLOW-ICOR-1 CARDS FOR DUPLICATION (ICOR=# OF CHECKS)
9000 2205  DO 2260 K=1,IJ
9100  C *** IF DUPLICATION OF AIRWAY NOS, THEN COMPARE CARDS
9200      IF (ABS(NCENT(K))-NCENT(J)) 2260,2210,2260
9300 2210  IF (NCENT(K)) 2235,2260,2215
9400  C *** IF AIRWAY NO < 0 GO TO 2235
9500 2215  SUMC1=CONT(J)+CONC(J)+O2MIN(J)+SMPO2(J)
9600      SUMC2=CONT(K)+CONC(K)+O2MIN(K)+SMPO2(K)
9700      IF (SUMC1-SUMC2) 2225,2220,2225
9800  C *** IF CONTAMINANT FROM TWO SOURCES IS DIFFERENT, THEN GO TO 2235
9900  C *** IF 2 CARDS WITH SAME AIRWAY NO. HAVE SAME TYPE AND SIZE OF CONTAM-
10000  C INANT SOURCE, DISREGARD FIRST CARD
10100 2220  ISTT(K)=ISTT(J)
10200      IENDT(K)=IENDT(J)
10300      ICOR=ICOR+1
10400      NCENT(K)=-NCENT(K)
10500      GO TO 2265
10600 2225  IF ((IENDT(K)-IENDT(J))+(ISTT(K)-ISTT(J))) 2265,2230,2265
10700  C *** IF DIFFERENT CONTAMINANT SOURCES ACT ON SAME AIRWAY AT SAME TIME,
10800  C DISREGARD FIRST CARD
10900 2230  CONT(K)=CONT(J)
11000      CONC(K)=CONC(J)
11100      O2MIN(K)=O2MIN(J)
11200      SMPO2(K)=SMPO2(J)
11300      HEAT(K)=HEAT(J)
11400      HTP02(K)=HTP02(J)
11500      ISTT(K)=ISTT(J)
11600      IENDT(K)=IENDT(J)
11700      ICOR=ICOR+1
11800      NCENT(K)=-NCENT(K)
11900      GO TO 2265
12000 2235  SUMC1=CONT(J)+CONC(J)+O2MIN(J)+SMPO2(J)
12100      SUMC2=CONT(K)+CONC(K)+O2MIN(K)+SMPO2(K)
12200  C *** IF CONTAMINANT DIFFERENT, GO TO 2250 AND COMPARE START AND FINISH
12300  C TIME
12400      IF (SUMC1-SUMC2) 2250,2240,2250
12500 2240  IF ((ISTT(K).EQ.ISTT(J)).AND.(IENDT(K).EQ.IENDT(J))) GO TO 2245

```

```

12600 C *** IF TWO CARDS WITH SAME AIRWAY # HAVE SAME TYPE AND SIZE
12700 C OF CONTAMINANT SOURCE, AND TIMES ARE
12800 C DIFFERENT, DISREGARD FIRST CARD
12900 ISTD(K)=ISTD(J)
13000 IENDT(K)=IENDT(J)
13100 2245 ICOR=ICOR+1
13200 GO TO 2265
13300 2250 IF ((ISTD(K).EQ.ISTD(J)).AND.(IENDT(K).EQ.IENDT(J))) GO TO 2255
13400 GO TO 2265
13500 C *** IF DIFFERENT CONTAMINANT SOURCES ACT ON SAME AIRWAY AT SAME
13600 C TIME, DISREGARD FIRST CARD
13700 2255 CONT(K)=CONT(J)
13800 CONC(K)=CONC(J)
13900 O2MIN(K)=O2MIN(J)
14000 SMPD2(K)=SMPD2(J)
14100 HEAT(K)=HEAT(J)
14200 HTPD2(K)=HTPD2(J)
14300 ICOR=ICOR+1
14400 GO TO 2265
14500 2260 CONTINUE
14600 2265 CONTINUE
14700 DO 2280 I=1, INFLOW
14800 IF (NCENT(I)) 2275, 2270, 2270
14900 C *** IF AN AIRWAY IN INFLOW CARDS DID NOT REAPPEAR IN NACC CARDS, THEN
15000 C SOURCE ACTS FOR ENTIRE REAL TIME CALCULATION
15100 2270 ISTD(I)=0.
15200 IENDT(I)=IDUR
15300 GO TO 2280
15400 2275 NCENT(I)=-NCENT(I)
15500 2280 CONTINUE
15600 C *** ICOR=# OF DELETIONS
15700 INFLOW=NACC+INFLOW-ICOR
15800 2285 WRITE (LP, 3120)
15900 IF ((L.GT.0).OR.(MRKL.GT.0)) WRITE (LP, 3310) LAAVR, AAVR
16000 WRITE (LP, 3130)
16100 WRITE(LP, 3135) (NCENT(I), CONT(I), CONC(I), O2MIN(I), SMPD2(I), ISTD(I)
16200 1, IENDT(I), I=1, INFLOW)
16300 C CALCULATE INTERNAL INCREMENT (XINT) AND MULTIPLIER (MULT).
16400 TL=0.
16500 C *** CALCULATE AIR VELOCITY AND TRAVEL TIME FOR EACH AIRWAY
16600 DO 2290 I=1, NB
16700 VEL(I)=Q(I)/A(I)
16800 TL=TL+LA(I)/VEL(I)
16900 2290 CONTINUE
17000 C *** CALCULATE AVERAGE TRAVEL TIME
17100 AVL=TL/NB
17200 C *** XL5PC=LARGEST VALUE OF CONTAMINANT TRAVEL TIME THAT CAN BE EXCLUDED
17300 C NAD=# OF AIRWAYS THAT CAN BE EXCLUDED
17400 XL5PC=AVL*EPX/100.
17500 NAD=IFIX((NB*REP/100.))
17600 IF (NAD.EQ.0) GO TO 2305
17700 DO 2300 I=1, NAD
17800 AMIN=1. E10
17900 C *** AMIN=MINIMUM TRAVEL TIME IN AIRWAYS NOT EXCLUDED
18000 C TEMPORARILY SET O(J)=-O(J) FOR EXCLUDED AIRWAYS
18100 DO 2295 J=1, NB
18200 IF (O(J).LT.0.) GO TO 2295
18300 IF ((LA(J)/VEL(J)).GT.AMIN) GO TO 2295
18400 AMIN=LA(J)/VEL(J)
18500 K=J
18600 2295 CONTINUE
18700 IF (AMIN.GT.XL5PC) GO TO 2305
18800 O(K)=-O(K)

```

```

18900 2300 CONTINUE
19000 2305 AMIN=1.E10
19100 C *** CALC MIN TRAVEL TIME IN AIRWAYS OTHER THAN EXCLUDED AIRWAYS
19200      DO 2310 I=1,NB
19300      IF (Q(I).LT.0.) GO TO 2310
19400      TRTM=LA(I)/VEL(I)
19500      IF (TRTM.LE.AMIN)AMIN=TRTM
19600 2310 CONTINUE
19700 C *** IF AMIN<INC, CALCULATE LEAST 'MULT' SUCH THAT XINT=INC/MULT
19800 C      WHERE XINT.LE.AMIN
19900      IF (AMIN.GE.INC) GO TO 2325
20000      DO 2315 I=1,IMSL
20100      MULT=I
20200      XINT=(FLOAT(INC))/(FLOAT(I))
20300      IF (XINT.LE.AMIN) GO TO 2320
20400 2315 CONTINUE
20500 2320 IF (XINT.LT.INC) GO TO 2330
20600 C *** IF XINT.GE.INC, SET XINT.EQ.INC
20700 2325 XINT=INC
20800      MULT=1
20900 2330 DO 2335 I=1,NB
21000 C *** RESET 'Q(I)' TO A POSITIVE QUANTITY
21100      IF(Q(I).LT.0)Q(I)=-Q(I)
21200      NW(I)=0
21300      ISCOB(I)=0
21400      NWAL(I)=0
21500      NWAR(I)=0
21600 2335 CONTINUE
21700 C      FORMATS
21800 3100 FORMAT (1H0,'REAL TIME CALCULATION NOT COMPLETED NO ', 'CONTAMINATI
21900 1ON STATED')
22000 3105 FORMAT (1H0,'REAL TIME CALCULATION NOT COMPLETED AIRWAY', ' LENGTH
22100 1 OR AREA NOT GIVEN')
22200 3115 FORMAT (3I5,2F6.2,F8.4,I5,F6.5)
22300 3120 FORMAT (1H1,T48,'R E A L   T I M E   A N A L Y S I S')
22400 3125 FORMAT (I5,F10.0,F10.5,F10.2,3F10.5,2I5)
22500 3130 FORMAT (////,T25,'THE FOLLOWING CONTAMINATION HISTORY ', 'WAS ASSUM
22600 1ED FOR THE REAL TIME ANALYSIS',/,T18,'CONTAMINATION',T43,'OXYGEN
22700 2CONCENTRATION',T67,'PRODUCTION PER % OXYGEN',T95,'TIME HISTORY OF
22800 3EVENT',/, 'AIRWAY FLOWRATE CONCENTRAT. ', 'BEHIN
22900 4D FIRE FUMES',T95,'START',T105,'END')
23000 3135 FORMAT (I6,F11.1,F11.1,22X,F6.2,17X,F8.2,T95,I5,T103,I5)
23100 3140 FORMAT (1H0,////,134('*'))
23200 3145 FORMAT (1H ,134('*'))
23300 3185 FORMAT (1H0,'AIRWAY CONC % LOCATION START ARRIVAL ')
23400 3295 FORMAT (1H0,///,T30,'AT',I5,' MIN. AFTER THE START OF CONTAMINATIO
23500 1N THE TOTAL EXPOSURE TO',/,T30,'THE CONTAMINANT MEASURED IN PPM*HO
23600 2URS WAS IN THE FOLLOWING JUNCTIONS')
23700 3310 FORMAT (////,T30,'AVERAGE VALUES OF',I8,' FT AND',F10.1,' SQFT
23800 1 WERE INTRODUCED, WHERE',/,T30,'AIRWAY LENGTH AND CROSS SECTIONA
23900 2L AREA HAD NOT BEEN SPECIFIED')
24000 2800 CONTINUE
24100      SNRW=WRNSM
24200      RETURN
24300      END

```

```

100      SUBROUTINE RTIME2
150      C      REAL TIME FUME SPREAD
200          INCLUDE 'CTPAM.COM'
300          DIMENSION NW(IAR),NWAR(IAR),NWAL(IAR), VEL(IAR), ISTD(20)
400          1, TOTEX(IJP),TOWEX(IJP), NGOUT(I
500          2AR),LOUT(IAR),NGIN(IAR),MIN(IAR)
600          INCLUDE 'CTCONN.COM'
700          COMMON/SCLR1/ADDT, BI, COR, DIFCH4, FRO, I, ITN, K, MRC, NM, PI, RN, SUMAIR,
800          1TDM, TOLD, X, ARGMT, CH4JS, CP, DIFPR, FX, ICFTM, J, L, MSTART, NREC, POT,
900          2RTCONT, SUMCH4, TFS, TR, AVRCH4, COAGE, CRITGS, DIFTRD, HC, INFLOW, JX, LP,
1000         3N, NSTART, PROPJS, SRCH4, SUMHT, TIME, VART, AVRPR, CONTAM, CRITHT, DR,
1100         4HEATAD, ISTART, JY, M, NB, NTEMP, QIN, SRPR, SUMPR, TJS, VISC, AVTRD, CONTG,
1200         5CRITSM, FC, HKA, ITCT, JZ, MARKC, NJ, OLADDT, GREC, STRD, SUMT, TM, WT,
1300         6AX, HSU, IO, NFNUM, NT, DNVP, TO, FACT, H, MADJC, MENDW, NADBC, NSFLOW,
1400         7OX, T1, ZDOWN, FNTM, MND, NSNVP, NVPN, ZUP, INDEX, LX, MARKD, NCONC,
1500         BNNVP, NX, ZO, DNVP, KX, MARKN, NETW, NOX, NSW, TSU, Z1, MADJ, MBEGW,
1600         9ITRUE, IFALSE
1700         COMMON/RDCCOM/AAVR, CH4CX, CH4VX, ES, HAX, HKX, KFAVR, CH4F,
1800         1JNOX, NAV, NCH4C, JSTART, CH4PAX, DZRDX, NDIM, OAVR, CH4S,
1900         2HAAVR, HKAVR, LAAVR, MAXJ, TSTART, TRF, TROCKX, TAVR, TRS, EF
2000         COMMON/RTNCOM/NACC, IDUR, INC, EPX, REP, SNRW, JSURF
2100         1      , MULT, XINT
2200         2      , ISCOB(IAR), IENDT(20), RTAC(IAR, 240, 4), RTJC(IAR, 2)
2300         COMMON/RTMCOM/MRKL
2400         EQUIVALENCE (INU,NGOUT), (KJS,LOUT), (KJF,NGIN), (KNO,MIN)
2500         EQUIVALENCE (PROP,TOWEX), (T,TOTEX), (NWTYP,NW), (NREV,NWAR), (KF,NWAL
2600         1), (TROCK,VEL), (NOF,ISTD)
2700      C
2800      C
2900      C      REAL TIME CALCULATION
3000      C
3100      C
3200      C
3300          NWM=240
3400          WRNSM=SNRW
3500      C
3600      C      REAL TIME CONCENTRATION AND FUME POSITION CALCULATION.
3700      C
3800          DO 2795 I=INC, IDUR, INC
3900          DO 2695 J=1, MULT
4000          DO 2650 K=1, NB
4100      C      CHECK AIRWAY CONDITION
4200          IF (NO(K)) 2650, 2650, 2340
4300      C      CALCULATE CONCENTRATION OF FUMES
4400      2340 DO 2350 M=1, NJ
4500          IF (ABS(JS(K))-ABS(JNOL(M))) 2350, 2345, 2350
4600      2345 M1=M
4700          GO TO 2355
4800      2350 CONTINUE
4900      2355 DO 2405 L=1, INFLOW
5000          IF (NCENT(L)-ABS(NO(K))) 2405, 2360, 2405
5100      2360 IF ((I-INC.LT. ISTD(L)).OR. (I.GT. IENDT(L))) GO TO 2405
5200      2365 IF (CONT(L)) 2370, 2375, 2370
5300      2370 CONTAM=CONT(L)*CONC(L)/100.
5400          CONTG=CONT(L)
5500          GO TO 2380
5600      2375 CONTAM=0.0
5700          CONTG=0.0
5800      2380 IF (O2MIN(L)) 2390, 2390, 2385
5900      2385 CONTAM=(.21-RTJC(M1, 1)-O2MIN(L)/100.)*G(K)
6000          CONTG=0.0
6100      2390 IF (SMPD2(L)) 2400, 2400, 2395
6200      2395 CONTAM=(.21-RTJC(M1, 1))*G(K)*SMPD2(L)

```

```

6300      CONTQ=0.0
6400      2400  TEMPRC=(RTJC(M1,1)*(Q(K)-CONTQ)/Q(K)+CONTAM/Q(K))
6500      JY=NW(K)
6600      IF(JY.EQ.0)JY=1
6700      C    CHECK CONCENTRATION & START NEW WAVE IF NECESSARY.
6800      IF (ABS(TEMPRC-RTAC(K,JY,1)).LE.CRITSM) GO TO 2415
6900      GO TO 2410
7000      2405  CONTINUE
7100      JY=NW(K)
7200      IF(JY.EQ.0)JY=1
7300      IF (ABS(RTAC(K,JY,1)-RTJC(M1,1)).LE.CRITSM) GO TO 2415
7400      TEMPRC=RTJC(M1,1)
7500      2410  NW(K)=NW(K)+1
7600      JY=NW(K)
7700      RTAC(K,JY,3)=I-INC+(J-1)*XINT
7800      RTAC(K,JY,1)=TEMPRC
7900      RTAC(K,JY,2)=0.
8000      IF(ISCOB(K).NE.-1)ISCOB(K)=-1
8100      2415  IF (ISCOB(K)) 2425,2420,2420
8200      2420  ND(K)=-ND(K)
8300      GO TO 2650
8400      C    CALCULATE FUME ADVANCE FOR EACH WAVE IN AIRWAY.
8500      2425  JY=NW(K)-NWAR(K)
8600      IS=1+NWAR(K)
8700      IF ((JY.LE.0).OR.(IS.LE.0).OR.(JY.LT.IS)) GO TO 2420
8800      XSMOK=VEL(K)*XINT
8900      DO 2430 L=IS,JY
9000      RTAC(K,L,2)=RTAC(K,L,2)+XSMOK
9100      2430  CONTINUE
9200      C    CHECK IF ANY WAVES HAVE ARRIVED AT JF AND CALCULATE
9300      C    ARRIVAL TIME.
9400
9500      K2=K
9600      2435  ITR=0
9700      DO 2440 L=IS,JY
9800      IF (RTAC(K2,L,2).LT.LA(K2)) GO TO 2440
9900      DVTM=(RTAC(K2,L,2)-LA(K2))/VEL(K2)
10000     RTAC(K2,L,2)=LA(K2)
10100     RTAC(K2,L,4)=I-INC+XINT*J-DVTM
10200     RTAC(K2,L,4)=-RTAC(K2,L,4)
10300     NWAR(K2)=NWAR(K2)+1
10400     ITR=-1
10500     2440  CONTINUE
10600     IF (ABS(JF(K2)).EQ.JSURF) GO TO 2420
10700     IF (ITR.NE.-1) GO TO 2420
10800     C    FIND ALL WAVES EFFECTING JUNCTION DURING THIS XINT
10900     DO 2645 L=1,NJ
11000     IF (ABS(JF(K2))-ABS(JNQL(L))) 2645,2445,2645
11100     2445  M1=MIN(L-1)+1
11200     M2=MIN(L)
11300     IF(L.EQ.1)M1=1
11400     DO 2480 M=M1,M2
11500     IA=NGIN(M)
11600     DO 2475 M3=1,NB
11700     IF (ABS(ND(IA)).EQ.ABS(ND(K2))) GO TO 2480
11800     IF (ABS(ND(M3))-ABS(ND(IA))) 2475,2450,2475
11900     2450  IF (ISCOB(M3)) 2455,2480,2480
12000     2455  IF (ND(M3)) 2480,2460,2460
12100     2460  IF (JF(M3)) 2480,2465,2465
12200     2465  JF(M3)=-JF(M3)
12300     XSMOK=VEL(M3)*XINT
12400     JY2=NW(M3)-NWAR(M3)
12500     IS=1+NWAR(M3)

```

```

12600      IF (JY2.LE.0) GO TO 2480
12700      C      ADVANCE ALL WAVES EFFECTING JUNCTION TO JUNCTION AND
12800      C      CALCULATE ARRIVAL TIME.
12900      DO 2470 IY=IS, JY2
13000      IF ((XSMOK+RTAC(M3, IY, 2)).LT.LA(M3)) GO TO 2480
13100      QVTM=(RTAC(M3, IY, 2)+XSMOK-LA(M3))/VEL(M3)
13200      RTAC(M3, IY, 2)=LA(M3)
13300      RTAC(M3, IY, 4)=I-INC+XINT#J-QVTM
13400      RTAC(M3, IY, 4)=-RTAC(M3, IY, 4)
13500      NWAR(M3)=NWAR(M3)+1
13600      2470 CONTINUE
13700      2475 CONTINUE
13800      2480 CONTINUE
13900      C      FIND FIRST WAVE TO ARRIVE OF ALL WAVES ARRIVING.
14000      2485 HIGH=-1.E+10
14100      NOH=0
14200      NWH=0
14300      2490 DO 2510 M=M1, M2
14400      IA=NGIN(M)
14500      DO 2505 M3=1, NB
14600      IF (ABS(NO(M3))-ABS(NO(IA))) 2505, 2495, 2505
14700      2495 JY2=NW(M3)-NWAL(M3)
14800      IF (JY2.LE.0) GO TO 2510
14900      DO 2500 M4=1, JY2
15000      IF (RTAC(M3, M4, 4).GE.0.) GO TO 2500
15100      IF (RTAC(M3, M4, 4).LT.HIGH) GO TO 2500
15200      HIGH=RTAC(M3, M4, 4)
15300      NOH=M3
15400      NWH=M4
15500      2500 CONTINUE
15600      2505 CONTINUE
15700      2510 CONTINUE
15800      IF (HIGH.EQ.-1.E+10) GO TO 2620
15900      IF(RTAC(NOH, NWH, 4).LT.0)RTAC(NOH, NWH, 4)=-RTAC(NOH, NWH, 4)
16000      SUMAIR=0.0
16100      SUMPR=0.
16200      C      CALCULATE JUNCTION CONDITIONS
16300      DO 2550 M=M1, M2
16400      IA=NGIN(M)
16500      DO 2545 M3=1, NB
16600      IF (ABS(NO(M3))-ABS(NO(IA))) 2545, 2515, 2545
16700      2515 SUMAIR=SUMAIR+Q(M3)
16800      IF (M3-NOH) 2525, 2520, 2525
16900      2520 SUMPR=SUMPR+RTAC(M3, NWH, 1)*Q(M3)
17000      GO TO 2550
17100      2525 JY2=NWAR(M3)
17200      IF (JY2) 2530, 2530, 2535
17300      2530 C=0.
17400      GO TO 2540
17500      2535 C=RTAC(M3, JY2, 1)
17600      2540 SUMPR=SUMPR+C*Q(M3)
17700      GO TO 2550
17800      2545 CONTINUE
17900      2550 CONTINUE
18000      EXPCN=RTJC(L, 1)
18100      EXPT=RTJC(L, 2)
18200      RTJC(L, 1)=SUMPR/SUMAIR
18300      RTJC(L, 2)=ABS(RTAC(NOH, NWH, 4))
18400      TOTEX(L)=TOTEX(L)+EXPCN*(RTJC(L, 2)-EXPT)*1000000./60.
18500      C      ADVANCE WAVE BY REMANING TIME INTO ALL OUTGOING AIRWAYS
18600      C      AND CALCULATE AIRWAY CONCENTRATIONS.
18700      M5=LOUT(L-1)+1
18800      M6=LOUT(L)

```

```

18900      IF (L. EQ. 1) M5=1
19000      RT=(I-INC+XINT*J)-ABS(HIGH)
19100      DO 2615 M4=M5, M6
19200      IA=NGOUT(M4)
19300      DO 2610 M=1, NB
19400      IF (ABS(ND(M))-ABS(ND(IA))) 2610, 2555, 2610
19500 2555   JY=NW(M)
19600      IF (JY. EQ. 0) JY=1
19700      DO 2600 M3=1, INFLOW
19800      IF (NCENT(M3)-ABS(ND(M))) 2600, 2560, 2600
19900 2560   IF ((I-INC. LT. ISTT(M3)). OR. (I. GT. IENDT(M3))) GO TO 2600
20000      IF (CONT(M3)) 2565, 2570, 2565
20100 2565   CONTAM=CONT(M3)*CONC(M3)/100.
20200      CONTQ=CONT(M3)
20300      GO TO 2575
20400 2570   CONTAM=0.
20500      CONTQ=0.
20600 2575   IF (O2MIN(M3)) 2585, 2585, 2580
20700 2580   CONTAM=(. 21-RTJC(L, 1)-O2MIN(M3)/100. ) * Q(M)
20800      CONTQ=0.
20900 2585   IF (SMPD2(M3)) 2595, 2595, 2590
21000 2590   CONTAM=(. 21-RTJC(L, 1)) * Q(M) * SMPD2(M3)
21100      CONTQ=0. 0
21200 2595   TEMPRC=(RTJC(L, 1) * (Q(M)-CONTQ) / Q(M) + CONTAM / Q(M))
21300      IF (ABS(TEMPRC-RTAC(M, JY, 1)). LE. CRITSM) GO TO 2615
21400      NW(M)=NW(M)+1
21500      JY=NW(M)
21600      RTAC(M, JY, 1)=TEMPRC
21700      GO TO 2605
21800 2600   CONTINUE
21900      IF (ABS(RTAC(M, JY, 1)-RTJC(L, 1)). LE. CRITSM) GO TO 2615
22000      NW(M)=NW(M)+1
22100      JY=NW(M)
22200      RTAC(M, JY, 1)=RTJC(L, 1)
22300 2605   ISCOB(M)=-1
22400      NWAL(M)=NVAL(M)+1
22500      RTAC(M, JY, 2)=VEL(M)*RT
22600      RTAC(M, JY, 3)=ABS(RTAC(NOH, NWH, 4))
22700      GO TO 2615
22800 2610   CONTINUE
22900 2615   CONTINUE
23000      GO TO 2485
23100  C     CALCULATE IF FUMES REACHES MORE THAN ONE JUNCTION IN
23200  C     ONE XINT.
23300 2620   DO 2640 M4=M5, M6
23400      IA=NGOUT(M4)
23500      DO 2635 M=1, NB
23600      IF (ABS(ND(M))-ABS(ND(IA))) 2635, 2625, 2635
23700 2625   JY=NW(M)
23800      IF (RTAC(M, JY, 2). LT. LA(M)) GO TO 2640
23900      IF (ABS(JF(M)). EQ. JSURF) GO TO 2630
24000      K2=M
24100      IS=1+NWAR(K2)
24200      JY=NW(K2)-NWAR(K2)
24300      GO TO 2435
24400 2630   DVTM=(RTAC(M, JY, 2)-LA(M)) / VEL(M)
24500      RTAC(M, JY, 4)=I-INC+XINT*J-DVTM
24600      RTAC(M, JY, 2)=LA(M)
24700      NWAR(M)=NWAR(M)+1
24800      GO TO 2640
24900 2635   CONTINUE
25000 2640   CONTINUE
25100      GO TO 2650

```

```

25200 2645 CONTINUE
25300 2650 CONTINUE
25400 C   RESET MARKERS, COMPACT WAVES IF NECESSARY AND CHECK
25500 C   FOR AIRWAYS WITH UNIFORM CONCENTRATIONS.
25600     DO 2690 IU=1,NB
25700     IF (NW(IU).LE.NWM) GO TO 2655
25800     WRITE (LP,3285) NO(IU)
25900     GO TO 2800
26000 2655 IF (NO(IU).LT.0)NO(IU)=-NO(IU)
26100     IF (JS(IU).LT.0)JS(IU)=-JS(IU)
26200     IF (JF(IU).LT.0)JF(IU)=-JF(IU)
26300     NWAL(IU)=0
26400     IF (NW(IU).LE.5) GO TO 2675
26500     M=0
26600     JY=NW(IU)
26700     DO 2660 IW=1,JY
26800     IF (RTAC(IU,IW,4).EQ.0) GO TO 2660
26900     M=M+1
27000     RTAC(IU,IW,1)=0.
27100     RTAC(IU,IW,2)=0.
27200     RTAC(IU,IW,3)=0.
27300     RTAC(IU,IW,4)=0.
27400     IF (M.EQ.5) GO TO 2665
27500 2660 CONTINUE
27600     IF (M.NE.0) GO TO 2665
27700     GO TO 2675
27800 2665 M1=M+1
27900     DO 2670 IW=M1,JY
28000     RTAC(IU,IW-M1+1,1)=RTAC(IU,IW,1)
28100     RTAC(IU,IW-M1+1,2)=RTAC(IU,IW,2)
28200     RTAC(IU,IW-M1+1,3)=RTAC(IU,IW,3)
28300     RTAC(IU,IW-M1+1,4)=RTAC(IU,IW,4)
28400     RTAC(IU,IW,1)=0.
28500     RTAC(IU,IW,2)=0.
28600     RTAC(IU,IW,3)=0.
28700     RTAC(IU,IW,4)=0.
28800 2670 CONTINUE
28900     NWAR(IU)=0
29000     NW(IU)=NW(IU)-M
29100 C   WRITE (LP,3275) M,NO(IU)
29200 2675 IF (NW(IU).EQ.0) GO TO 2690
29300     JY=NW(IU)
29400     IF (RTAC(IU,1,4).LT.0.)RTAC(IU,1,4)=-RTAC(IU,1,4)
29500     IF ((NW(IU).EQ.1).AND.(RTAC(IU,1,2).EQ.LA(IU))) GO TO 2685
29600     IF (NW(IU).EQ.1) GO TO 2690
29700     DO 2680 ID=2,JY
29800     IF (RTAC(IU,ID,4).LT.0.)RTAC(IU,ID,4)=-RTAC(IU,ID,4)
29900     IF (RTAC(IU,ID,2).EQ.LA(IU)) GO TO 2680
30000     GO TO 2690
30100 2680 CONTINUE
30200 2685 ISCOB(IU)=1
30300 2690 CONTINUE
30400 2695 CONTINUE
30500 C   OUTPUT
30600     WRITE (LP,3140)
30700     WRITE (LP,3145)
30800     WRITE (LP,3145)
30900     NWMAX=0
31000     DO 2705 M=1,NB
31100     JY=NW(M)
31200     NWE=NW(M)
31300     IF (NW(M).EQ.0) GO TO 2705
31400     DO 2700 M1=1,JY

```

```

31500      IF(RTAC(M, M1, 1). LT. WRNSM)NWE=NWE-1
31600 2700  CONTINUE
31700      IF(NWE. GE. NWMAX)NWMAX=NWE
31800 2705  CONTINUE
31900      IF (NWMAX. GT. 0) GO TO 2710
32000      WRITE (LP, 3155) I, WRNSM
32100      GO TO 2795
32200 2710  WRITE (LP, 3150) I, WRNSM
32300      WRITE (LP, 3160)
32400      DO 2720 M=1, NB
32500      IF(O(M). LT. 0)O(M)=O(M)*-1
32600      JY=NW(M)
32700      DO 2715 M2=1, JY
32800      IF (RTAC(M, M2, 1). LT. WRNSM) GO TO 2715
32900      IF(O(M). GT. 0)O(M)=O(M)*-1
33000      MM=NW(M)
33100      WRITE(LP, 3165) NO(M), JS(M), JF(M), LA(M), NW(M), RTAC(M, MM, 1), RTAC(M, M
33200      1M, 3), RTAC(M, MM, 2)
33300      GO TO 2720
33400 2715  CONTINUE
33500 2720  CONTINUE
33600      WRITE (LP, 3170)
33700      IF (NWMAX. GE. 2) WRITE (LP, 3175)
33800      IF (NWMAX. GE. 3) WRITE (LP, 3180)
33900      WRITE (LP, 3185)
34000      IF (NWMAX. GE. 2) WRITE (LP, 3190)
34100      IF (NWMAX. GE. 3) WRITE (LP, 3195)
34200      WRITE (LP, 3200)
34300      IF (NWMAX. GE. 2) WRITE (LP, 3205)
34400      IF (NWMAX. GE. 3) WRITE (LP, 3210)
34500      DO 2745 M=1, NB
34600      IF (O(M). GT. 0) GO TO 2745
34700      IF (NWMAX. GT. 6) GO TO 2735
34800      GO TO (2725, 2730, 2735, 2735, 2735, 2735), NWMAX
34900 2725  WRITE (LP, 3260)
35000      GO TO 2740
35100 2730  WRITE (LP, 3265)
35200      GO TO 2740
35300 2735  WRITE (LP, 3270)
35400 2740  IF (NW(M). GT. 0) WRITE (LP, 3290) NO(M)
35500      IF(RTAC(M, 1, 1). GT. WRNSM) WRITE (LP, 3215) RTAC(M, 1, 1), RTAC(M, 1, 2), R
35600      1TAC(M, 1, 3), RTAC(M, 1, 4)
35700      IF(RTAC(M, 2, 1). GT. WRNSM) WRITE (LP, 3220) RTAC(M, 2, 1), RTAC(M, 2, 2), R
35800      1TAC(M, 2, 3), RTAC(M, 2, 4)
35900      IF(RTAC(M, 3, 1). GT. WRNSM) WRITE (LP, 3225) RTAC(M, 3, 1), RTAC(M, 3, 2), R
36000      1TAC(M, 3, 3), RTAC(M, 3, 4)
36100      IF(NWMAX. LE. 3)O(M)=-O(M)
36200 2745  CONTINUE
36300      IF (NWMAX. LE. 3) GO TO 2780
36400      WRITE (LP, 3230)
36500      IF (NWMAX. GE. 5) WRITE (LP, 3235)
36600      IF (NWMAX. GE. 6) WRITE (LP, 3240)
36700      WRITE (LP, 3185)
36800      IF (NWMAX. GE. 5) WRITE (LP, 3190)
36900      IF (NWMAX. GE. 6) WRITE (LP, 3195)
37000      WRITE (LP, 3200)
37100      IF (NWMAX. GE. 5) WRITE (LP, 3205)
37200      IF (NWMAX. GE. 6) WRITE (LP, 3210)
37300      DO 2770 M=1, NB
37400      IF (O(M). GT. 0.) GO TO 2770
37500      IF (NW(M). LT. 4) GO TO 2770
37600      IF (NWMAX. GT. 6) GO TO 2760
37700      GO TO (2770, 2770, 2770, 2750, 2755, 2760), NWMAX

```

```

37800 2750 WRITE (LP,3260)
37900      GO TO 2765
38000 2755 WRITE (LP,3265)
38100      GO TO 2765
38200 2760 WRITE (LP,3270)
38300 2765 IF (NW(M).GT.3) WRITE (LP,3290) NO(M)
38400      IF(RTAC(M,4,1).GT.WRNSM) WRITE (LP,3215) RTAC(M,4,1),RTAC(M,4,2),R
38500      1TAC(M,4,3),RTAC(M,4,4)
38600      IF(RTAC(M,5,1).GT.WRNSM) WRITE (LP,3220) RTAC(M,5,1),RTAC(M,5,2),R
38700      1TAC(M,5,3),RTAC(M,5,4)
38800      IF(RTAC(M,6,1).GT.WRNSM) WRITE (LP,3225) RTAC(M,6,1),RTAC(M,6,2),R
38900      1TAC(M,6,3),RTAC(M,6,4)
39000      O(M)=-O(M)
39100 2770 CONTINUE
39200      DO 2775 M=1,NB
39300      IF (NW(M).LE.6) GO TO 2775
39400      IBUF=NW(M)-6
39500      WRITE (LP,3280) IBUF,NO(M)
39600 2775 CONTINUE
39700 2780 WRITE (LP,3245) I,WRNSM
39800      WRITE (LP,3250)
39900      DO 2785 M=1,NJ
40000      IF(RTJC(M,1).GT.WRNSM) WRITE (LP,3255) JNOL(M),RTJC(M,1),RTJC(M,2)
40100 2785 CONTINUE
40200      WRITE (LP,3295) I
40300      WRITE (LP,3300)
40400      DO 2790 K=1,NJ
40500      TOWEX(K)=TDTEX(K)+(RTJC(K,1)*(I-RTJC(K,2)))*1000000./60.
40600 2790 CONTINUE
40700      WRITE (LP,3305) (JNOL(K),TOWEX(K),K=1,NJ)
40800 2795 CONTINUE
40900 2800 RETURN
41000 C
41100 C FORMATS
41200 3140 FORMAT (1H0,////,120('*'))
41300 3145 FORMAT (1H,120('*'))
41400 3150 FORMAT (1H0,///,T39,'AT ',I5,' MIN. AFTER THE START OF ', 'CONTAMIN
41500      1ATION CRITICAL',/,T39,' FUME CONCENTRATIONS ', '(FUMES > ',2PF8.4,'
41600      2 %) NOW EXIST IN THE',/,T57,' FOLLOWING', ' AIRWAYS')
41700 3155 FORMAT (1H, 'AT ',I5,' MIN. AFTER THE START OF ', 'CONTAMINATION NO
41800      1 CRITICAL FUME CONDITIONS (FUMES > ',2PF8.4,' %) NOW EXIST')
41900 3160 FORMAT (1H0,///,T32,'AIRWAY',T92,'WAVE',///,T15,'NUMBER FROM
42000      1 TO LENGTH FT',T73,'NUMBER CONC % START TIME LENGTH FT')
42100 3165 FORMAT (1H ,T16,I5,I8,I7,T42,I7,T74,I5,2PF9.4,T92,OPF7.2,T105,OPF7
42200      1.1)
42300 3170 FORMAT (1H0,///,T30,'WAVE 1')
42400 3175 FORMAT (1H+,T60,'WAVE 2')
42500 3180 FORMAT (1H+,T90,'WAVE 3')
42600 3185 FORMAT (1H0,'AIRWAY CONC % LOCATION START ARRIVAL ')
42700 3190 FORMAT (1H+,T46,' CONC % LOCATION START ARRIVAL ')
42800 3195 FORMAT (1H+,T82,' CONC % LOCATION START ARRIVAL ')
42900 3200 FORMAT (1H ,T9,' ',T23,'FT',T29,'TIME',T37,'TIME',T45,' ')
43000 3205 FORMAT (1H+,T58,'FT',T64,'TIME',T72,'TIME',T81,' ')
43100 3210 FORMAT (1H+,T95,'FT',T101,'TIME',T108,'TIME',T117,' ')
43200 3215 FORMAT (1H+,T11,2PF8.4,T20,OPF7.1,T29,F7.2,T37,F7.2)
43300 3220 FORMAT (1H+,T47,2PF8.4,T57,OPF7.1,T66,F7.2,T74,F7.2)
43400 3225 FORMAT (1H+,T83,2PF8.4,T93,OPF7.1,T102,F7.2,T110,F7.2)
43500 3230 FORMAT (1H0,///,T30,'WAVE 4')
43600 3235 FORMAT (1H+,T60,'WAVE 5')
43700 3240 FORMAT (1H+,T90,'WAVE 6')
43800 3245 FORMAT (1H0,///,T39,'AT ',I5,' MIN. AFTER THE START OF ', 'CONTAMIN
43900      1ATION CRITICAL',/,T39,' FUME CONCENTRATIONS ', '(FUMES > ',2PF7.3,'
44000      2) % NOW EXIST IN THE',/,T57,' FOLLOWING', ' JUNCTIONS')

```

```

44100 3250 FORMAT (1H0, 'JUNCTION', T15, 'CURRENT FUME CONCENTRATION', T50, 'TIME
44200 1 OF FIRST CONTAMINATION')
44300 3255 FORMAT (1H , T3, I5, T25, 2PF8. 4, T63, OPF7. 2)
44400 3260 FORMAT (1H , T9, ' ', T45, ' ')
44500 3265 FORMAT (1H , T9, ' ', T45, ' ', T81, ' ')
44600 3270 FORMAT (1H , T9, ' ', T45, ' ', T81, ' ', T117, ' ')
44700 C3275 FORMAT (1H , '**WARNING** THE FIRST ', I1, ' WAVES OF ', 'AIRWAY', I5, '
44800 C 1 ARE BEING REMOVED TO ALLOW FOR ', 'ADDITIONAL WAVES')
44900 3280 FORMAT (1H0, ///, ' ', I5, ' WAVES OF AIRWAY ', I5, ' ARE BEING BUFFERD
45000 1UNTIL PRINTING SPACE IS AVAABLE')
45100 3285 FORMAT (1H0, ///, ' PROGRAM EXECUTION TERMINATED DUE TO AN ', 'EXCESS
45200 1IVE NUMBER OF CONTAMINATION WAVES IN AIRWAY ', I5, ' ', ' TO RECEIV
45300 2E ', 'MORE DETAILED INFORMATION INTERNAL PROGRAM MODIFICATION IS '
45400 3, 'NESSARY. ')
45500 3290 FORMAT (1H+, I5)
45600 3295 FORMAT (1H0, ///, T30, 'AT', I5, ' MIN. AFTER THE START OF CONTAMINATIO
45700 1N THE TOTAL EXPOSURE TO', ' ', T30, 'THE CONTAMINANT MEASURED IN PPM*HD
45800 2URS WAS IN THE FOLLOWING JUNCTIONS')
45900 3300 FORMAT (1H0, 'JUNCTION', T14, 'TOTAL EXPOSURE', T40, 'JUNCTION', T54, 'TO
46000 1TAL EXPOSURE', T80, 'JUNCTION', T94, 'TOTAL EXPOSURE')
46100 3305 FORMAT (1H , I8, T16, F10. 2, T40, I8, T56, F10. 2, T80, I8, T96, F10. 2)
46200 END

```

```
50 C CTPAM.COM  
100 PARAMETER IAR=300, IJP=300, J5=300, IFIN=300, IMSL=9000
```

```
50      CTCONN. COM
100      COMMON NO(IAR), JS(IAR), JF(IAR), Q(IAR),
200      1JNQL(IJP), JND(IJP), JLR(IJP), PROP(IJP), RDPROP(IAR),
300      2MEMREC(J5), NOREC(J5), ESTPR(J5), ESTCH4(J5), ESTTR(J5), HEAT(20), TR
400      3D(IAR), LA(IAR), A(IAR), O(IAR), KF(IAR), CH4V(IAR),
500      4T(IJP), NCENT(20), CONT(20), CONC(20), TROCK(IAR), HA(IAR), HK(
600      5IAR), DZRD(IAR), PRCH4(IJP), RDCH4(IJP), O2MIN(20), SMPD2(20), HTPD2(20)
700      6, TFSI(20), XNEW(IAR), R(IAR), MEND(IFIN), MSL(IMSL), RSTD(IAR),
800      7 FRNVP(IAR
900      8), QF(10, 10), PF(10, 10), RGRAD(10), NFCW(10), NFREG(10), MPTS(10),
1000     9FNVP(IFIN), NWTYP(IAR), RQ(IAR), INU(IAR), KJS(IAR), KJF(IAR), KND
1100     $(IAR), NOF(20), NREV(IAR)
```

APPENDIX B.--INPUT DATA FOR FUEL-RICH FIRE IN A DOWNCAST SHAFT

100	NETWORK CONTROL CARD												
200	NB	NJ	NFUM	NADBC	NVPN	NETW	NCONC	NTEMP	MADJ	ITN	DR	TR	IRTCC
300	51	32	2	3	1	1	1	1	10	30	.075	70.00	1
400	AIRWAY CARDS												
500	NO	JS	JF	NWTYP	R	G	KF	LA	A	O			
600	1	1	2	0	0.156	200000	250	2597	200.0	50.0			
700	2	2	3	0	0.048	60000	250	325	200.0	50.0			
800	3	1	4	0	0.479	100000	250	2577	200.0	50.0			
900	4	1	23	0	0.995	30000	250	2580	200.0	50.0			
1000	5	2	4	0	2.400	35000	100	2900	80.0	35.0			
1100	6	4	5	1	4.000	60000	100	100	80.0	35.0			
1200	7	5	6	0	2.307	60000	100	2700	80.0	35.0			
1300	8	6	7	0	1888.233	5000	350	524	120.0	44.0			
1400	9	6	7	0	9.923	60000	100	1700	80.0	35.0			
1500	10	7	14	0	3.239	70000	100	1650	80.0	35.0			
1600	11	14	31	0	20.002	70000	100	4500	80.0	35.0			
1700	12	3	8	0	0.360	53600	100	2700	80.0	35.0			
1800	13	8	19	0	41.490	20000	100	2050	80.0	35.0			
1900	14	8	9	0	0.821	50000	100	600	80.0	35.0			
2000	15	9	10	0	1.437	35000	100	600	80.0	35.0			
2100	16	10	11	0	124.385	6000	100	600	80.0	30.0			
2200	17	10	11	0	5.500	30000	100	1100	80.0	35.0			
2300	18	11	12	0	3.900	35000	350	319	120.0	44.0			
2400	19	12	13	0	3.772	35000	100	600	80.0	35.0			
2500	20	14	13	0	4.000	6000	350	524	120.0	44.0			
2600	21	13	15	0	1.108	35000	100	550	80.0	35.0			
2700	22	9	15	0	474.065	6000	350	318	120.0	44.0			
2800	23	15	16	0	2.047	30000	100	600	80.0	35.0			
2900	24	2	16	0	77.702	14800	100	2600	80.0	35.0			
3000	25	16	17	0	2.285	60000	100	1050	80.0	35.0			
3100	26	17	18	0	2.966	60000	350	228	120.0	44.0			
3200	27	20	17	0	3.500	2000	100	800	80.0	35.0			
3300	28	20	18	0	4.931	50000	100	1217	80.0	35.0			
3400	29	19	20	0	4.565	50000	350	333	120.0	44.0			
3500	30	21	19	0	0.475	31300	100	1100	80.0	35.0			
3600	31	22	21	0	13.375	40000	100	1313	80.0	35.0			
3700	32	22	21	0	1234.019	3000	350	313	120.0	44.0			
3800	33	23	22	0	14.500	20000	100	1800	80.0	35.0			
3900	34	23	22	0	14.500	20000	100	1800	80.0	35.0			
4000	35	4	24	0	4.324	110000	100	2400	80.0	35.0			
4100	36	24	25	0	5.572	45000	100	2600	80.0	35.0			
4200	37	24	27	0	5.450	20000	100	3200	80.0	35.0			
4300	38	27	28	0	1.066	100000	350	230	120.0	44.0			
4400	39	28	31	0	14.000	40000	100	2292	80.0	35.0			
4500	40	25	26	0	18.360	45000	100	2000	80.0	35.0			
4600	41	26	30	0	3.630	38000	100	1700	80.0	35.0			
4700	42	26	29	0	1.385	5000	100	1050	80.0	35.0			
4800	43	2	27	0	65.065	35449	100	1650	80.0	35.0			
4900	44	28	29	0	1.260	73000	100	750	80.0	35.0			
5000	45	29	30	0	0.854	80000							
5100	46	2	30	0	46.882	44000	100	525	80.0	35.0			
5200	47	30	31	0	0.072	203000							
5300	48	18	30	0	6.265	100000	100	4100	80.0	35.0			
5400	50	1	32	0	441.000	20000	250	30	200.0	50.0			
5500	49	31	32	0	0.610	288350							
5600	51	32	1	1	10.000	450000	100	100	80.0	35.0			
5700	JUNCTION CARDS												
5800	JND	T	Z	CH4									
5900	1	50.0	114										
6000	2	65.06	-2465										
6100	3	67.32	-2790										
6200	4	64.39	-2463										
6300	5	64.51	-2462	0.12									
6400	6	69.88	-2462	0.20									

6500	7	75.60	-1938	0.80
6600	8	72.54	-2787	0.12
6700	9	75.67	-2785	0.25
6800	10	77.09	-2785	0.30
6900	11	78.82	-2787	0.90
7000	12	79.31	-2468	0.95
7100	13	82.42	-2465	0.90
7200	14	81.62	-1942	0.85
7300	15	83.25	-2467	0.90
7400	16	78.56	-2466	0.90
7500	17	77.92	-2463	
7600	18	78.39	-2235	
7700	19	82.54	-2785	0.8
7800	20	80.90	-2452	
7900	21	82.87	-2786	0.85
8000	22	73.28	-2473	0.70
8100	23	65.27	-2466	
8200	24	69.95	-2462	0.15
8300	25	80.65	-2245	0.90
8400	26	86.57	-2247	0.95
8500	27	70.59	-2465	
8600	28	68.59	-2235	
8700	29	72.08	-2239	
8800	30	76.80	-2240	
8900	31	76.44	-1943	
9000	32	65.70	88	
9100	FAN CHARACTERISTIC CARDS			
9200	NOF MPTS			
9300	6	10		
9400	GF	PF	GF	PF
9500	20000	3.60	25000	4.30
9600	70000	4.29	85000	3.96
9700	51	10	100000	3.70
9800	GF	PF	GF	PF
9900	80000	12.25	100000	14.00
10000	400000	10.25	500000	8.85
10100	ADDITIONAL AIRWAY CARDS			
10200	NO		KF	LA
10300	45		100	300
10400	47		250	297
10500	49		250	2031
10600	CONCENTRATION CONTROL CARD			
10700	NDIM	NCH4C	NAV	MAXJ
10800	WRNGS	WRNHT	INFLW	JSTART
10900	6	2	1	32
11000	AVERAGE VALUE CARD			
11100	TAVR	HAAVR	HKA VR	KFAVR
11200	70.0	0.10	3.0	100
11300	ADDITIONAL CONCENTRATION AIRWAY CARDS			
11400	NDX	CH4VX		DZRDx
11500	9	320.0		
11600	17	90.0		
11700	33	120.0		
11800	34	20.0		
11900	36	250.0		
12000	50		50.00	
12100	ADDITIONAL CONCENTRATION JUNCTION CARDS			
12200	JNOX		CH4CX	
12300	27		0.60	
12400	28		0.60	
12500	CONTAMINATION CARD			
12600	NCENT		SMPO2	HTPO2
12700	20		1.00	300.00

12800	REAL TIME CONTROL CARD									
12900	NACC	IDUR	INC	EXP	REP	WRNSM	JSURF	CRITSM		
13000	1	10	2	2.00	2.00	0.001		1.001		
13100	CONTAMINATION CARD									
13200	NCENT					SMP02	HTP02	ISTT	IENDT	
13300	20					1.00	300.00	0	10	

APPENDIX C.--OUTPUT DATA FOR FUEL-RICH FIRE IN A DOWNCAST SHAFT CALCULATION

ORDINARY AIRFLOW AND PRESSURE DISTRIBUTION BEFORE EVENT (BASED ON THE LISTED INPUT DATA)

REGULAR AIRWAYS

AIRWAY	FROM	TO	AIRFLOW	PRESSURE LOSS	LENGTH	AREA	RESISTANCE	K	PERIMETER
1	1	2	153842.	0.369	2597	200.000	0.156	250	50.000
2	2	3	43346.	0.009	325	200.000	0.048	250	50.000
3	1	4	115697.	0.641	2577	200.000	0.479	250	50.000
4	1	23	27030.	0.073	2580	200.000	0.995	250	50.000
5	2	4	32114.	0.248	2900	80.000	2.400	100	35.000
7	5	6	59089.	0.805	2700	80.000	2.307	100	35.000
8	6	7	3994.	3.012	524	120.000	1888.233	350	44.000
9	6	7	55095.	3.012	1700	80.000	9.923	100	35.000
10	7	14	59089.	1.131	1650	80.000	3.239	100	35.000
11	14	31	56342.	6.349	4500	80.000	20.002	100	35.000
12	3	8	43346.	0.068	2700	80.000	0.360	100	35.000
13	8	19	14202.	0.837	2050	80.000	41.490	100	35.000
14	8	9	29145.	0.070	600	80.000	0.821	100	35.000
15	9	10	24837.	0.089	600	80.000	1.437	100	35.000
16	10	11	4313.	0.231	600	80.000	124.385	100	30.000
17	10	11	20524.	0.232	1100	80.000	5.500	100	35.000
18	11	12	24837.	0.241	319	120.000	3.900	350	44.000
19	12	13	24837.	0.233	600	80.000	3.772	100	35.000
20	14	13	2747.	0.003	524	120.000	4.000	350	44.000
21	13	15	27584.	0.084	550	80.000	1.108	100	35.000
22	9	15	4308.	0.880	318	120.000	474.065	350	44.000
23	15	16	31892.	0.208	600	80.000	2.047	100	35.000
24	2	16	11998.	1.118	2600	80.000	77.702	100	35.000
25	16	17	43890.	0.440	1050	80.000	2.285	100	35.000
26	17	18	47731.	0.676	228	120.000	2.966	350	44.000
27	20	17	3842.	0.005	800	80.000	3.500	100	35.000
28	20	18	37390.	0.689	1217	80.000	4.931	100	35.000
29	19	20	41231.	0.776	333	120.000	4.565	350	44.000
30	21	19	27030.	0.035	1100	80.000	0.475	100	35.000
31	22	21	24481.	0.802	1313	80.000	13.375	100	35.000
32	22	21	2549.	0.802	313	120.000	1234.019	350	44.000
33	23	22	13515.	0.265	1800	80.000	14.500	100	35.000
34	23	22	13515.	0.265	1800	80.000	14.500	100	35.000
35	4	24	88722.	3.404	2400	80.000	4.324	100	35.000
36	24	25	34147.	0.650	2600	80.000	5.572	100	35.000
37	24	27	54575.	1.623	3200	80.000	5.450	100	35.000
38	27	28	83055.	0.735	230	120.000	1.066	350	44.000
39	28	31	26833.	1.008	2292	80.000	14.000	100	35.000
40	25	26	34147.	2.141	2000	80.000	18.360	100	35.000
41	26	30	29620.	0.318	1700	80.000	3.630	100	35.000
42	26	29	4526.	0.003	1050	80.000	1.385	100	35.000
43	2	27	28480.	5.277	1650	80.000	65.065	100	35.000
44	28	29	56222.	0.398	750	80.000	1.260	100	35.000
45	29	30	60748.	0.315	300	80.000	0.854	100	35.000
46	2	30	37904.	6.736	525	80.000	46.882	100	35.000
47	30	31	213394.	0.328	297	200.000	0.072	250	50.000
48	18	30	85121.	4.539	4100	80.000	6.265	100	35.000
50	1	32	16360.	11.804	30	200.000	441.000	250	50.000
49	31	32	296569.	5.365	2031	200.000	0.610	250	50.000

FANS

AIRWAY	FROM	TO	AIRFLOW	FAN PRESSURE
6	4	5	59089.	4.505
51	32	1	312929.	11.806

THESE CHARACTERISTICS WERE STORED FOR FANS 6 51

20000.	3.60	25000.	4.30	30000.	4.60	40000.	4.78	55000.	4.58
70000.	4.29	85000.	3.96	100000.	3.70	150000.	3.00	200000.	2.52
80000.	12.25	100000.	14.00	150000.	14.90	200000.	14.05	300000.	12.00
400000.	10.25	500000.	8.85	600000.	7.80	700000.	6.90	800000.	6.20

THE STATED NUMBER OF AIRWAYS WAS 51 THE STATED NUMBER OF JUNCTIONS WAS 32

INPUT DATA FOR CONCENTRATION AND TEMPERATURE CALCULATIONS

AIRWAY	FROM	TO	ELEVATION DIFF.	ROCK TEMP.	METHANE PRODD.	CONDUCTIVITY	DIFFUSIVITY
1	1	2	-2579.0	58.2	0.0	3.0	0.1000
2	2	3	-325.0	67.6	0.0	3.0	0.1000
3	1	4	-2577.0	57.5	0.0	3.0	0.1000
4	1	23	-2580.0	58.4	0.0	3.0	0.1000
5	2	4	2.0	64.3	0.0	3.0	0.1000
6	4	5	1.0	65.7	70.9	3.0	0.1000
7	5	6	0.0	69.9	47.3	3.0	0.1000
8	6	7	524.0	80.1	24.0	3.0	0.1000
9	6	7	524.0	77.5	320.0	3.0	0.1000
10	7	14	-4.0	82.0	29.5	3.0	0.1000
11	14	31	-1.0	76.4	0.0	3.0	0.1000
12	3	8	3.0	72.6	52.0	3.0	0.1000
13	8	19	2.0	82.6	96.6	3.0	0.1000
14	8	9	2.0	77.1	37.9	3.0	0.1000
15	9	10	0.0	77.6	12.4	3.0	0.1000
16	10	11	-2.0	79.4	25.9	3.0	0.1000
17	10	11	-2.0	79.0	90.0	3.0	0.1000
18	11	12	319.0	83.1	12.4	3.0	0.1000
19	12	13	3.0	83.8	0.0	3.0	0.1000
20	14	13	-523.0	80.4	1.4	3.0	0.1000
21	13	15	-2.0	83.6	0.0	3.0	0.1000
22	9	15	318.0	91.7	28.0	3.0	0.1000
23	15	16	1.0	76.2	0.0	3.0	0.1000
24	2	16	-1.0	78.5	108.0	3.0	0.1000
25	16	17	3.0	77.8	0.0	3.0	0.1000
26	17	18	228.0	82.7	0.0	3.0	0.1000
27	20	17	-11.0	77.5	0.0	3.0	0.1000
28	20	18	217.0	78.7	0.0	3.0	0.1000
29	19	20	333.0	82.0	0.0	3.0	0.1000
30	21	19	1.0	82.5	0.0	3.0	0.1000
31	22	21	-313.0	82.6	36.7	3.0	0.1000
32	22	21	-313.0	87.7	3.8	3.0	0.1000
33	23	22	-7.0	73.3	120.0	3.0	0.1000
34	23	22	-7.0	73.3	20.0	3.0	0.1000
35	4	24	1.0	70.1	133.1	3.0	0.1000
36	24	25	217.0	81.3	250.0	3.0	0.1000
37	24	27	-3.0	70.5	245.6	3.0	0.1000
38	27	28	230.0	67.1	0.0	3.0	0.1000
39	28	31	292.0	77.3	0.0	3.0	0.1000
40	25	26	-2.0	86.7	17.1	3.0	0.1000
41	26	30	7.0	76.4	0.0	3.0	0.1000
42	26	29	8.0	71.2	0.0	3.0	0.1000
43	2	27	0.0	70.8	170.9	3.0	0.1000
44	28	29	-4.0	73.4	0.0	3.0	0.1000
45	29	30	-1.0	84.4	0.0	3.0	0.1000
46	2	30	225.0	85.8	0.0	3.0	0.1000
47	30	31	297.0	81.2	0.0	3.0	0.1000
48	18	30	-5.0	76.8	0.0	3.0	0.1000
50	1	32	0.0	50.0	0.0	3.0	0.1000
49	31	32	2031.0	71.2	0.0	3.0	0.1000
51	32	1	26.0	70.0	0.0	3.0	0.1000

TIME AFTER BEGINNING OF EVENT 1.00 HOURS

A TEMPERATURE OF 50.0 WAS ASSIGNED TO JUNCTION NO 1

THE FOLLOWING CONTAMINATION WAS ASSUMED

AIRWAY	CONTAMINATION		HEAT	OXYGEN CONCENTRATION		PRODUCTION PER CU FT OXYGEN	
	FLOWRATE	CONCENTRAT.		BEHIND FIRE	SMOKE	HEAT	
20	0.000	0.000	0.000	0.00	1.000	300.000	

TEMPERATURES AND CONCENTRATIONS AT AIRWAY ENDS, PRESSURES IN AIRWAYS

AIRWAY	FROM	TO	AIRFLOW	TEMPERATURE	SMOKE	METHANE	PRESSURE
1	1	2	162196.	64.98	0.0000	0.00	0.392
2	2	3	66815.	67.28	0.0000	0.00	0.021
3	1	4	98838.	64.34	0.0000	0.00	0.446
4	1	23	33157.	65.26	0.0000	0.00	0.104
5	2	4	10514.	64.30	0.0000	0.00	0.026
6	4	5	18590.	64.57	0.0000	0.38	4.300
7	5	6	18590.	69.84	0.0000	0.63	0.079
8	6	7	1304.	78.37	0.0000	2.43	0.330
9	6	7	17286.	75.87	0.0000	2.44	0.302
10	7	14	18590.	81.82	0.0000	2.59	0.116
11	14	31	61833.	78.21	14.6862	1.12	10.948
12	3	8	66815.	72.34	0.0000	0.08	0.161
13	8	19	17856.	82.46	0.0000	0.62	1.374
14	8	9	48959.	75.01	0.0000	0.16	0.200
15	9	10	42038.	76.56	0.0000	0.18	0.260
16	10	11	7304.	78.63	0.0000	0.54	0.683
17	10	11	34733.	78.60	0.0000	0.44	0.683
18	11	12	42038.	79.40	0.0000	0.49	0.713
19	12	13	42038.	81.99	0.0000	0.49	0.694
20	13	14	43242.	947.49	21.0000	0.49	5.479
21	15	13	1205.	83.87	0.0000	0.56	0.000
22	9	15	6922.	86.12	0.0000	0.56	2.374
23	15	16	5717.	77.97	0.0000	0.56	0.007
24	2	16	18178.	78.47	0.0000	0.59	2.626
25	16	17	23895.	77.87	0.0000	0.58	0.134
26	17	18	40458.	78.76	0.0000	0.58	0.501
27	20	17	16563.	78.18	0.0000	0.57	0.099
28	20	18	34450.	78.35	0.0000	0.57	0.606
29	19	20	51013.	80.92	0.0000	0.57	1.241
30	21	19	33157.	82.52	0.0000	0.54	0.055
31	22	21	30059.	82.54	0.0000	0.54	1.251
32	22	21	3098.	85.97	0.0000	0.54	1.234
33	23	22	16579.	73.17	0.0000	0.72	0.400
34	23	22	16579.	73.17	0.0000	0.12	0.400
35	4	24	90762.	69.56	0.0000	0.15	3.534
36	24	25	34382.	80.51	0.0000	0.87	0.680
37	24	27	56380.	70.49	0.0000	0.58	1.734
38	27	28	84968.	68.47	0.0000	0.58	0.768
39	28	31	27214.	76.35	0.0000	0.58	1.056
40	25	26	34382.	86.41	0.0000	0.92	2.293
41	26	30	29967.	76.94	0.0000	0.92	0.338
42	26	29	4415.	71.74	0.0000	0.92	0.003
43	2	27	28589.	70.42	0.0000	0.59	5.295
44	28	29	57754.	71.54	0.0000	0.58	0.421
45	29	30	62169.	75.56	0.0000	0.61	0.335
46	2	30	38100.	75.65	0.0000	0.00	6.828
47	30	31	205144.	75.69	0.0000	0.53	0.310
48	18	30	74908.	76.81	0.0000	0.57	3.611
50	1	32	17031.	50.00	0.0000	0.00	11.844
49	31	32	294191.	65.60	3.0867	0.66	5.299
51	32	1	311222.	64.85	2.9178	0.62	11.848

TEMPERATURES AND CONCENTRATIONS OF SMOKE AND METHANE IN JUNCTIONS

JUNCTION	TEMPERATURE	SMOKE	METHANE	JUNCTION	TEMPERATURE	SMOKE	METHANE
1	50.00	0.0000	0.0000	2	64.98	0.0000	0.0000
3	67.28	0.0000	0.0000	4	64.34	0.0000	0.0000
5	64.57	0.0000	0.3800	6	69.84	0.0000	0.6326
7	76.04	0.0000	2.4377	8	72.34	0.0000	0.0778
9	75.01	0.0000	0.1551	10	76.56	0.0000	0.1845
11	78.60	0.0000	0.4589	12	79.40	0.0000	0.4883
13	82.04	0.0000	0.4902	14	701.18	14.6862	1.1245
15	86.12	0.0000	0.5573	16	78.35	0.0000	0.5826
17	78.00	0.0000	0.5762	18	78.57	0.0000	0.5720
19	82.50	0.0000	0.5671	20	80.92	0.0000	0.5671
21	82.86	0.0000	0.5412	22	73.17	0.0000	0.4196
23	65.26	0.0000	0.0000	24	69.56	0.0000	0.1464
25	80.51	0.0000	0.8672	26	86.41	0.0000	0.9164
27	70.46	0.0000	0.5844	28	68.47	0.0000	0.5844
29	71.56	0.0000	0.6080	30	76.24	0.0000	0.5270
31	76.28	3.0867	0.6579	32	64.75	2.9178	0.6219

NUMBER OF ITERATIONS 6

IN THE FOLLOWING AIRWAYS EXIST CRITICAL CONDITIONS
(THE STATED NUMBERS REFER TO AIRWAY ENDS)

AIRWAY	FROM	TO	METHANE CONCENTRATION HIGHER THAN 1.0 PERCENT	SMOKE CONCENTRATION HIGHER THAN 0.050 PERCENT	TEMPERATURE HIGHER THAN 95. DEGREES	LOW VENTILAT. PRESSURE LOWER THAN 0.010 INCHES WG
8	6	7	2.43	0.0000	78.4	0.330
9	6	7	2.44	0.0000	75.9	0.302
10	7	14	2.59	0.0000	81.8	0.116
11	14	31	1.12	14.6862	78.2	10.948
20	13	14	0.49	21.0000	947.5	5.479
21	15	13	0.56	0.0000	83.9	0.000
23	15	16	0.56	0.0000	78.0	0.007
42	26	29	0.92	0.0000	71.7	0.003
49	31	32	0.66	3.0867	65.6	5.299
51	32	1	0.62	2.9178	64.8	11.848

JUNCTION	IN THE FOLLOWING JUNCTIONS EXIST CRITICAL CONDITIONS		
	METHANE CONCENTRATION HIGHER THAN 1.0 PERCENT	SMOKE CONCENTRATIONS HIGHER THAN 0.050 PERCENT	TEMPERATURE MORE THAN 95.0 DEGREES
7	2.4	0.0000	76.0
14	1.1	14.6862	701.2
31	0.7	3.0867	76.3
32	0.6	2.9178	64.8

REVERSAL OF AIRFLOW HAS OCCURRED IN THE FOLLOWING PLACES

AIRWAY	20	IS NOW CARRYING AIR FROM	13	TO	14
AIRWAY	21	IS NOW CARRYING AIR FROM	15	TO	13

REAL TIME ANALYSIS

THE FOLLOWING CONTAMINATION HISTORY WAS ASSUMED FOR THE REAL TIME ANALYSIS

AIRWAY	CONTAMINATION		OXYGEN CONCENTRATION BEHIND FIRE	PRODUCTION PER % OXYGEN FUMES	TIME HISTORY OF EVENT	
	FLOWRATE	CONCENTRAT.			START	END
20	0.0	0.0	0.00	1.00	0	10

AT 2 MIN. AFTER THE START OF CONTAMINATION CRITICAL
 FUME CONCENTRATIONS (FUMES > 0.0010 %) NOW EXIST IN THE
 FOLLOWING AIRWAYS

AIRWAY				WAVE			
NUMBER	FROM	TO	LENGTH FT	NUMBER	CONC %	START TIME	LENGTH FT
11	14	31	4500	1	14.6862	1.45	421.9
20	13	14	524	1	21.0000	0.00	524.0

WAVE 1

AIRWAY	CONC %	LOCATION FT	START TIME	ARRIVAL TIME
11	14.6862	421.9	1.45	0.00
20	21.0000	524.0	0.00	1.45

AT 2 MIN. AFTER THE START OF CONTAMINATION CRITICAL
 FUME CONCENTRATIONS (FUMES > 0.001) % NOW EXIST IN THE
 FOLLOWING JUNCTIONS

JUNCTION	CURRENT FUME CONCENTRATION	TIME OF FIRST CONTAMINATION
14	14.6862	1.45

AT 2 MIN. AFTER THE START OF CONTAMINATION THE TOTAL EXPOSURE TO THE CONTAMINANT MEASURED IN PPM*HOURS WAS IN THE FOLLOWING JUNCTIONS

JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE
1	0.00	2	0.00	3	0.00
4	0.00	5	0.00	6	0.00
7	0.00	8	0.00	9	0.00
10	0.00	11	0.00	12	0.00
13	0.00	14	1336.13	15	0.00
16	0.00	17	0.00	18	0.00
19	0.00	20	0.00	21	0.00
22	0.00	23	0.00	24	0.00
25	0.00	26	0.00	27	0.00
28	0.00	29	0.00	30	0.00
31	0.00	32	0.00		

AT 4 MIN. AFTER THE START OF CONTAMINATION CRITICAL FUME CONCENTRATIONS (FUMES > 0.0010 %) NOW EXIST IN THE FOLLOWING AIRWAYS

AIRWAY				WAVE			
NUMBER	FROM	TO	LENGTH FT	NUMBER	CONC %	START TIME	LENGTH FT
11	14	31	4500	1	14.6862	1.45	1967.7
20	13	14	524	1	21.0000	0.00	524.0

WAVE 1

AIRWAY	CONC %	LOCATION FT	START TIME	ARRIVAL TIME
11	14.6862	1967.7	1.45	0.00
20	21.0000	524.0	0.00	1.45

AT 4 MIN. AFTER THE START OF CONTAMINATION CRITICAL FUME CONCENTRATIONS (FUMES > 0.001) % NOW EXIST IN THE FOLLOWING JUNCTIONS

JUNCTION	CURRENT FUME CONCENTRATION	TIME OF FIRST CONTAMINATION
14	14.6862	1.45

AT 4 MIN. AFTER THE START OF CONTAMINATION THE TOTAL EXPOSURE TO THE CONTAMINANT MEASURED IN PPM*HOURS WAS IN THE FOLLOWING JUNCTIONS

JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE
1	0.00	2	0.00	3	0.00
4	0.00	5	0.00	6	0.00
7	0.00	8	0.00	9	0.00
10	0.00	11	0.00	12	0.00
13	0.00	14	6231.53	15	0.00
16	0.00	17	0.00	18	0.00
19	0.00	20	0.00	21	0.00
22	0.00	23	0.00	24	0.00
25	0.00	26	0.00	27	0.00
28	0.00	29	0.00	30	0.00
31	0.00	32	0.00		

AT 6 MIN. AFTER THE START OF CONTAMINATION CRITICAL FUME CONCENTRATIONS (FUMES > 0.0010 %) NOW EXIST IN THE FOLLOWING AIRWAYS

AIRWAY				WAVE			
NUMBER	FROM	TO	LENGTH FT	NUMBER	CONC %	START TIME	LENGTH FT
11	14	31	4500	1	14.6862	1.45	3513.6
20	13	14	524	1	21.0000	0.00	524.0

WAVE 1

AIRWAY	CONC %	LOCATION FT	START TIME	ARRIVAL TIME
11	14.6862	3513.6	1.45	0.00
20	21.0000	524.0	0.00	1.45

AT 6 MIN. AFTER THE START OF CONTAMINATION CRITICAL FUME CONCENTRATIONS (FUMES > 0.001) % NOW EXIST IN THE FOLLOWING JUNCTIONS

JUNCTION	CURRENT FUME CONCENTRATION	TIME OF FIRST CONTAMINATION
14	14.6862	1.45

AT 6 MIN. AFTER THE START OF CONTAMINATION THE TOTAL EXPOSURE TO THE CONTAMINANT MEASURED IN PPM*HOURS WAS IN THE FOLLOWING JUNCTIONS

JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE
1	0.00	2	0.00	3	0.00
4	0.00	5	0.00	6	0.00
7	0.00	8	0.00	9	0.00
10	0.00	11	0.00	12	0.00
13	0.00	14	11126.93	15	0.00
16	0.00	17	0.00	18	0.00
19	0.00	20	0.00	21	0.00
22	0.00	23	0.00	24	0.00
25	0.00	26	0.00	27	0.00
28	0.00	29	0.00	30	0.00
31	0.00	32	0.00		

AT 8 MIN. AFTER THE START OF CONTAMINATION CRITICAL FUME CONCENTRATIONS (FUMES > 0.0010 %) NOW EXIST IN THE FOLLOWING AIRWAYS

AIRWAY				WAVE			
NUMBER	FROM	TO	LENGTH FT	NUMBER	CONC %	START TIME	LENGTH FT
11	14	31	4500	1	14.6862	1.45	4500.0
20	13	14	524	1	21.0000	0.00	524.0
49	31	32	2031	1	3.0867	7.28	1064.6

WAVE 1

AIRWAY	CONC %	LOCATION FT	START TIME	ARRIVAL TIME
11	14.6862	4500.0	1.45	7.28
20	21.0000	524.0	0.00	1.45
49	3.0867	1064.6	7.28	0.00

AT 8 MIN. AFTER THE START OF CONTAMINATION CRITICAL FUME CONCENTRATIONS (FUMES > 0.001) % NOW EXIST IN THE FOLLOWING JUNCTIONS

JUNCTION	CURRENT FUME CONCENTRATION	TIME OF FIRST CONTAMINATION
14	14.6862	1.45
31	3.0867	7.28

AT 8 MIN. AFTER THE START OF CONTAMINATION THE TOTAL EXPOSURE TO
THE CONTAMINANT MEASURED IN PPM*HOURS WAS IN THE FOLLOWING JUNCTIONS

JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE
1	0.00	2	0.00	3	0.00
4	0.00	5	0.00	6	0.00
7	0.00	8	0.00	9	0.00
10	0.00	11	0.00	12	0.00
13	0.00	14	16022.34	15	0.00
16	0.00	17	0.00	18	0.00
19	0.00	20	0.00	21	0.00
22	0.00	23	0.00	24	0.00
25	0.00	26	0.00	27	0.00
28	0.00	29	0.00	30	0.00
31	372.32	32	0.00		

AT 10 MIN. AFTER THE START OF CONTAMINATION CRITICAL
FUME CONCENTRATIONS (FUMES > 0.0010 %) NOW EXIST IN THE
FOLLOWING AIRWAYS

AIRWAY				WAVE			
NUMBER	FROM	TO	LENGTH FT	NUMBER	CONC %	START TIME	LENGTH FT
11	14	31	4500	1	14.6862	1.45	4500.0
20	13	14	524	1	21.0000	0.00	524.0
49	31	32	2031	1	3.0867	7.28	2031.0
51	32	1	100	1	2.9178	8.66	100.0

WAVE 1

AIRWAY	CONC %	LOCATION FT	START TIME	ARRIVAL TIME
11	14.6862	4500.0	1.45	7.28
20	21.0000	524.0	0.00	1.45
49	3.0867	2031.0	7.28	8.66
51	2.9178	100.0	8.66	8.68

AT 10 MIN. AFTER THE START OF CONTAMINATION CRITICAL
FUME CONCENTRATIONS (FUMES > 0.001) % NOW EXIST IN THE
FOLLOWING JUNCTIONS

JUNCTION	CURRENT FUME CONCENTRATION	TIME OF FIRST CONTAMINATION
14	14.6862	1.45
31	3.0867	7.28
32	2.9178	8.66

AT 10 MIN. AFTER THE START OF CONTAMINATION THE TOTAL EXPOSURE TO
THE CONTAMINANT MEASURED IN PPM*HOURS WAS IN THE FOLLOWING JUNCTIONS

JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE
1	0.00	2	0.00	3	0.00
4	0.00	5	0.00	6	0.00
7	0.00	8	0.00	9	0.00
10	0.00	11	0.00	12	0.00
13	0.00	14	20917.74	15	0.00
16	0.00	17	0.00	18	0.00
19	0.00	20	0.00	21	0.00
22	0.00	23	0.00	24	0.00
25	0.00	26	0.00	27	0.00
28	0.00	29	0.00	30	0.00
31	1401.23	32	653.10		

END OF RUN

APPENDIX D.--INPUT DATA FOR FUEL-RICH FIRE IN A DOWNCAST SHAFT
CALCULATION WITH FAN FAILURE

NETWORK CONTROL CARD											DR	TR	IRTCC
NB	NJ	NFUM	NADBC	NVPN	NETW	NCONC	NTEMP	MADJ	ITN				
51	32	1	3	1	1	1	1	10	30	075	70.00	1	
AIRWAY CARDS													
NO	JS	JF	NWTYP	R	Q	KF	LA	A	D				
1	1	2	0	0.156	200000	250	2597	200.0	50.0				
2	2	3	0	0.048	60000	250	325	200.0	50.0				
3	1	4	0	0.479	100000	250	2577	200.0	50.0				
4	1	23	0	0.995	30000	250	2580	200.0	50.0				
5	2	4	0	2.400	35000	100	2900	80.0	35.0				
6	4	5	1	4.000	60000	100	100	80.0	35.0				
7	5	6	0	2.307	60000	100	2700	80.0	35.0				
8	6	7	0	1888.233	5000	350	524	120.0	44.0				
9	6	7	0	9.923	60000	100	1700	80.0	35.0				
10	7	14	0	3.239	70000	100	1650	80.0	35.0				
11	14	31	0	20.002	70000	100	4500	80.0	35.0				
12	3	8	0	0.360	53600	100	2700	80.0	35.0				
13	8	19	0	41.490	20000	100	2050	80.0	35.0				
14	8	9	0	0.821	50000	100	600	80.0	35.0				
15	9	10	0	1.437	35000	100	600	80.0	35.0				
16	10	11	0	124.385	6000	100	600	80.0	30.0				
17	10	11	0	5.500	30000	100	1100	80.0	35.0				
18	11	12	0	3.900	35000	350	319	120.0	44.0				
19	12	13	0	3.772	35000	100	600	80.0	35.0				
20	14	13	0	4.000	6000	350	524	120.0	44.0				
21	13	15	0	1.108	35000	100	550	80.0	35.0				
22	9	15	0	474.065	6000	350	318	120.0	44.0				
23	15	16	0	2.047	30000	100	600	80.0	35.0				
24	2	16	0	77.702	14800	100	2600	80.0	35.0				
25	16	17	0	2.285	60000	100	1050	80.0	35.0				
26	17	18	0	2.966	60000	350	228	120.0	44.0				
27	20	17	0	3.500	2000	100	800	80.0	35.0				
28	20	18	0	4.931	50000	100	1217	80.0	35.0				
29	19	20	0	4.565	50000	350	333	120.0	44.0				
30	21	19	0	0.475	31300	100	1100	80.0	35.0				
31	22	21	0	13.375	40000	100	1313	80.0	35.0				
32	22	21	0	1234.019	3000	350	313	120.0	44.0				
33	23	22	0	14.500	20000	100	1800	80.0	35.0				
34	23	22	0	14.500	20000	100	1800	80.0	35.0				
35	4	24	0	4.324	110000	100	2400	80.0	35.0				
36	24	25	0	5.572	45000	100	2600	80.0	35.0				
37	24	27	0	5.450	20000	100	3200	80.0	35.0				
38	27	28	0	1.066	100000	350	230	120.0	44.0				
39	28	31	0	14.000	40000	100	2292	80.0	35.0				
40	25	26	0	18.360	45000	100	2000	80.0	35.0				
41	26	30	0	3.630	38000	100	1700	80.0	35.0				
42	26	29	0	1.385	5000	100	1050	80.0	35.0				
43	2	27	0	65.065	35449	100	1650	80.0	35.0				
44	28	29	0	1.260	73000	100	750	80.0	35.0				
45	29	30	0	0.854	80000								
46	2	30	0	46.882	44000	100	525	80.0	35.0				
47	30	31	0	0.072	203000								
48	18	30	0	6.265	100000	100	4100	80.0	35.0				
50	1	32	0	441.000	20000	250	30	200.0	50.0				
49	31	32	0	0.610	288350								
51	32	1	0	10.000	450000	100	100	80.0	35.0				

JUNCTION CARDS

JND	T	Z	CH4
1	50.0	114	
2	65.06	-2465	
3	67.32	-2790	
4	64.39	-2463	
5	64.51	-2462	0.12
6	69.88	-2462	0.20
7	75.60	-1938	0.80
8	72.54	-2787	0.12
9	75.67	-2785	0.25
10	77.09	-2785	0.30
11	78.82	-2787	0.90
12	79.31	-2468	0.95
13	82.42	-2465	0.90
14	81.62	-1942	0.85
15	83.25	-2467	0.90
16	78.56	-2466	0.90
17	77.92	-2463	
18	78.39	-2235	
19	82.54	-2785	0.8
20	80.90	-2452	
21	82.87	-2786	0.85
22	73.28	-2473	0.70
23	65.27	-2466	
24	69.95	-2462	0.15
25	80.65	-2245	0.90
26	86.57	-2247	0.95
27	70.59	-2465	
28	68.59	-2235	
29	72.08	-2239	
30	76.80	-2240	
31	76.44	-1943	
32	65.70	88	

FAN CHARACTERISTIC CARDS

NDF MPTS

6 10

GF	PF	GF	PF	GF	PF	GF	PF	GF	PF
20000	3.60	25000	4.30	30000	4.60	40000	4.78	55000	4.58
70000	4.29	85000	3.96	100000	3.70	150000	3.00	200000	2.52

ADDITIONAL AIRWAY CARDS

ND	KF	LA	A	O
45	100	300	80.0	35.0
47	250	297	200.0	50.0
49	250	2031	200.0	50.0

CONCENTRATION CONTROL CARD

NDIM	NCH4C	NAV	MAXJ	INFLOW	JSTART	TSTART	TIME	CRITSM	CRITGS	CRITHT	WRNPR	WRNSM
6	2	1	32	1	1	50.00	1.00	.005	0.10	.20	.01	.05
											1.0	95.

AVERAGE VALUE CARD

TAVR	HAAVR	HKAVR	KFAVR	LA AVR	AAVR	DAVR
70.0	0.10	3.0	100	1000	100.0	100.0

ADDITIONAL CONCENTRATION AIRWAY CARDS

NOX	CH4VX	DZRDx
9	320.0	
17	90.0	
33	120.0	
34	20.0	
36	250.0	
50		50.00

ADDITIONAL CONCENTRATION JUNCTION CARDS

JNDX	CH4CX
27	0.60
28	0.60

CONTAMINATION CARD

NCENT	SMPO2	HTPO2
20	1.00	300.00

REAL TIME CONTROL CARD

NACC	IDUR	INC	EXP	REP	WRNSM	JSURF	CRITSM
1	360	60	2.00	2.00	0.001		1.001

CONTAMINATION CARD

NCENT	SMPO2	HTPO2	ISTT	IENDT
20	1.00	300.00	0	360

APPENDIX E.--OUTPUT DATA FOR FUEL-RICH FIRE IN A DOWNCAST SHAFT
CALCULATION WITH FAN FAILURE

ORDINARY AIRFLOW AND PRESSURE DISTRIBUTION BEFORE EVENT (BASED ON THE LISTED INPUT DATA)

REGULAR AIRWAYS

AIRWAY	FROM	TO	AIRFLOW	PRESSURE LOSS	LENGTH	AREA	RESISTANCE	K	PERIMETER
1	1	2	3709.	0.000	2597	200.000	0.156	250	50.000
2	2	3	-7929.	0.000	325	200.000	0.048	250	50.000
3	1	4	35910.	0.062	2577	200.000	0.479	250	50.000
4	1	23	-5216.	-0.003	2580	200.000	0.995	250	50.000
5	2	4	12405.	0.037	2900	80.000	2.400	100	35.000
7	5	6	51860.	0.620	2700	80.000	2.307	100	35.000
8	6	7	3505.	2.320	524	120.000	1888.233	350	44.000
9	6	7	48355.	2.320	1700	80.000	9.923	100	35.000
10	7	14	51860.	0.871	1650	80.000	3.239	100	35.000
11	14	31	20109.	0.809	4500	80.000	20.002	100	35.000
12	3	8	-7929.	-0.002	2700	80.000	0.360	100	35.000
13	8	19	4077.	0.069	2050	80.000	41.490	100	35.000
14	8	9	-12006.	-0.012	600	80.000	0.821	100	35.000
15	9	10	-10616.	-0.016	600	80.000	1.437	100	35.000
16	10	11	-1840.	-0.042	600	80.000	124.385	100	30.000
17	10	11	-8776.	-0.042	1100	80.000	5.500	100	35.000
18	11	12	-10616.	-0.044	319	120.000	3.900	350	44.000
19	12	13	-10616.	-0.043	600	80.000	3.772	100	35.000
20	14	13	31751.	0.403	524	120.000	4.000	350	44.000
21	13	15	21135.	0.049	550	80.000	1.108	100	35.000
22	9	15	-1390.	-0.092	318	120.000	474.065	350	44.000
23	15	16	19745.	0.080	600	80.000	2.047	100	35.000
24	2	16	-4256.	-0.141	2600	80.000	77.702	100	35.000
25	16	17	15489.	0.055	1050	80.000	2.285	100	35.000
26	17	18	8744.	0.023	228	120.000	2.966	350	44.000
27	20	17	-6745.	-0.016	800	80.000	3.500	100	35.000
28	20	18	5606.	0.015	1217	80.000	4.931	100	35.000
29	19	20	-1139.	-0.001	333	120.000	4.565	350	44.000
30	21	19	-5216.	-0.001	1100	80.000	0.475	100	35.000
31	22	21	-4722.	-0.030	1313	80.000	13.375	100	35.000
32	22	21	-494.	-0.030	313	120.000	1234.019	350	44.000
33	23	22	-2608.	-0.010	1800	80.000	14.500	100	35.000
34	23	22	-2608.	-0.010	1800	80.000	14.500	100	35.000
35	4	24	-3545.	-0.005	2400	80.000	4.324	100	35.000
36	24	25	2386.	0.003	2600	80.000	5.572	100	35.000
37	24	27	-5931.	-0.019	3200	80.000	5.450	100	35.000
38	27	28	-4518.	-0.002	230	120.000	1.066	350	44.000
39	28	31	-4689.	-0.031	2292	80.000	14.000	100	35.000
40	25	26	2386.	0.010	2000	80.000	18.360	100	35.000
41	26	30	1305.	0.001	1700	80.000	3.630	100	35.000
42	26	29	1081.	0.000	1050	80.000	1.385	100	35.000
43	2	27	1413.	0.013	1650	80.000	65.065	100	35.000
44	28	29	171.	0.000	750	80.000	1.260	100	35.000
45	29	30	1252.	0.000	300	80.000	0.854	100	35.000
46	2	30	2073.	0.020	525	80.000	46.882	100	35.000
47	30	31	18982.	0.003	297	200.000	0.072	250	50.000
48	18	30	14350.	0.129	4100	80.000	6.265	100	35.000
50	1	32	-4502.	-0.894	30	200.000	441.000	250	50.000
49	31	32	34402.	0.072	2031	200.000	0.610	250	50.000
51	32	1	29900.	0.894	100	80.000	10.000	100	35.000

FANS

AIRWAY	FROM	TO	AIRFLOW	FAN PRESSURE
6	4	5	51860.	4.658

THESE CHARACTERISTICS WERE STORED FOR FANS 6

20000.	3.60	25000.	4.30	30000.	4.60	40000.	4.78	55000.	4.58
70000.	4.29	85000.	3.96	100000.	3.70	150000.	3.00	200000.	2.52

THE STATED NUMBER OF AIRWAYS WAS 51 THE STATED NUMBER OF JUNCTIONS WAS 32

INPUT DATA FOR CONCENTRATION AND TEMPERATURE CALCULATIONS

AIRWAY	FROM	TO	ELEVATION DIFF.	ROCK TEMP.	METHANE PROD.	CONDUCTIVITY	DIFFUSIVITY
1	1	2	-2579.0	58.1	0.0	3.0	0.1000
2	2	3	-325.0	67.2	0.0	3.0	0.1000
3	1	4	-2577.0	57.4	0.0	3.0	0.1000
4	1	23	-2580.0	58.3	0.0	3.0	0.1000
5	2	4	2.0	64.3	0.0	3.0	0.1000
6	4	5	1.0	65.6	62.2	3.0	0.1000
7	5	6	0.0	69.9	41.5	3.0	0.1000
8	6	7	524.0	79.9	21.0	3.0	0.1000
9	6	7	524.0	77.5	320.0	3.0	0.1000
10	7	14	-4.0	82.0	25.9	3.0	0.1000
11	14	31	-1.0	76.4	0.0	3.0	0.1000
12	3	8	3.0	72.5	-9.5	3.0	0.1000
13	8	19	2.0	82.5	27.7	3.0	0.1000
14	8	9	2.0	76.7	-15.6	3.0	0.1000
15	9	10	0.0	77.5	-5.3	3.0	0.1000
16	10	11	-2.0	79.2	-11.0	3.0	0.1000
17	10	11	-2.0	78.9	90.0	3.0	0.1000
18	11	12	319.0	82.5	-5.3	3.0	0.1000
19	12	13	3.0	83.5	0.0	3.0	0.1000
20	14	13	-523.0	79.6	15.9	3.0	0.1000
21	13	15	-2.0	83.6	0.0	3.0	0.1000
22	9	15	318.0	89.5	-9.0	3.0	0.1000
23	15	16	1.0	76.5	0.0	3.0	0.1000
24	2	16	-1.0	78.5	-38.3	3.0	0.1000
25	16	17	3.0	77.8	0.0	3.0	0.1000
26	17	18	228.0	81.4	0.0	3.0	0.1000
27	20	17	-11.0	77.4	0.0	3.0	0.1000
28	20	18	217.0	78.8	0.0	3.0	0.1000
29	19	20	333.0	81.9	0.0	3.0	0.1000
30	21	19	1.0	82.5	0.0	3.0	0.1000
31	22	21	-313.0	82.2	-7.1	3.0	0.1000
32	22	21	-313.0	85.3	-0.7	3.0	0.1000
33	23	22	-7.0	73.2	120.0	3.0	0.1000
34	23	22	-7.0	73.2	20.0	3.0	0.1000
35	4	24	1.0	69.9	-5.3	3.0	0.1000
36	24	25	217.0	81.2	250.0	3.0	0.1000
37	24	27	-3.0	70.5	-26.7	3.0	0.1000
38	27	28	230.0	68.1	0.0	3.0	0.1000
39	28	31	292.0	77.2	0.0	3.0	0.1000
40	25	26	-2.0	86.5	1.2	3.0	0.1000
41	26	30	7.0	76.8	0.0	3.0	0.1000
42	26	29	8.0	71.7	0.0	3.0	0.1000
43	2	27	0.0	70.5	8.5	3.0	0.1000
44	28	29	-4.0	72.1	0.0	3.0	0.1000
45	29	30	-1.0	79.3	0.0	3.0	0.1000
46	2	30	225.0	80.4	0.0	3.0	0.1000
47	30	31	297.0	79.5	0.0	3.0	0.1000
48	18	30	-5.0	76.8	0.0	3.0	0.1000
50	1	32	0.0	50.0	0.0	3.0	0.1000
49	31	32	2031.0	71.1	0.0	3.0	0.1000
51	32	1	26.0	70.0	0.0	3.0	0.1000

TIME AFTER BEGINNING OF EVENT 1.00 HOURS

A TEMPERATURE OF 50.0 WAS ASSIGNED TO JUNCTION NO 1

THE FOLLOWING CONTAMINATION WAS ASSUMED

AIRWAY	CONTAMINATION FLOWRATE	CONCENTRAT.	HEAT	OXYGEN CONCENTRATION BEHIND FIRE	PRODUCTION PER CU FT OXYGEN SMOKE	HEAT
20	0.000	0.000	0.000	0.00	1.000	300.000

TEMPERATURES AND CONCENTRATIONS AT AIRWAY ENDS, PRESSURES IN AIRWAYS

AIRWAY	FROM	TO	AIRFLOW	TEMPERATURE	SMOKE	METHANE	PRESSURE
1	1	2	47403.	65.01	0.0000	0.00	0.033
2	2	3	33371.	67.24	1.7453	0.13	0.005
3	4	1	26392.	50.58	21.0000	1.56	0.032
4	1	23	9466.	65.25	0.0000	0.00	0.009
5	4	-2	4297.	64.31	21.0000	1.56	0.004
6	5	4	46504.	69.60	21.0000	1.56	4.739
7	6	5	46504.	70.20	21.0000	1.43	0.906
8	7	6	3161.	86.02	21.0000	1.28	2.151
9	7	6	43343.	85.67	21.0000	1.35	2.134
10	14	7	46504.	159.11	21.0000	0.62	1.640
11	14	31	8097.	76.40	21.0000	0.56	0.170
12	3	8	33371.	72.44	1.7453	0.10	0.040
13	8	19	7011.	82.49	1.7453	0.49	0.212
14	8	9	26360.	75.23	1.7453	0.04	0.058
15	9	10	22869.	76.74	1.7453	0.02	0.077
16	10	11	3973.	78.70	1.7453	-0.26	0.202
17	10	11	18896.	78.70	1.7453	0.49	0.202
18	11	12	22869.	79.61	1.7453	0.34	0.211
19	12	13	22869.	82.20	1.7453	0.34	0.206
20	13	14	54601.	984.32	21.0000	0.56	8.418
21	15	13	31732.	81.36	2.8587	0.68	0.116
22	9	15	3491.	85.71	1.7453	-0.22	0.604
23	16	15	28241.	77.11	2.9963	0.79	0.168
24	2	16	7071.	78.50	1.7453	-0.42	0.398
25	17	16	21170.	78.03	3.4142	1.19	0.106
26	18	-17	10002.	80.62	6.3972	1.42	0.031
27	20	17	11168.	77.96	0.7426	0.99	0.049
28	20	18	5309.	78.28	0.7426	0.99	0.014
29	19	20	16477.	80.89	0.7426	0.99	0.129
30	21	19	9466.	82.51	0.0000	1.37	0.004
31	22	21	8622.	82.75	0.0000	1.37	0.103
32	22	21	845.	85.23	0.0000	1.36	0.092
33	23	22	4733.	73.20	0.0000	2.47	0.033
34	23	22	4733.	73.20	0.0000	0.42	0.033
35	4	24	15815.	69.90	21.0000	1.53	0.108
36	24	25	7193.	80.59	21.0000	4.84	0.030
37	24	27	8622.	70.50	21.0000	1.22	0.041
38	27	28	13343.	68.33	14.1881	0.90	0.019
39	28	31	3854.	76.41	14.1881	0.90	0.021
40	25	26	7193.	86.48	21.0000	4.85	0.101
41	26	30	5976.	76.85	21.0000	4.85	0.012
42	26	29	1617.	71.93	21.0000	4.85	0.000
43	2	27	4720.	70.48	1.7453	0.31	0.145
44	28	29	9488.	71.49	14.1881	0.90	0.011
45	29	30	11105.	75.53	15.1797	1.47	0.011
46	2	30	6537.	76.02	1.7453	0.13	0.202
47	30	31	18526.	76.25	12.7951	1.91	0.003
48	30	18	4693.	76.77	12.7951	1.91	0.014
50	32	1	4002.	64.32	15.1512	1.42	0.693
49	31	32	30478.	65.68	15.1512	1.42	0.097
51	32	1	26476.	66.26	15.1512	1.42	0.690

TEMPERATURES AND CONCENTRATIONS OF SMOKE AND METHANE IN JUNCTIONS

JUNCTION	TEMPERATURE	SMOKE	METHANE	JUNCTION	TEMPERATURE	SMOKE	METHANE
1	50.00	0.0000	0.0000	2	64.95	1.7453	0.1278
3	67.24	1.7453	0.1278	4	69.60	21.0000	1.5624
5	70.20	21.0000	1.4307	6	85.69	21.0000	1.3427
7	159.11	21.0000	0.6192	8	72.44	1.7453	0.0993
9	75.23	1.7453	0.0401	10	76.74	1.7453	0.0169
11	78.70	1.7453	0.3601	12	79.61	1.7453	0.3370
13	81.71	2.3924	0.5349	14	984.32	21.0000	0.5638
15	78.06	2.8587	0.6775	16	78.15	2.9963	0.7884
17	79.22	3.4142	1.1907	18	77.57	6.3972	1.4222
19	82.51	0.7426	0.9940	20	80.89	0.7426	0.9940
21	82.97	0.0000	1.3652	22	73.20	0.0000	1.4467
23	65.25	0.0000	0.0000	24	69.90	21.0000	1.5293
25	80.59	21.0000	4.8368	26	86.48	21.0000	4.8525
27	70.49	14.1881	0.8992	28	68.33	14.1881	0.8992
29	71.56	15.1797	1.4747	30	75.98	12.7951	1.9068
31	76.31	15.1512	1.4225	32	65.68	15.1512	1.4225

NUMBER OF ITERATIONS 8
 WITH AIRWAY NO 5 INTO JUNCTION NO 2
 WITH AIRWAY NO 26 INTO JUNCTION NO 17

A RECIRCULATION PATH IS BEING CLOSED

IN THE FOLLOWING AIRWAYS EXIST CRITICAL CONDITIONS
(THE STATED NUMBERS REFER TO AIRWAY ENDS)

AIRWAY	FROM	TO	METHANE CONCENTRATION HIGHER THAN 1.0 PERCENT	SMOKE CONCENTRATION HIGHER THAN 0.050 PERCENT	TEMPERATURE HIGHER THAN 95. DEGREES	LOW VENTILAT. PRESSURE LOWER THAN 0.010 INCHES WG
2	2	3	0.13	1.7453	67.2	0.005
3	4	1	1.56	21.0000	50.6	0.032
4	1	23	0.00	0.0000	65.2	0.009
5	4	2	1.56	21.0000	64.3	0.004
6	5	4	1.56	21.0000	69.6	4.739
7	6	5	1.43	21.0000	70.2	0.506
8	7	6	1.28	21.0000	86.0	2.151
9	7	6	1.35	21.0000	85.7	2.134
10	14	7	0.62	21.0000	159.1	1.640
11	14	31	0.56	21.0000	76.4	0.170
12	3	8	0.10	1.7453	72.4	0.040
13	8	19	0.49	1.7453	82.5	0.212
14	8	9	0.04	1.7453	75.2	0.058
15	9	10	0.02	1.7453	76.7	0.077
16	10	11	-0.26	1.7453	78.7	0.202
17	10	11	0.49	1.7453	78.7	0.202
18	11	12	0.34	1.7453	79.6	0.211
19	12	13	0.34	1.7453	82.2	0.206
20	13	14	0.56	21.0000	984.3	8.418
21	15	13	0.68	2.8587	81.4	0.116
22	9	15	-0.22	1.7453	85.7	0.604
23	16	15	0.79	2.9963	77.1	0.168
24	2	16	-0.42	1.7453	78.5	0.398
25	17	16	1.19	3.4142	78.0	0.106
26	18	17	1.42	6.3972	80.6	0.031
27	20	17	0.99	0.7426	78.0	0.045
28	20	18	0.99	0.7426	78.3	0.014
29	19	20	0.99	0.7426	80.9	0.129
30	21	19	1.37	0.0000	82.5	0.004
31	22	21	1.37	0.0000	82.8	0.103
32	22	21	1.36	0.0000	85.2	0.092
33	23	22	2.47	0.0000	73.2	0.033
35	4	24	1.53	21.0000	69.9	0.108
36	24	25	4.84	21.0000	80.6	0.030
37	24	27	1.22	21.0000	70.5	0.041
38	27	28	0.90	14.1881	68.3	0.019
39	28	31	0.90	14.1881	76.4	0.021
40	25	26	4.85	21.0000	86.5	0.101
41	26	30	4.85	21.0000	76.8	0.012
42	26	29	4.85	21.0000	71.9	0.000
43	2	27	0.31	1.7453	70.5	0.145
44	28	29	0.90	14.1881	71.5	0.011
45	29	30	1.47	15.1797	75.5	0.011
46	2	30	0.13	1.7453	76.0	0.202
47	30	31	1.91	12.7951	76.2	0.003
48	30	18	1.91	12.7951	76.8	0.014
50	32	1	1.42	15.1512	64.3	0.693
49	31	32	1.42	15.1512	65.7	0.057
51	32	1	1.42	15.1512	66.3	0.690

JUNCTION	IN THE FOLLOWING JUNCTIONS EXIST CRITICAL CONDITIONS		
	METHANE CONCENTRATION HIGHER THAN 1.0 PERCENT	SMOKE CONCENTRATIONS HIGHER THAN 0.050 PERCENT	TEMPERATURE MORE THAN 95.0 DEGREES
2	0.1	1.7453	65.0
3	0.1	1.7453	67.2
4	1.6	21.0000	69.6
5	1.4	21.0000	70.2
6	1.3	21.0000	85.7
7	0.6	21.0000	159.1
8	0.1	1.7453	72.4
9	0.0	1.7453	75.2
10	0.0	1.7453	76.7
11	0.4	1.7453	78.7
12	0.3	1.7453	79.6
13	0.5	2.3924	81.7
14	0.6	21.0000	984.3
15	0.7	2.8587	78.1
16	0.8	2.9963	78.1
17	1.2	3.4142	79.2
18	1.4	6.3972	77.6
19	1.0	0.7426	82.5
20	1.0	0.7426	80.9
21	1.4	0.0000	83.0
22	1.4	0.0000	73.2
24	1.5	21.0000	69.9
25	4.8	21.0000	80.6
26	4.9	21.0000	86.5
27	0.9	14.1881	70.5
28	0.9	14.1881	68.3
29	1.5	15.1797	71.6
30	1.9	12.7951	76.0
31	1.4	15.1512	76.3
32	1.4	15.1512	65.7

REVERSAL OF AIRFLOW HAS OCCURRED IN THE FOLLOWING PLACES

AIRWAY	3	IS NOW CARRYING AIR FROM	4	TO	1
AIRWAY	5	IS NOW CARRYING AIR FROM	4	TO	2
AIRWAY	6	IS NOW CARRYING AIR FROM	5	TO	4
AIRWAY	7	IS NOW CARRYING AIR FROM	6	TO	5
AIRWAY	8	IS NOW CARRYING AIR FROM	7	TO	6
AIRWAY	9	IS NOW CARRYING AIR FROM	7	TO	6
AIRWAY	10	IS NOW CARRYING AIR FROM	14	TO	7
AIRWAY	20	IS NOW CARRYING AIR FROM	13	TO	14
AIRWAY	21	IS NOW CARRYING AIR FROM	15	TO	13
AIRWAY	23	IS NOW CARRYING AIR FROM	16	TO	15
AIRWAY	25	IS NOW CARRYING AIR FROM	17	TO	16
AIRWAY	26	IS NOW CARRYING AIR FROM	18	TO	17
AIRWAY	48	IS NOW CARRYING AIR FROM	30	TO	18
AIRWAY	50	IS NOW CARRYING AIR FROM	32	TO	1

REAL TIME ANALYSIS

THE FOLLOWING CONTAMINATION HISTORY WAS ASSUMED FOR THE REAL TIME ANALYSIS

AIRWAY	CONTAMINATION FLOWRATE	CONCENTRATION	OXYGENCONCENTRATION BEHIND FIRE	PRODUCTION PER % OXYGEN FUMES	TIME HISTORY START	TIME HISTORY END
20	0.0	0.0	0.00	1.00	0	360

AT 60 MIN. AFTER THE START OF CONTAMINATION CRITICAL FUME CONCENTRATIONS (FUMES > 0.0010 %) NOW EXIST IN THE FOLLOWING AIRWAYS

AIRWAY				WAVE			
NUMBER	FROM	TO	LENGTH FT	NUMBER	CONC %	START TIME	LENGTH FT
3	4	1	2577	2	21.0000	28.70	2577.0
5	4	2	2900	2	21.0000	28.70	1681.1
6	5	4	100	2	21.0000	28.53	100.0
7	6	5	2700	2	21.0000	23.88	2700.0
8	7	6	524	1	21.0000	3.99	524.0
9	7	6	1700	1	21.0000	3.99	1700.0
10	14	7	1650	1	21.0000	1.15	1650.0
11	14	31	4500	1	21.0000	1.15	4500.0
20	13	14	524	1	21.0000	0.00	524.0
35	4	24	2400	2	21.0000	28.70	2400.0
36	24	25	2600	2	21.0000	40.84	1722.8
37	24	27	3200	2	21.0000	40.84	2065.1
38	27	28	230	1	12.6482	53.78	230.0
39	28	31	2292	1	12.6482	55.84	200.3
40	25	26	2000	1	19.5726	53.00	629.3
44	28	29	750	1	12.6482	55.84	493.0
50	32	1	30	1	5.5793	58.94	21.3
49	31	32	2031	1	5.5793	45.61	2031.0
51	32	1	100	1	5.5793	58.94	100.0

WAVE 1					WAVE 2				
AIRWAY	CONC %	LOCATION FT	START TIME	ARRIVAL TIME	CONC %	LOCATION FT	START TIME	ARRIVAL TIME	
3	19.5726	2577.0	11.94	31.47	21.0000	2577.0	28.70	48.23	
5	19.5726	2981.0	11.94	0.00	21.0000	1681.1	28.70	0.00	
6	19.5726	100.0	11.77	11.94	21.0000	100.0	28.53	28.70	
7	19.5726	2700.0	7.13	11.77	21.0000	2700.0	23.88	28.53	
8	21.0000	524.0	3.99	23.88					
9	21.0000	1700.0	3.99	7.13					
10	21.0000	1650.0	1.15	3.99					
11	21.0000	4500.0	1.15	45.61					
20	21.0000	524.0	0.00	1.15					
35	19.5726	2400.0	11.94	24.08	21.0000	2400.0	28.70	40.84	
36	19.5726	2600.0	24.08	53.00	21.0000	1722.8	40.84	0.00	
37	19.5726	3200.0	24.08	53.78	21.0000	2065.1	40.84	0.00	
38	12.6482	230.0	53.78	55.84					
39	12.6482	200.3	55.84	0.00					
40	19.5726	629.3	53.00	0.00					
44	12.6482	493.0	55.84	0.00					
50	5.5793	21.3	58.94	0.00					
49	5.5793	2031.0	45.61	58.94					
51	5.5793	100.0	58.94	59.24					

AT 60 MIN. AFTER THE START OF CONTAMINATION CRITICAL FUME CONCENTRATIONS (FUMES > 0.001) % NOW EXIST IN THE FOLLOWING JUNCTIONS

JUNCTION	CURRENT FUME CONCENTRATION	TIME OF FIRST CONTAMINATION
4	21.0000	28.70
5	21.0000	28.53
6	21.0000	23.88
7	21.0000	3.99
14	21.0000	1.15
24	21.0000	40.84
25	19.5726	53.00
27	12.6482	53.78
28	12.6482	55.84
31	5.5793	45.61
32	5.5793	58.94

AT 60 MIN. AFTER THE START OF CONTAMINATION THE TOTAL EXPOSURE TO THE CONTAMINANT MEASURED IN PPM*HOURS WAS IN THE FOLLOWING JUNCTIONS

JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE
1	0.00	2	0.00	3	0.00
4	164207.64	5	164809.73	6	181066.45
7	196034.67	8	0.00	9	0.00
10	0.00	11	0.00	12	0.00
13	0.00	14	205969.33	15	0.00
16	0.00	17	0.00	18	0.00
19	0.00	20	0.00	21	0.00
22	0.00	23	0.00	24	121717.37
25	22829.84	26	0.00	27	13122.41
28	8761.85	29	0.00	30	0.00
31	13381.06	32	987.75		

AT 120 MIN. AFTER THE START OF CONTAMINATION CRITICAL
 FUME CONCENTRATIONS (FUMES > 0.0010 %) NOW EXIST IN THE
 FOLLOWING AIRWAYS

AIRWAY				WAVE			
NUMBER	FROM	TO	LENGTH FT	NUMBER	CONC %	START TIME	LENGTH FT
2	2	3	325	2	1.7453	82.69	325.0
3	4	1	2577	2	21.0000	28.70	2577.0
5	4	2	2900	2	21.0000	28.70	2900.0
6	5	4	100	2	21.0000	28.53	100.0
7	6	5	2700	2	21.0000	23.88	2700.0
8	7	6	524	1	21.0000	3.99	524.0
9	7	6	1700	1	21.0000	3.99	1700.0
10	14	7	1650	1	21.0000	1.15	1650.0
11	14	31	4500	1	21.0000	1.15	4500.0
12	3	8	2700	2	1.7453	84.64	2700.0
13	8	19	2050	2	1.7453	91.11	2050.0
14	8	9	600	2	1.7453	91.11	600.0
15	9	10	600	2	1.7453	92.93	600.0
16	10	11	600	2	1.7453	95.03	600.0
17	10	11	1100	2	1.7453	95.03	1100.0
18	11	12	319	4	1.7453	107.11	319.0
19	12	13	600	4	1.7453	108.79	600.0
20	13	14	524	1	21.0000	0.00	524.0
21	15	13	550	5	0.8245	113.81	550.0
22	9	15	318	2	1.7453	92.93	318.0
23	16	15	600	3	0.7107	112.11	600.0
24	2	16	2600	2	1.7453	82.69	2600.0
25	17	16	1050	1	0.3651	105.91	1050.0
26	18	17	228	1	0.3674	118.51	124.0
27	20	17	800	2	0.7426	116.93	428.6
28	20	18	1217	2	0.7426	116.93	203.8
29	19	20	333	2	0.7426	114.50	333.0
35	4	24	2400	2	21.0000	28.70	2400.0
36	24	25	2600	2	21.0000	40.84	2600.0
37	24	27	3200	2	21.0000	40.84	3200.0
38	27	28	230	4	14.1881	110.66	230.0
39	28	31	2292	4	14.1881	112.73	350.5
40	25	26	2000	2	21.0000	69.76	2000.0
41	26	30	1700	2	21.0000	92.00	1700.0
42	26	29	1050	2	21.0000	92.00	565.8
43	2	27	1650	2	1.7453	82.69	1650.0
44	28	29	750	4	14.1881	112.73	750.0
45	29	30	300	4	12.1226	119.05	132.0
46	2	30	525	2	1.7453	82.69	525.0
47	30	31	297	2	11.3158	116.39	297.0
48	30	18	4100	7	11.3158	116.39	211.8
50	32	1	30	2	13.7059	116.74	30.0
49	31	32	2031	5	14.0572	119.59	61.8
51	32	1	100	2	13.7059	116.74	100.0

AIRWAY	WAVE 1				WAVE 2				WAVE 3			
	CONC %	LOCATION	START	ARRIVAL	CONC %	LOCATION	START	ARRIVAL	CONC %	LOCATION	START	ARRIVAL
		FT	TIME	TIME		FT	TIME	TIME		FT	TIME	TIME
2	1.6267	325.0	65.94	67.89	1.7453	325.0	82.69	84.64				
3	19.5726	2577.0	11.94	31.47	21.0000	2577.0	28.70	48.23				
5	19.5726	2900.0	11.94	65.94	21.0000	2900.0	28.70	82.69				
6	19.5726	100.0	11.77	11.94	21.0000	100.0	28.53	28.70				
7	19.5726	2700.0	7.13	11.77	21.0000	2700.0	23.88	28.53				
8	21.0000	524.0	3.99	23.88								
9	21.0000	1700.0	3.99	7.13								
10	21.0000	1650.0	1.15	3.99								
11	21.0000	4500.0	1.15	45.61								
12	1.6267	2700.0	67.89	74.36	1.7453	2700.0	84.64	91.11				
13	1.6267	2050.0	74.36	97.75	1.7453	2050.0	91.11	114.50				
14	1.6267	600.0	74.36	76.18	1.7453	600.0	91.11	92.93				
15	1.6267	600.0	76.18	78.28	1.7453	600.0	92.93	95.03				
16	1.6267	600.0	78.28	90.36	1.7453	600.0	95.03	107.11				
17	1.6267	1100.0	78.28	82.94	1.7453	1100.0	95.03	99.69				
18	1.3441	319.0	82.94	84.61	1.6267	319.0	90.36	92.03	1.7247	319.0	99.69	101.36
19	1.3441	600.0	84.61	86.71	1.6267	600.0	92.03	94.13	1.7247	600.0	101.36	103.46
20	21.0000	524.0	0.00	1.15								
21	0.1790	550.0	87.11	88.50	0.5414	550.0	97.05	98.44	0.5545	550.0	103.87	105.25
22	1.6267	318.0	76.18	87.11	1.7453	318.0	92.93	103.87				
23	0.4073	600.0	95.35	97.05	0.6810	600.0	109.87	111.57	0.7107	600.0	112.11	113.81
24	1.6267	2600.0	65.94	95.35	1.7453	2600.0	82.69	112.11				
25	0.3651	1050.0	105.91	109.87								
26	0.3674	124.0	118.51	0.00								
27	0.6922	800.0	100.18	105.91	0.7426	428.6	116.93	0.00				
28	0.6922	1217.0	100.18	118.51	0.7426	203.8	116.93	0.00				
29	0.6922	333.0	97.75	100.18	0.7426	333.0	114.50	116.93				
35	19.5726	2400.0	11.94	24.08	21.0000	2400.0	28.70	40.84				
36	19.5726	2600.0	24.08	53.00	21.0000	2600.0	40.84	69.76				
37	19.5726	3200.0	24.08	53.78	21.0000	3200.0	40.84	70.53				
38	12.6482	230.0	53.78	55.84	13.5706	230.0	70.53	72.60	14.1461	230.0	93.90	95.97
39	12.6482	2292.0	55.84	103.42	13.5706	2283.8	72.60	0.00	14.1461	1157.7	95.97	0.00
40	19.5726	2000.0	53.00	75.25	21.0000	2000.0	69.76	92.00				
41	19.5726	1700.0	75.25	99.63	21.0000	1700.0	92.00	116.39				
42	19.5726	904.4	75.25	0.00	21.0000	565.8	92.00	0.00				
43	1.6267	1650.0	65.94	93.90	1.7453	1650.0	82.69	110.66				
44	12.6482	750.0	55.84	62.17	13.5706	750.0	72.60	78.92	14.1461	750.0	95.97	102.29
45	10.8069	300.0	62.17	64.33	11.5950	300.0	78.92	81.08	12.0868	300.0	102.29	104.46
46	1.6267	525.0	65.94	72.36	1.7453	525.0	82.69	89.12				
47	10.9730	297.0	104.46	107.66	11.3158	297.0	116.39	119.59				
48	5.1687	3265.5	64.33	0.00	5.6267	2794.2	72.36	0.00	6.0036	2282.8	81.08	0.00
50	12.1063	30.0	116.17	117.67	13.7059	30.0	116.74	118.24				
49	9.2490	2031.0	92.32	105.65	12.1063	2031.0	102.84	116.17	13.7059	2031.0	103.42	116.74
51	12.1063	100.0	116.17	116.47	13.7059	100.0	116.74	117.05				

AIRWAY	WAVE 4				WAVE 5				WAVE 6			
	CONC %	LOCATION	START	ARRIVAL	CONC %	LOCATION	START	ARRIVAL	CONC %	LOCATION	START	ARRIVAL
		FT	TIME	TIME		FT	TIME	TIME		FT	TIME	TIME
18	1.7453	319.0	107.11	108.79								
19	1.7453	600.0	108.79	110.89								
21	0.7981	550.0	111.57	112.96	0.8245	550.0	113.81	115.20				
38	14.1881	230.0	110.66	112.73								
39	14.1881	350.5	112.73	0.00								
44	14.1881	750.0	112.73	119.05								
45	12.1226	132.0	119.05	0.00								
48	6.0370	1811.4	89.12	0.00	10.7378	1194.6	99.63	0.00	10.9730	911.8	104.46	0.00
49	13.8488	1880.2	107.66	0.00	14.0572	61.8	119.59	0.00				

1 WAVES OF AIRWAY 48 ARE BEING BUFFERDUNTIL PRINTING SPACE IS AVAILBLE

AT 120 MIN. AFTER THE START OF CONTAMINATION CRITICAL
FUME CONCENTRATIONS (FUMES > 0.001) % NOW EXIST IN THE
FOLLOWING JUNCTIONS

JUNCTION	CURRENT FUME CONCENTRATION	TIME OF FIRST CONTAMINATION
2	1.7453	82.69
3	1.7453	84.64
4	21.0000	28.70
5	21.0000	28.53
6	21.0000	23.88
7	21.0000	3.99
8	1.7453	91.11
9	1.7453	92.93
10	1.7453	95.03
11	1.7453	107.11
12	1.7453	108.79
13	1.2102	115.20
14	21.0000	1.15
15	0.8245	113.81
16	0.7107	112.11
17	0.3651	105.91
18	0.3674	118.51
19	0.7426	114.50
20	0.7426	116.93
24	21.0000	40.84
25	21.0000	69.76
26	21.0000	92.00
27	14.1881	110.66
28	14.1881	112.73
29	12.1226	119.05
30	11.3158	116.39
31	14.0572	119.59
32	13.7059	116.74

AT 120 MIN. AFTER THE START OF CONTAMINATION THE TOTAL EXPOSURE TO
THE CONTAMINANT MEASURED IN PPM*HOURS WAS IN THE FOLLOWING JUNCTIONS

JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE
1	0.00	2	15394.34	3	14827.77
4	374207.59	5	374809.72	6	391066.44
7	406034.66	8	12944.99	9	12415.31
10	11804.78	11	10074.94	12	9588.04
13	5260.23	14	415969.31	15	2771.73
16	2174.04	17	857.74	18	91.10
19	2613.00	20	2312.83	21	0.00
22	0.00	23	0.00	24	331717.38
25	230508.75	26	152655.94	27	149778.38
28	144886.92	29	111018.19	30	70983.38
31	113067.57	32	82314.81		

AT 180 MIN. AFTER THE START OF CONTAMINATION CRITICAL
 FUME CONCENTRATIONS (FUMES > 0.0010 %) NOW EXIST IN THE
 FOLLOWING AIRWAYS

AIRWAY				WAVE			
NUMBER	FROM	TO	LENGTH FT	NUMBER	CONC %	START TIME	LENGTH FT
2	2	3	325	2	1.7453	82.69	325.0
3	4	1	2577	2	21.0000	28.70	2577.0
5	4	2	2900	2	21.0000	28.70	2900.0
6	5	4	100	2	21.0000	28.53	100.0
7	6	5	2700	2	21.0000	23.88	2700.0
8	7	6	524	1	21.0000	3.99	524.0
9	7	6	1700	1	21.0000	3.99	1700.0
10	14	7	1650	1	21.0000	1.15	1650.0
11	14	31	4500	1	21.0000	1.15	4500.0
12	3	8	2700	2	1.7453	84.64	2700.0
13	8	19	2050	2	1.7453	91.11	2050.0
14	8	9	600	2	1.7453	91.11	600.0
15	9	10	600	2	1.7453	92.93	600.0
16	10	11	600	2	1.7453	95.03	600.0
17	10	11	1100	2	1.7453	95.03	1100.0
18	11	12	319	4	1.7453	107.11	319.0
19	12	13	600	4	1.7453	108.79	600.0
20	13	14	524	1	21.0000	0.00	524.0
21	15	13	550	3	2.5545	177.93	550.0
22	9	15	318	2	1.7453	92.93	318.0
23	16	15	600	1	2.6545	176.23	600.0
24	2	16	2600	2	1.7453	82.69	2600.0
25	17	16	1050	5	3.0103	177.09	770.4
26	18	17	228	3	5.5424	174.35	228.0
27	20	17	800	2	0.7426	116.93	800.0
28	20	18	1217	2	0.7426	116.93	1217.0
29	19	20	333	2	0.7426	114.50	333.0
35	4	24	2400	2	21.0000	28.70	2400.0
36	24	25	2600	2	21.0000	40.84	2600.0
37	24	27	3200	2	21.0000	40.84	3200.0
38	27	28	230	4	14.1881	110.66	230.0
39	28	31	2292	4	14.1881	112.73	2292.0
40	25	26	2000	2	21.0000	69.76	2000.0
41	26	30	1700	2	21.0000	92.00	1700.0
42	26	29	1050	2	21.0000	92.00	1050.0
43	2	27	1650	2	1.7453	82.69	1650.0
44	28	29	750	4	14.1881	112.73	750.0
45	29	30	300	1	15.1797	143.96	300.0
46	2	30	525	2	1.7453	82.69	525.0
47	30	31	297	5	12.7951	146.12	297.0
48	30	18	4100	5	12.7951	146.12	1987.3
50	32	1	30	5	15.1512	173.63	30.0
49	31	32	2031	4	15.1512	160.30	2031.0
51	32	1	100	5	15.1512	173.63	100.0

AIRWAY	WAVE 1				WAVE 2				WAVE 3			
	CONC %	LOCATION	START	ARRIVAL	CONC %	LOCATION	START	ARRIVAL	CONC %	LOCATION	START	ARRIVAL
		FT	TIME	TIME		FT	TIME	TIME		FT	TIME	TIME
2	1.6267	325.0	65.94	67.89	1.7453	325.0	82.69	84.64				
3	19.5726	2577.0	11.94	31.47	21.0000	2577.0	28.70	48.23				
5	19.5726	2900.0	11.94	65.94	21.0000	2900.0	28.70	82.69				
6	19.5726	100.0	11.77	11.94	21.0000	100.0	28.53	28.70				
7	19.5726	2700.0	7.13	11.77	21.0000	2700.0	23.88	28.53				
8	21.0000	524.0	3.99	23.88								
9	21.0000	1700.0	3.99	7.13								
10	21.0000	1650.0	1.15	3.99								
11	21.0000	4500.0	1.15	45.61								
12	1.6267	2700.0	67.89	74.36	1.7453	2700.0	84.64	91.11				
13	1.6267	2050.0	74.36	97.75	1.7453	2050.0	91.11	114.50				
14	1.6267	600.0	74.36	76.18	1.7453	600.0	91.11	92.93				
15	1.6267	600.0	76.18	78.28	1.7453	600.0	92.93	93.03				
16	1.6267	600.0	78.28	90.36	1.7453	600.0	93.03	107.11				
17	1.6267	1100.0	78.28	82.94	1.7453	1100.0	95.03	99.69				
18	1.3441	319.0	82.94	84.61	1.6267	319.0	90.36	92.03	1.7247	319.0	99.69	101.36
19	1.3441	600.0	84.61	86.71	1.6267	600.0	92.03	94.13	1.7247	600.0	101.36	103.46
20	21.0000	524.0	0.00	1.15								
21	1.8544	550.0	159.38	160.77	1.8593	550.0	167.42	168.81	2.5545	550.0	177.93	179.32
22	1.6267	318.0	76.18	87.11	1.7453	318.0	92.93	103.87				
23	2.6545	600.0	176.23	177.93								
24	1.6267	2600.0	65.94	95.35	1.7453	2600.0	82.69	112.11				
25	1.8252	1050.0	145.00	148.96	1.9088	1050.0	153.72	157.68	1.9162	1050.0	161.75	165.72
26	3.2266	228.0	159.02	161.75	5.4320	228.0	169.53	172.27	5.5424	228.0	174.35	177.09
27	0.6922	800.0	100.18	105.91	0.7426	800.0	116.93	122.66				
28	0.6922	1217.0	100.18	118.51	0.7426	1217.0	116.93	135.27				
29	0.6922	333.0	97.75	100.18	0.7426	333.0	114.50	116.93				
35	19.5726	2400.0	11.94	24.08	21.0000	2400.0	28.70	40.84				
36	19.5726	2600.0	24.08	53.00	21.0000	2600.0	40.84	69.76				
37	19.5726	3200.0	24.08	53.78	21.0000	3200.0	40.84	70.53				
38	12.6482	230.0	53.78	55.84	13.5706	230.0	70.53	72.60	14.1461	230.0	93.90	95.97
39	12.6482	2292.0	55.84	103.42	13.5706	2292.0	72.60	120.17	14.1461	2292.0	95.97	143.54
40	19.5726	2000.0	53.00	75.25	21.0000	2000.0	69.76	92.00				
41	19.5726	1700.0	75.25	99.63	21.0000	1700.0	92.00	116.39				
42	19.5726	1050.0	75.25	127.21	21.0000	1050.0	92.00	143.96				
43	1.6267	1650.0	65.94	93.90	1.7453	1650.0	82.69	110.66				
44	12.6482	750.0	55.84	62.17	13.5706	750.0	72.60	78.92	14.1461	750.0	95.97	102.29
45	15.1797	300.0	143.96	146.12								
46	1.6267	525.0	65.94	72.36	1.7453	525.0	82.69	89.12				
47	10.9730	297.0	104.46	107.66	11.3158	297.0	116.39	119.59	11.3330	297.0	121.21	124.42
48	10.9730	4100.0	104.46	174.35	11.3158	3731.3	116.39	0.00	11.3330	3448.4	121.21	0.00
50	14.1843	30.0	137.74	139.24	15.0127	30.0	145.90	147.40	15.0855	30.0	156.87	158.37
49	15.0127	2031.0	132.57	145.90	15.0855	2031.0	143.54	156.87	15.1459	2031.0	149.33	162.66
51	14.1843	100.0	137.74	138.05	15.0127	100.0	145.90	146.20	15.0855	100.0	156.87	157.17

AIRWAY	WAVE 4				WAVE 5			
	CONC %	LOCATION	START	ARRIVAL	CONC %	LOCATION	START	ARRIVAL
		FT	TIME	TIME		FT	TIME	TIME
18	1.7453	319.0	107.11	108.79				
19	1.7453	600.0	108.79	110.89				
25	2.9582	1050.0	172.27	176.23	3.0103	770.4	177.09	0.00
38	14.1881	230.0	110.66	112.73				
39	14.1881	2292.0	112.73	160.30				
44	14.1881	750.0	112.73	119.05				
47	12.6957	297.0	129.37	132.57	12.7951	297.0	146.12	149.33
48	12.6957	2970.0	129.37	0.00	12.7951	1987.3	146.12	0.00
50	15.1459	30.0	162.66	164.15	15.1512	30.0	173.63	175.12
49	15.1512	2031.0	160.30	173.63				
51	15.1459	100.0	162.66	162.96	15.1512	100.0	173.63	173.93

AT 180 MIN. AFTER THE START OF CONTAMINATION CRITICAL
FUME CONCENTRATIONS (FUMES > 0.001) % NOW EXIST IN THE
FOLLOWING JUNCTIONS

JUNCTION	CURRENT FUME CONCENTRATION	TIME OF FIRST CONTAMINATION
2	1.7453	82.67
3	1.7453	84.64
4	21.0000	28.70
5	21.0000	28.53
6	21.0000	23.88
7	21.0000	3.99
8	1.7453	91.11
9	1.7453	92.93
10	1.7453	95.03
11	1.7453	107.11
12	1.7453	108.79
13	2.2156	179.32
14	21.0000	1.15
15	2.5545	177.93
16	2.6545	176.23
17	3.0103	177.09
18	5.5424	174.35
19	0.7426	114.50
20	0.7426	116.93
24	21.0000	40.84
25	21.0000	69.76
26	21.0000	92.00
27	14.1881	110.66
28	14.1881	112.73
29	15.1797	143.96
30	12.7951	146.12
31	15.1512	160.30
32	15.1512	173.63

AT 180 MIN. AFTER THE START OF CONTAMINATION THE TOTAL EXPOSURE TO
THE CONTAMINANT MEASURED IN PPM*HOURS WAS IN THE FOLLOWING JUNCTIONS

JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE
1	0.00	2	32847.38	3	32280.81
4	584207.63	5	584809.69	6	601066.44
7	616034.69	8	30398.04	9	29868.35
10	29257.82	11	27527.98	12	27041.08
13	20541.75	14	625969.31	15	16888.05
16	16428.53	17	15783.96	18	25852.22
19	10039.38	20	9739.21	21	0.00
22	0.00	23	0.00	24	541717.38
25	440508.72	26	362655.94	27	291659.19
28	286767.78	29	258564.30	30	196371.08
31	262216.09	32	228561.02		

AT 240 MIN. AFTER THE START OF CONTAMINATION CRITICAL
 FUME CONCENTRATIONS (FUMES > 0.0010 %) NOW EXIST IN THE
 FOLLOWING AIRWAYS

AIRWAY				WAVE			
NUMBER	FROM	TO	LENGTH FT	NUMBER	CONC %	START TIME	LENGTH FT
2	2	3	325	2	1.7453	82.69	325.0
3	4	1	2577	2	21.0000	28.70	2577.0
5	4	2	2900	2	21.0000	28.70	2900.0
6	5	4	100	2	21.0000	28.53	100.0
7	6	5	2700	2	21.0000	23.88	2700.0
8	7	6	524	1	21.0000	3.99	524.0
9	7	6	1700	1	21.0000	3.99	1700.0
10	14	7	1650	1	21.0000	1.15	1650.0
11	14	31	4500	1	21.0000	1.15	4500.0
12	3	8	2700	2	1.7453	84.64	2700.0
13	8	19	2050	2	1.7453	91.11	2050.0
14	8	9	600	2	1.7453	91.11	600.0
15	9	10	600	2	1.7453	92.93	600.0
16	10	11	600	2	1.7453	95.03	600.0
17	10	11	1100	2	1.7453	95.03	1100.0
18	11	12	319	4	1.7453	107.11	319.0
19	12	13	600	4	1.7453	108.79	600.0
20	13	14	524	1	21.0000	0.00	524.0
21	15	13	550	3	2.8587	224.42	550.0
22	9	15	318	2	1.7453	92.93	318.0
23	16	15	600	1	2.9963	222.72	600.0
24	2	16	2600	2	1.7453	82.69	2600.0
25	17	16	1050	4	3.4142	218.75	1050.0
26	18	17	228	2	6.3972	216.02	228.0
27	20	17	800	2	0.7426	116.93	800.0
28	20	18	1217	2	0.7426	116.93	1217.0
29	19	20	333	2	0.7426	114.50	333.0
35	4	24	2400	2	21.0000	28.70	2400.0
36	24	25	2600	2	21.0000	40.84	2600.0
37	24	27	3200	2	21.0000	40.84	3200.0
38	27	28	230	4	14.1881	110.66	230.0
39	28	31	2292	4	14.1881	112.73	2292.0
40	25	26	2000	2	21.0000	69.76	2000.0
41	26	30	1700	2	21.0000	92.00	1700.0
42	26	29	1050	2	21.0000	92.00	1050.0
43	2	27	1650	2	1.7453	82.69	1650.0
44	28	29	750	4	14.1881	112.73	750.0
45	29	30	300	1	15.1797	143.96	300.0
46	2	30	525	2	1.7453	82.69	525.0
47	30	31	297	5	12.7951	146.12	297.0
48	30	18	4100	5	12.7951	146.12	4100.0
50	32	1	30	5	15.1512	173.63	30.0
49	31	32	2031	4	15.1512	160.30	2031.0
51	32	1	100	5	15.1512	173.63	100.0

AIRWAY	WAVE 1				WAVE 2				WAVE 3			
	CONC %	LOCATION FT	START TIME	ARRIVAL TIME	CONC %	LOCATION FT	START TIME	ARRIVAL TIME	CONC %	LOCATION FT	START TIME	ARRIVAL TIME
2	1.6267	325.0	65.94	67.89	1.7453	325.0	82.69	84.64				
3	19.5726	2577.0	11.94	31.47	21.0000	2577.0	28.70	48.23				
5	19.5726	2900.0	11.94	65.94	21.0000	2900.0	28.70	82.69				
6	19.5726	100.0	11.77	11.94	21.0000	100.0	28.33	28.70				
7	19.5726	2700.0	7.13	11.77	21.0000	2700.0	23.88	28.53				
8	21.0000	524.0	3.99	23.88								
9	21.0000	1700.0	3.99	7.13								
10	21.0000	1650.0	1.15	3.99								
11	21.0000	4500.0	1.15	45.61								
12	1.6267	2700.0	67.89	74.36	1.7453	2700.0	84.64	91.11				
13	1.6267	2050.0	74.36	97.75	1.7453	2050.0	91.11	114.50				
14	1.6267	600.0	74.36	76.18	1.7453	600.0	91.11	92.93				
15	1.6267	600.0	76.18	78.28	1.7453	600.0	92.93	95.03				
16	1.6267	600.0	78.28	90.36	1.7453	600.0	95.03	107.11				
17	1.6267	1100.0	78.28	82.94	1.7453	1100.0	95.03	99.69				
18	1.3441	319.0	82.94	84.61	1.6267	319.0	90.36	92.03	1.7247	319.0	99.69	101.36
19	1.3441	600.0	84.61	86.71	1.6267	600.0	92.03	94.13	1.7247	600.0	101.36	103.46
20	21.0000	524.0	0.00	1.15								
21	2.6425	550.0	199.51	200.90	2.8440	550.0	207.67	209.05	2.8587	550.0	224.42	225.81
22	1.6267	318.0	76.18	87.11	1.7453	318.0	92.93	103.87				
23	2.9963	600.0	222.72	224.42								
24	1.6267	2600.0	65.94	95.35	1.7453	2600.0	82.69	112.11				
25	3.0863	1050.0	189.02	192.99	3.0901	1050.0	193.84	197.81	3.3922	1050.0	202.00	205.97
26	6.3506	228.0	199.26	202.00	6.3972	228.0	216.02	218.75				
27	0.6922	800.0	100.18	105.91	0.7426	800.0	116.93	122.66				
28	0.6922	1217.0	100.18	118.51	0.7426	1217.0	116.93	135.27				
29	0.6922	333.0	97.75	100.18	0.7426	333.0	114.50	116.93				
35	19.5726	2400.0	11.94	24.08	21.0000	2400.0	28.70	40.84				
36	19.5726	2600.0	24.08	53.00	21.0000	2600.0	40.84	69.76				
37	19.5726	3200.0	24.08	53.78	21.0000	3200.0	40.84	70.53				
38	12.6482	230.0	53.78	55.84	13.5706	230.0	70.53	72.60	14.1461	230.0	93.90	95.97
39	12.6482	2292.0	55.84	103.42	13.5706	2292.0	72.60	120.17	14.1461	2292.0	95.97	143.54
40	19.5726	2000.0	53.00	75.25	21.0000	2000.0	69.76	92.00				
41	19.5726	1700.0	75.25	99.63	21.0000	1700.0	92.00	116.39				
42	19.5726	1050.0	75.25	127.21	21.0000	1050.0	92.00	143.96				
43	1.6267	1650.0	65.94	93.90	1.7453	1650.0	82.69	110.66				
44	12.6482	750.0	55.84	62.17	13.5706	750.0	72.60	78.92	14.1461	750.0	95.97	102.29
45	15.1797	300.0	143.96	146.12								
46	1.6267	525.0	65.94	72.36	1.7453	525.0	82.69	89.12				
47	10.9730	297.0	104.46	107.66	11.3158	297.0	116.39	119.59	11.3330	297.0	121.21	124.42
48	10.9730	4100.0	104.46	174.35	11.3158	4100.0	116.39	186.29	11.3330	4100.0	121.21	191.11
50	14.1843	30.0	137.74	139.24	15.0127	30.0	145.90	147.40	15.0855	30.0	156.87	158.37
49	15.0127	2031.0	132.57	145.90	15.0855	2031.0	143.54	156.87	15.1459	2031.0	149.33	162.66
51	14.1843	100.0	137.74	138.05	15.0127	100.0	145.90	146.20	15.0855	100.0	156.87	157.17

AIRWAY	WAVE 4				WAVE 5			
	CONC %	LOCATION FT	START TIME	ARRIVAL TIME	CONC %	LOCATION FT	START TIME	ARRIVAL TIME
18	1.7453	319.0	107.11	108.79				
19	1.7453	600.0	108.79	110.89				
25	3.4142	1050.0	218.75	222.72				
38	14.1881	230.0	110.66	112.73				
39	14.1881	2292.0	112.73	160.30				
44	14.1881	750.0	112.73	119.05				
47	12.6957	297.0	129.37	132.57	12.7931	297.0	146.12	149.33
48	12.6957	4100.0	129.37	199.26	12.7931	4100.0	146.12	216.02
50	15.1459	30.0	162.66	164.15	15.1512	30.0	173.63	175.12
49	15.1512	2031.0	160.30	173.63				
51	15.1459	100.0	162.66	162.96	15.1512	100.0	173.63	173.93

AT 240 MIN. AFTER THE START OF CONTAMINATION CRITICAL
FUME CONCENTRATIONS (FUMES > 0.001) % NOW EXIST IN THE
FOLLOWING JUNCTIONS

JUNCTION	CURRENT FUME CONCENTRATION	TIME OF FIRST CONTAMINATION
2	1.7453	82.69
3	1.7453	84.64
4	21.0000	28.70
5	21.0000	28.53
6	21.0000	23.88
7	21.0000	3.99
8	1.7453	91.11
9	1.7453	92.93
10	1.7453	95.03
11	1.7453	107.11
12	1.7453	108.79
13	2.3924	225.81
14	21.0000	1.15
15	2.8587	224.42
16	2.9963	222.72
17	3.4142	218.75
18	6.3972	216.02
19	0.7426	114.50
20	0.7426	116.93
24	21.0000	40.84
25	21.0000	69.76
26	21.0000	92.00
27	14.1881	110.66
28	14.1881	112.73
29	15.1797	143.96
30	12.7951	146.12
31	15.1512	160.30
32	15.1512	173.63

AT 240 MIN. AFTER THE START OF CONTAMINATION THE TOTAL EXPOSURE TO
THE CONTAMINANT MEASURED IN PPM*HOURS WAS IN THE FOLLOWING JUNCTIONS

JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE
1	0.00	2	50300.42	3	49733.85
4	794207.63	5	794809.69	6	811066.38
7	826034.63	8	47851.08	9	47321.40
10	46710.87	11	44981.03	12	44494.12
13	43735.12	14	835969.25	15	44288.78
16	45155.75	17	48553.21	18	87308.57
19	17465.75	20	17165.59	21	0.00
22	0.00	23	0.00	24	751717.31
25	650508.75	26	572655.94	27	433540.09
28	428648.63	29	410361.78	30	324322.25
31	413727.88	32	380072.84		

AT 300 MIN. AFTER THE START OF CONTAMINATION CRITICAL
 FUME CONCENTRATIONS (FUMES > 0.0010 %) NOW EXIST IN THE
 FOLLOWING AIRWAYS

AIRWAY				WAVE			
NUMBER	FROM TO	LENGTH FT		NUMBER	CONC %	START TIME	LENGTH FT
2	2	3	325	2	1.7453	82.69	325.0
3	4	1	2577	2	21.0000	28.70	2577.0
5	4	2	2900	2	21.0000	28.70	2900.0
6	5	4	100	2	21.0000	28.53	100.0
7	6	5	2700	2	21.0000	23.88	2700.0
8	7	6	524	1	21.0000	3.99	524.0
9	7	6	1700	1	21.0000	3.99	1700.0
10	14	7	1650	1	21.0000	1.15	1650.0
11	14	31	4500	1	21.0000	1.15	4500.0
12	3	8	2700	2	1.7453	84.64	2700.0
13	8	19	2050	2	1.7453	91.11	2050.0
14	8	9	600	2	1.7453	91.11	600.0
15	9	10	600	2	1.7453	92.93	600.0
16	10	11	600	2	1.7453	95.03	600.0
17	10	11	1100	2	1.7453	95.03	1100.0
18	11	12	319	4	1.7453	107.11	319.0
19	12	13	600	4	1.7453	108.79	600.0
20	13	14	524	1	21.0000	0.00	524.0
21	15	13	550	3	2.8587	224.42	550.0
22	9	15	318	2	1.7453	92.93	318.0
23	16	15	600	1	2.9963	222.72	600.0
24	2	16	2600	2	1.7453	82.69	2600.0
25	17	16	1050	4	3.4142	218.75	1050.0
26	18	17	228	2	6.3972	216.02	228.0
27	20	17	800	2	0.7426	116.93	800.0
28	20	18	1217	2	0.7426	116.93	1217.0
29	19	20	333	2	0.7426	114.50	333.0
35	4	24	2400	2	21.0000	28.70	2400.0
36	24	25	2600	2	21.0000	40.84	2600.0
37	24	27	3200	2	21.0000	40.84	3200.0
38	27	28	230	4	14.1881	110.66	230.0
39	28	31	2292	4	14.1881	112.73	2292.0
40	25	26	2000	2	21.0000	69.76	2000.0
41	26	30	1700	2	21.0000	92.00	1700.0
42	26	29	1050	2	21.0000	92.00	1050.0
43	2	27	1650	2	1.7453	82.69	1650.0
44	28	29	750	4	14.1881	112.73	750.0
45	29	30	300	1	15.1797	143.96	300.0
46	2	30	525	2	1.7453	82.69	525.0
47	30	31	297	5	12.7951	146.12	297.0
48	30	18	4100	5	12.7951	146.12	4100.0
50	32	1	30	5	15.1512	173.63	30.0
49	31	32	2031	4	15.1512	160.30	2031.0
51	32	1	100	5	15.1512	173.63	100.0

AIRWAY	WAVE 1				WAVE 2				WAVE 3			
	CONC %	LOCATION	START	ARRIVAL	CONC %	LOCATION	START	ARRIVAL	CONC %	LOCATION	START	ARRIVAL
		FT	TIME	TIME		FT	TIME	TIME		FT	TIME	TIME
2	1.6267	325.0	65.94	67.89	1.7453	325.0	82.69	84.64				
3	19.5726	2577.0	11.94	31.47	21.0000	2577.0	28.70	48.23				
5	19.5726	2900.0	11.94	65.94	21.0000	2900.0	28.70	82.69				
6	19.5726	100.0	11.77	11.94	21.0000	100.0	28.53	28.70				
7	19.5726	2700.0	7.13	11.77	21.0000	2700.0	23.88	28.53				
8	21.0000	524.0	3.99	23.88								
9	21.0000	1700.0	3.99	7.13								
10	21.0000	1650.0	1.15	3.99								
11	21.0000	4500.0	1.15	45.61								
12	1.6267	2700.0	67.89	74.36	1.7453	2700.0	84.64	91.11				
13	1.6267	2050.0	74.36	97.75	1.7453	2050.0	91.11	114.50				
14	1.6267	600.0	74.36	76.18	1.7453	600.0	91.11	92.93				
15	1.6267	600.0	76.18	78.28	1.7453	600.0	92.93	95.03				
16	1.6267	600.0	78.28	90.36	1.7453	600.0	95.03	107.11				
17	1.6267	1100.0	78.28	82.94	1.7453	1100.0	95.03	99.69				
18	1.3441	319.0	82.94	84.61	1.6267	319.0	90.36	92.03	1.7247	319.0	99.69	101.36
19	1.3441	600.0	84.61	86.71	1.6267	600.0	92.03	94.13	1.7247	600.0	101.36	103.46
20	21.0000	524.0	0.00	1.15								
21	2.6425	550.0	199.51	200.90	2.8440	550.0	207.67	209.05	2.8587	550.0	224.42	225.81
22	1.6267	318.0	76.18	87.11	1.7453	318.0	92.93	103.87				
23	2.9963	600.0	222.72	224.42								
24	1.6267	2600.0	65.94	95.35	1.7453	2600.0	82.69	112.11				
25	3.0863	1050.0	189.02	192.99	3.0901	1050.0	193.84	197.81	3.3922	1050.0	202.00	205.97
26	6.3506	228.0	199.26	202.00	6.3972	228.0	216.02	218.75				
27	0.6922	800.0	100.18	105.91	0.7426	800.0	116.93	122.66				
28	0.6922	1217.0	100.18	118.51	0.7426	1217.0	116.93	135.27				
29	0.6922	333.0	97.75	100.18	0.7426	333.0	114.50	116.93				
35	19.5726	2400.0	11.94	24.08	21.0000	2400.0	28.70	40.84				
36	19.5726	2600.0	24.08	53.00	21.0000	2600.0	40.84	69.76				
37	19.5726	3200.0	24.08	53.78	21.0000	3200.0	40.84	70.53				
38	12.6482	230.0	53.78	55.84	13.5706	230.0	70.53	72.60	14.1461	230.0	93.90	95.97
39	12.6482	2292.0	55.84	103.42	13.5706	2292.0	72.60	120.17	14.1461	2292.0	95.97	143.54
40	19.5726	2000.0	53.00	75.25	21.0000	2000.0	69.76	92.00				
41	19.5726	1700.0	75.25	99.63	21.0000	1700.0	92.00	116.39				
42	19.5726	1050.0	75.25	127.21	21.0000	1050.0	92.00	143.96				
43	1.6267	1650.0	65.94	93.90	1.7453	1650.0	82.69	110.66				
44	12.6482	750.0	55.84	62.17	13.5706	750.0	72.60	78.92	14.1461	750.0	95.97	102.29
45	15.1797	300.0	143.96	146.12								
46	1.6267	525.0	65.94	72.36	1.7453	525.0	82.69	89.12				
47	10.9730	297.0	104.46	107.66	11.3158	297.0	116.39	119.59	11.3330	297.0	121.21	124.42
48	10.9730	4100.0	104.46	174.35	11.3158	4100.0	116.39	186.29	11.3330	4100.0	121.21	191.11
50	14.1843	30.0	137.74	139.24	15.0127	30.0	145.90	147.40	15.0855	30.0	156.87	158.37
49	15.0127	2031.0	132.57	145.90	15.0855	2031.0	143.54	156.87	15.1459	2031.0	149.33	162.66
51	14.1843	100.0	137.74	138.05	15.0127	100.0	145.90	146.20	15.0855	100.0	156.87	157.17

AIRWAY	WAVE 4				WAVE 5			
	CONC %	LOCATION	START	ARRIVAL	CONC %	LOCATION	START	ARRIVAL
		FT	TIME	TIME		FT	TIME	TIME
18	1.7453	319.0	107.11	108.79				
19	1.7453	600.0	108.79	110.89				
25	3.4142	1050.0	218.75	222.72				
38	14.1881	230.0	110.66	112.73				
39	14.1881	2292.0	112.73	160.30				
44	14.1881	750.0	112.73	119.05				
47	12.6957	297.0	129.37	132.57	12.7951	297.0	146.12	149.33
48	12.6957	4100.0	129.37	199.26	12.7951	4100.0	146.12	216.02
50	15.1459	30.0	162.66	164.15	15.1512	30.0	173.63	175.12
49	15.1512	2031.0	160.30	173.63				
51	15.1459	100.0	162.66	162.96	15.1512	100.0	173.63	173.93

AT 300 MIN. AFTER THE START OF CONTAMINATION CRITICAL
FUME CONCENTRATIONS (FUMES > 0.001) % NOW EXIST IN THE
FOLLOWING JUNCTIONS

JUNCTION	CURRENT FUME CONCENTRATION	TIME OF FIRST CONTAMINATION
2	1.7453	82.69
3	1.7453	84.64
4	21.0000	28.70
5	21.0000	28.53
6	21.0000	23.88
7	21.0000	3.99
8	1.7453	91.11
9	1.7453	92.93
10	1.7453	95.03
11	1.7453	107.11
12	1.7453	108.79
13	2.3924	225.81
14	21.0000	1.15
15	2.8587	224.42
16	2.9963	222.72
17	3.4142	218.75
18	6.3972	216.02
19	0.7426	114.50
20	0.7426	116.93
24	21.0000	40.84
25	21.0000	69.76
26	21.0000	92.00
27	14.1881	110.66
28	14.1881	112.73
29	15.1797	143.96
30	12.7951	146.12
31	15.1512	160.30
32	15.1512	173.63

AT 300 MIN. AFTER THE START OF CONTAMINATION THE TOTAL EXPOSURE TO
THE CONTAMINANT MEASURED IN PPM*HOURS WAS IN THE FOLLOWING JUNCTIONS

JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE
1	0.00	2	67753.47	3	67186.89
4	1004207.56	5	1004809.63	6	1021066.31
7	1036034.75	8	65304.12	9	64774.44
10	64163.91	11	62434.07	12	61947.17
13	67658.85	14	1045969.31	15	72875.94
16	75119.23	17	82695.36	18	151281.02
19	24892.13	20	24591.96	21	0.00
22	0.00	23	0.00	24	961717.25
25	860508.69	26	782655.94	27	575420.88
28	570529.50	29	562159.25	30	452273.47
31	565239.69	32	531584.69		

AT 360 MIN. AFTER THE START OF CONTAMINATION CRITICAL
 FUME CONCENTRATIONS (FUMES > 0.0010 %) NOW EXIST IN THE
 FOLLOWING AIRWAYS

AIRWAY				WAVE			
NUMBER	FROM	TO	LENGTH FT	NUMBER	CONC %	START TIME	LENGTH FT
2	2	3	325	2	1.7453	82.69	325.0
3	4	1	2577	2	21.0000	28.70	2577.0
5	4	2	2900	2	21.0000	28.70	2900.0
6	5	4	100	2	21.0000	28.53	100.0
7	6	5	2700	2	21.0000	23.88	2700.0
8	7	6	524	1	21.0000	3.99	524.0
9	7	6	1700	1	21.0000	3.99	1700.0
10	14	7	1650	1	21.0000	1.15	1650.0
11	14	31	4500	1	21.0000	1.15	4500.0
12	3	8	2700	2	1.7453	84.64	2700.0
13	8	19	2050	2	1.7453	91.11	2050.0
14	8	9	600	2	1.7453	91.11	600.0
15	9	10	600	2	1.7453	92.93	600.0
16	10	11	600	2	1.7453	95.03	600.0
17	10	11	1100	2	1.7453	95.03	1100.0
18	11	12	319	4	1.7453	107.11	319.0
19	12	13	600	4	1.7453	108.79	600.0
20	13	14	524	1	21.0000	0.00	524.0
21	15	13	550	3	2.8587	224.42	550.0
22	9	15	318	2	1.7453	92.93	318.0
23	16	15	600	1	2.9963	222.72	600.0
24	2	16	2600	2	1.7453	82.69	2600.0
25	17	16	1050	4	3.4142	218.75	1050.0
26	18	17	228	2	6.3972	216.02	228.0
27	20	17	800	2	0.7426	116.93	800.0
28	20	18	1217	2	0.7426	116.93	1217.0
29	19	20	333	2	0.7426	114.50	333.0
35	4	24	2400	2	21.0000	28.70	2400.0
36	24	25	2600	2	21.0000	40.84	2600.0
37	24	27	3200	2	21.0000	40.84	3200.0
38	27	28	230	4	14.1881	110.66	230.0
39	28	31	2292	4	14.1881	112.73	2292.0
40	25	26	2000	2	21.0000	69.76	2000.0
41	26	30	1700	2	21.0000	92.00	1700.0
42	26	29	1050	2	21.0000	92.00	1050.0
43	2	27	1650	2	1.7453	82.69	1650.0
44	28	29	750	4	14.1881	112.73	750.0
45	29	30	300	1	15.1797	143.96	300.0
46	2	30	525	2	1.7453	82.69	525.0
47	30	31	297	5	12.7951	146.12	297.0
48	30	18	4100	5	12.7951	146.12	4100.0
50	32	1	30	5	15.1512	173.63	30.0
49	31	32	2031	4	15.1512	160.30	2031.0
51	32	1	100	5	15.1512	173.63	100.0

AIRWAY	WAVE 1				WAVE 2				WAVE 3			
	CONC %	LOCATION FT	START TIME	ARRIVAL TIME	CONC %	LOCATION FT	START TIME	ARRIVAL TIME	CONC %	LOCATION FT	START TIME	ARRIVAL TIME
2	1.6267	325.0	65.94	67.89	1.7453	325.0	82.69	84.64				
3	19.5726	2577.0	11.94	31.47	21.0000	2577.0	28.70	48.23				
5	19.5726	2900.0	11.94	65.94	21.0000	2900.0	28.70	82.69				
6	19.5726	100.0	11.77	11.94	21.0000	100.0	28.53	28.70				
7	19.5726	2700.0	7.13	11.77	21.0000	2700.0	23.88	28.53				
8	21.0000	524.0	3.99	23.88								
9	21.0000	1700.0	3.99	7.13								
10	21.0000	1650.0	1.15	3.99								
11	21.0000	4500.0	1.15	45.61								
12	1.6267	2700.0	67.89	74.36	1.7453	2700.0	84.64	91.11				
13	1.6267	2050.0	74.36	97.75	1.7453	2050.0	91.11	114.50				
14	1.6267	600.0	74.36	76.18	1.7453	600.0	91.11	92.93				
15	1.6267	600.0	76.18	78.28	1.7453	600.0	92.93	95.03				
16	1.6267	600.0	78.28	90.36	1.7453	600.0	95.03	107.11				
17	1.6267	1100.0	78.28	82.94	1.7453	1100.0	95.03	99.69				
18	1.3441	319.0	82.94	84.61	1.6267	319.0	90.36	92.03	1.7247	319.0	99.69	101.36
19	1.3441	600.0	84.61	86.71	1.6267	600.0	92.03	94.13	1.7247	600.0	101.36	103.46
20	21.0000	524.0	0.00	1.15								
21	2.6425	550.0	199.51	200.90	2.8440	550.0	207.67	209.05	2.8587	550.0	224.42	225.81
22	1.6267	318.0	76.18	87.11	1.7453	318.0	92.93	103.87				
23	2.9963	600.0	222.72	224.42								
24	1.6267	2600.0	65.94	95.35	1.7453	2600.0	82.69	112.11				
25	3.0863	1050.0	189.02	192.99	3.0901	1050.0	193.84	197.81	3.3922	1050.0	202.00	205.97
26	6.3506	228.0	199.26	202.00	6.3972	228.0	216.02	218.75				
27	0.6922	800.0	100.18	105.91	0.7426	800.0	116.93	122.66				
28	0.6922	1217.0	100.18	118.51	0.7426	1217.0	116.93	135.27				
29	0.6922	333.0	97.75	100.18	0.7426	333.0	114.50	116.93				
35	19.5726	2400.0	11.94	24.08	21.0000	2400.0	28.70	40.84				
36	19.5726	2600.0	24.08	53.00	21.0000	2600.0	40.84	69.76				
37	19.5726	3200.0	24.08	53.78	21.0000	3200.0	40.84	70.53				
38	12.6482	230.0	53.78	55.84	13.5706	230.0	70.53	72.60	14.1461	230.0	93.90	95.97
39	12.6482	2292.0	55.84	103.42	13.5706	2292.0	72.60	120.17	14.1461	2292.0	95.97	143.54
40	19.5726	2000.0	53.00	75.25	21.0000	2000.0	69.76	92.00				
41	19.5726	1700.0	75.25	99.63	21.0000	1700.0	92.00	116.39				
42	19.5726	1050.0	75.25	127.21	21.0000	1050.0	92.00	143.96				
43	1.6267	1650.0	65.94	93.90	1.7453	1650.0	82.69	110.66				
44	12.6482	750.0	55.84	62.17	13.5706	750.0	72.60	78.92	14.1461	750.0	95.97	102.29
45	15.1797	300.0	143.96	146.12								
46	1.6267	525.0	65.94	72.36	1.7453	525.0	82.69	89.12				
47	10.9730	297.0	104.46	107.66	11.3158	297.0	116.39	119.59	11.3330	297.0	121.21	124.42
48	10.9730	4100.0	104.46	174.35	11.3158	4100.0	116.39	186.29	11.3330	4100.0	121.21	191.11
50	14.1843	30.0	137.74	139.24	15.0127	30.0	145.90	147.40	15.0855	30.0	156.87	158.37
49	15.0127	2031.0	132.57	145.90	15.0855	2031.0	143.54	156.87	15.1459	2031.0	149.33	162.66
51	14.1843	100.0	137.74	138.05	15.0127	100.0	145.90	146.20	15.0855	100.0	156.87	157.17

AIRWAY	WAVE 4				WAVE 5			
	CONC %	LOCATION FT	START TIME	ARRIVAL TIME	CONC %	LOCATION FT	START TIME	ARRIVAL TIME
18	1.7453	319.0	107.11	108.79				
19	1.7453	600.0	108.79	110.89				
25	3.4142	1050.0	218.75	222.72				
38	14.1881	230.0	110.66	112.73				
39	14.1881	2292.0	112.73	160.30				
44	14.1881	750.0	112.73	119.05				
47	12.6957	297.0	129.37	132.57	12.7951	297.0	146.12	149.33
48	12.6957	4100.0	129.37	199.26	12.7951	4100.0	146.12	216.02
50	15.1459	30.0	162.66	164.15	15.1512	30.0	173.63	175.12
49	15.1512	2031.0	160.30	173.63				
51	15.1459	100.0	162.66	162.96	15.1512	100.0	173.63	173.93


AT 360 MIN. AFTER THE START OF CONTAMINATION CRITICAL
FUME CONCENTRATIONS (FUMES > 0.001) % NOW EXIST IN THE
FOLLOWING JUNCTIONS

JUNCTION	CURRENT FUME CONCENTRATION	TIME OF FIRST CONTAMINATION
2	1.7453	82.69
3	1.7453	84.64
4	21.0000	28.70
5	21.0000	28.53
6	21.0000	23.88
7	21.0000	3.99
8	1.7453	91.11
9	1.7453	92.93
10	1.7453	95.03
11	1.7453	107.11
12	1.7453	108.79
13	2.3924	225.81
14	21.0000	1.15
15	2.8587	224.42
16	2.9963	222.72
17	3.4142	218.75
18	6.3972	216.02
19	0.7426	114.50
20	0.7426	116.93
24	21.0000	40.84
25	21.0000	69.76
26	21.0000	92.00
27	14.1881	110.66
28	14.1881	112.73
29	15.1797	143.96
30	12.7951	146.12
31	15.1512	160.30
32	15.1512	173.63

AT 360 MIN. AFTER THE START OF CONTAMINATION THE TOTAL EXPOSURE TO
THE CONTAMINANT MEASURED IN PPM*HOURS WAS IN THE FOLLOWING JUNCTIONS

JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE	JUNCTION	TOTAL EXPOSURE
1	0.00	2	85206.52	3	84639.94
4	1214207.50	5	1214809.75	6	1231066.25
7	1246034.63	8	82757.16	9	82227.48
10	81616.95	11	79887.11	12	79400.20
13	91582.59	14	1255969.38	15	101463.10
16	105082.70	17	116837.52	18	215253.45
19	32318.50	20	32018.34	21	0.00
22	0.00	23	0.00	24	1171717.25
25	1070508.75	26	992655.88	27	717301.69
28	712410.31	29	713956.75	30	580224.63
31	716751.50	32	683096.44		

END OF RUN





REPORT DOCUMENTATION PAGE		1. REPORT NO. BuMines IC 8901	2.
4. Title and Subtitle Real-Time Calculation of Product of Combustion Spread in a Multilevel Mine		5. Report Date January 1983	
7. Author(s) John C. Edwards and Rudolf E. Greuer		6.	
3. Performing Organization Name and Address Twin Cities Research Center 5629 Minnehaha Avenue South Minneapolis, Minnesota 55417		8. Performing Organization Rept. No.	
12. Sponsoring Organization Name and Address Assistant Director, Division of Mining Research Bureau of Mines U.S. Department of the Interior Washington, D. C. 20241		10. Project/Task/Work Unit No.	
		11. Contract(C) or Grant(G) No. (C) (G)	
		13. Type of Report & Period Covered Information Circular	
15. Supplementary Notes		14.	
16. Abstract (Limit 200 words) <p>A computer program, developed for the Bureau of Mines under contract, predicts in a quasi-steady-state approximation the ventilation and contaminant concentrations and temperatures when a fire occurs in a multilevel mine. For periods of time in which there is no significant change in the ventilation, yet a fire is producing fumes, a real-time fume concentration throughout the mine is calculated. Multiple and time-variable contaminant sources can be simulated. Recirculation paths that can develop provide a mechanism for increasing the fume concentration in the mine network and are identified by the computer program. This report contains a listing of the Fortran computer program as well as the required format of the input data. Two examples are provided of the real-time spread of smoke from a fuel-rich fire throughout a multilevel mine. The first example considers an operational exhaust fan as well as a booster fan. The second example evaluates the real-time smoke spread following a failure in the exhaust fan; recirculation occurs in this latter case.</p>			
17. Document Analysis			
a. Descriptors Mine Ventilation Computerized Simulation			
b. Identifiers/Open-Ended Terms Ventilation Mathematical Model			
c. COSATI Field/Group 08 09 Mining Engineering; 13 01 Ventilation			
18. Availability Statement Release to the Public		19. Security Class (This Report) Unclassified	21. No. of Pages 10
		20. Security Class (This Page)	22. Price

