Laboratory evaluation of smoke detectors for use in underground mines Charles D. Litton *

National Institute for Occupational Safety and Health, Pittsburgh Research Laboratory/Disaster Prevention and Response Branch, Box 626, Cochrans Mill Road, Pittsburgh, PA 15236, USA

ABSTRACT

Laboratory experiments were conducted to determine the responses of a prototype smoke detector and a commercially available photoelectric smoke detector to smoke particles generated from various combustion sources. The prototype smoke detector combines optical scattering measurements with ionization chamber measurements in order to reduce/eliminate nuisance alarms due to the presence of airborne dusts or diesel exhaust particles. The commercially available smoke detector is designed for use in harsh environments where airborne dust represents a major problem due to both nuisance alarms and detector contamination. In the experiments, the responses of the two detectors were measured when exposed to smoke particles from the exhaust of a diesel engine and from a variety of fire sources, including wood, coal, styrene butadiene rubber, and No. 2 diesel fuel. For the solid fuels, data were obtained for both smoldering and flaming combustions. This report describes the experiments, their results, and the use of these results as they apply to early-warning fire sensors capable of the rapid and reliable detection of fires in atmospheres that may or may not be contaminated by either airborne dust or the products produced from diesel engines.

1. Introduction

1.1. Background

Fire sensors that detect the smoke and gases produced during the early stages of developing fires are often compromised by the presence of background levels of aerosols or gases that mimic the signatures of the developing fires, often resulting in frequent false or nuisance, sensor alarms. When this frequency is high, the tendency is to either ignore sensor alarms, or to de-energize the sensors, with the potentially catastrophic consequence that an actual fire is not detected. For instance, previous surveys of installed residential smoke detectors [1] indicated that nearly 20% of the detectors did not have functioning power sources, and of these, about one-third was intentionally disconnected because of nuisance alarms. In another study [2], 273 smoke detectors were examined by fire departments subsequent to the extinguishment of residential fires that went undetected. Of these, 159 (59%) were found to be disconnected from the power source. Nuisance alarms can occur in industrial settings, as well, with similar actions and consequences-real alarms that may be ignored or sensors that are disconnected from their power source-resulting in fires that destroy both life and property. A recent workshop [3] highlighted

E-mail address: chl3@cdc.gov

the problems associated with nuisance alarms in aircraft cargo areas and critical telecommunications systems and stressed the need to develop improved fire sensing systems and test procedures for installed fire detection systems. Fire detection in underground mines and tunnels is often compromised by exhaust products from diesel engines or other vehicles, or by routine procedures, such as welding or cutting. In mines, and to a somewhat lesser degree in tunnels, dust is an ever-present problem.

A significant level of research is being done to resolve some of these problems. For smoke, efforts continue to more accurately and completely define the properties of smoke produced from different sources [4-7] and to develop improved techniques for smoke measurement [8]. Characterizing the signatures of interfering sources using multi-sensor arrays coupled with neural networks or other multi-signature alarm algorithms [9-11] offers promise in many applications. But the use of these multi-sensor approaches is generally application-specific in that different applications may require different sensors and the necessary algorithms can vary significantly from one application to the next. In some of these approaches, it is not only the relative signals from different sensors, but also the manner in which these signals vary with time, that allow for the discrimination. However, incorporating time into the detection process can delay the alarm and thus be detrimental to the early-warning capability of the system. In underground mines, multi-sensor approaches and simpler gas ratio techniques [12,13] have also been used with varying degrees

^{*} Tel.: 4123866752; fax: 4123866595.

of success. In general, the use of multi-sensor packages and software to process the signals and make decisions increases both the complexity and the cost of the system, not only in terms of base, initial expense, but also in terms of system maintenance and sensor replacement.

One alternative to these approaches is the development of simple, stand-alone fire sensors that capitalize on the differences between common, interfering aerosol and/or gas backgrounds and those that result from developing fires so that the discrimination occurs via the sensor and its associated electronics rather than from a potentially more complex processing algorithm. This paper describes the laboratory evaluation of two candidate smoke sensors for the detection of fires in underground mines, where major background sources are dust and the emissions from diesel engines that are used routinely in day-to-day mining operations.

1.2. The sensors

The prototype smoke detector, the first sensor that was evaluated during this study, utilized the responses of both an ionization chamber and an optical scattering chamber to discriminate between nuisance sources that are not fire-related. Previous research [14-16] has described this approach and presented the relevant data using discrete ionization chambers and optical scattering chambers. Briefly, the prototype consists of an ionization chamber, typical in design to those used in commercial smoke detectors, where smoke particles are sensed due to the depletion of ions within the air space between two electrodes, and an optical scattering chamber where the collimated light beam from a laser diode is scattered by smoke particles into silicon photo-detectors at forward angles of 15° and 30°. Fig. 1 is a schematic of the two chambers. In this study, a prototype instrument was fabricated that combined both chambers into one package, together with improved electronics for



Fig. 1. Schematic of the ionization chamber (top) and the optical scattering chamber (bottom) used in the prototype detector.



Fig. 2. Photograph of prototype smoke detector evaluated during this study.

storage and processing of the data. A photograph of the fabricated prototype, opened to show the locations of the ionization and scattering chambers, is shown in Fig. 2.

The commercial smoke detector, the second sensor that was evaluated in these experiments, was a photoelectric type that measures light scattered at a forward angle of 45°. This detector is designed to operate in harsh environments containing dusts and water mists that can interfere with and degrade the performance of typical smoke detectors. To do this, the detector uses an internal fan that is activated every 35 s to sample the surrounding air for a period of 5 s. Within this 5 s interval, the air is flowed through a $32\,\mu m$ filter to remove the dust particles and water droplets that may be present. The air then flows through the scattering chamber where air is sampled for smoke particles before it exhausts to the outside air. Internal sensors detect clogged filters that are easily replaced or signal that the fan is malfunctioning. While this sensor contains no capability to discriminate nuisance particles from smoke particles, it uses flow through a filter to eliminate the dust and it uses light scattering which is relatively insensitive to the very small particles from diesel exhausts, thus reducing the frequency of alarms from these nuisance sources. A schematic of this sensor showing the flow of air and particles during the 5s sampling interval is shown in Fig. 3. The experiments were conducted to assess the reproducibility of previous experiments and thus the reliability of using either the prototype or commercial sensor for early-warning fire detection.

2. Experimental

Combustion experiments to produce smoke particles were conducted in the configuration shown in Fig. 4 and described in more detail in Ref. [17], where smoke particles from either flaming or smoldering combustion are generated in a cubical enclosure measuring 0.30 m along each edge and then flowed into a standard UL 217 smoke box [18] through a variable-orifice iris



Fig. 3. Schematic illustrating the flow of air during the 5 sec sampling period of the commercial smoke sensor.

that controlled the rate of aerosol accumulation within the smoke box. Inside the smoke box, three of the commercial smoke detectors were placed on a platform and two small internal fans were used to mix the incoming smoke particles to produce a uniform distribution throughout the chamber. The optical density of the aerosol was measured over a 1.483 m optical path using an incandescent lamp and a standard photocell with a peak response at a wavelength of 546 nm and a spectral response matching the spectral response of the human eye. During the experiments, smoke particle samples were continuously extracted through a metal tube inserted into the top of the smoke box very close to the location of the three commercial sensors and then flowed to three of the prototype smoke detectors. In this configuration, data were obtained for flaming No. 2 diesel fuel (a small pool flame), flaming coal, flaming wood, flaming styrene butadiene rubber (SBR), smoldering coal, smoldering wood, and smoldering SBR.

For diesel exhaust particles, the experimental system in which the tests were conducted, known generically as a dust box, is shown in Fig. 5 and described in greater detail in Ref. [19]. Briefly, dusts or diesel exhaust particles are dispersed near the top of the dust box, allowed to mix thoroughly and then fall via gravity coupled with a small, imposed flow. Samples of diesel exhaust particles are extracted through 10 mm cyclones near the bottom of the dust box at nominal flow-rates of 2 lpm and flowed to three prototype smoke detectors. In this configuration, data were acquired for particles produced from the exhaust of a diesel generator under different load conditions.

During the diesel exhaust experiments, a Tapered Element Oscillating Microbalance (TEOM) [20] was used to continuously measure the mass concentrations of aerosol. In the TEOM, a small filter is mounted onto what amounts to a hollow tuning fork vibrating at a fixed frequency. Particles in the flow through this filter are deposited on the filter increasing the filter mass. As the filter mass increases, the frequency of vibration decreases proportionally so that the change in mass due to accumulation of particles on the filter is measured as a function of time. The rate of change of the filter mass (due to smoke particles) divided by the volumetric flow rate through the filter yields the average mass concentration.

3. Results and analysis

3.1. Experiments using only the prototype smoke detector

Because of their simplicity, the combustion experiments using the UL 217 smoke box could be conducted quickly resulting in a large number of experiments so that several tests under identical





Fig. 4. Schematic of the smoke box and sample chamber in which the combustion experiments were conducted.

conditions could be used to assess the reproducibility of the data and the variations that occurred from one test to the next. In general, combustion aerosol mass concentrations varied over the range from roughly 0.5 mg/m^3 to approximately 30 mg/m^3 , although in the data and analysis that follow, particular attention was paid to mass concentrations $< 10 \text{ mg/m}^3$, since it is within this mass concentration range that early-warning fire detectors generally alarm. The basic data acquired for the prototype sensor are summarized as averages in Table 1, where the averages represent measurements from typically 2 to 4 tests for each combustion source and combustion mode. It is also worth noting that, although differences for one source or mode, from one test to the next, did occur, these differences were generally within ± 15 –20% of the average reported. For each test, the ion chamber and angular scattering signals were found to vary linearly with the well-mixed aerosol mass concentrations in the smoke box. The resultant sensitivities, in V/(mg/m³), were defined to be the slopes from linear regressions of the signals as functions of the mass concentrations. In general, the linear regression analyses yielded r^2 -values greater than 0.90 and typically in the range 0.95–0.98. In the table, the response of the ionization chamber is given by the quantity *CEV*, in volts, corresponding to the change in potential of the floating, collection electrode. The response of the photodetectors, also in volts, represents the changes in signal at 15° and 30°, *V*(15) and *V*(30), respectively. The aerosol mass concentration in the smoke box, *M*, is in mg/m³.

As discussed in a previous paper [14], it is convenient to look at the ratios of the ionization chamber responses to the optical scattering responses as a means for discriminating between fire smoke particles and diesel exhaust particles. These ratios are



Fig. 5. Schematic (A) and photograph (B) of the dust box where the response to diesel exhaust particles was measured.

Table 1

Measured sensitivities, V/(mg/m³), for diesel exhaust particles and various combustion aerosols using the bipolar ion chamber with floating collection electrode and the dual angle scattering module at 15° and 30° for the prototype smoke detector

Aerosol source	CEV/M	V(15)/M	V(30)/M	
Diesel exhaust	0.455	0.0047	Not measured	
Flaming				
No. 2 diesel fuel	0.0778	0.01056	0.0020	
Pittsburgh seam coal	0.0796	0.0115	0.00267	
SBR	0.0934	0.01095	0.0023	
Douglas fir	0.1270	0.00976	0.00136	
Smoldering				
Pittsburgh seam coal	0.0466	0.0131	0.0041	
SBR	0.0426	0.0138	0.0041	
Douglas fir	0.0313	0.0200	0.0051	

Sensitivities for each combustion source represent the average of 2–4 separate experiments.

Table 2

Sensitivity ratios for the three types of aerosols measured during these experiments

<i>CEV/V</i> (15)	<i>CEV/V</i> (30)	
98.2 9.17 2.81	Not measured 53.0 9.64	
	CEV/V(15) 98.2 9.17 2.81	

displayed in Table 2, where the ratio, CEV/V(15), for diesel exhaust particles is more than a factor of 10 greater than the average ratio for flaming combustion particles and almost a factor of 35 greater than the average ratio for smoldering combustion particles. It is worth noting at this point that from previous data [21] the response of the ionization chamber to dust particles (typically those in the respirable range from about 0.80 to $10\,\mu\text{m}$) is approximately 0.

When all of the data for both CEV/M and V(15)/M are plotted as a function of the ratio, CEV/V(15), the curves of Fig. 6 result, indicating that there are definite correlations. For the ionization chamber, this correlation is given by

and for the optical scattering at 15°, by

$$V(15)/M = 0.02145/[CEV/V(15)]^{-1/3}$$
⁽²⁾

A similar correlation (not shown) also exists for the ratio of ionization chamber response to the response of the optical scattering at 30°. These correlations with ratios are important not only because they provide a clear mechanism for determining if the particles are produced from a fire or from a diesel engine but also because they can be used to calculate mass concentrations, surface area concentrations, and average particle diameters as outlined in a previous report [14]. Also shown in Fig. 6 are the data obtained from previous experiments.

3.2. Experiments using both the prototype and the commercial smoke detector

Because the commercial smoke detector was not available for the initial experiments conducted using only the prototype smoke detector, a second series of experiments were conducted and simultaneous data acquired for both detectors. This series of experiments used combustion sources and modes identical to those used in the initial series of experiments.

In general, the data for the commercial smoke detector tested indicated that the detector was very responsive to particles from the smoldering combustion mode, not responsive to the diesel exhaust particles, and either not responsive or marginally responsive to particles from the flaming combustion mode. To demonstrate the response of the commercial smoke detector to particles from both the smoldering and flaming modes, Fig. 7 is a plot of the response of this sensor to a typical experiment using wood as the combustible sample, along with the responses of the ionization chamber and the 15° optical scattering detector from the prototype smoke detector. The response during the later stages of the flaming wood fire occurred after flaming had ceased and the combustion had returned to a smoldering mode. For data obtained during the flaming combustion mode, the superior response of the ionization chamber is clearly evident due to the much smaller particle diameters generated during the flaming combustion mode.

For all of the data for the smoldering combustion mode, the commercial smoke detector alarmed at an average value of 0.162 V for the 15° optical scattering signal and an average smoke particle mass concentration of 11.0 mg/m^3 . The average value of the ionization chamber signal at the commercial detector alarm varied from a low value of 0.22 V to a maximum value of 1.07 V.



Fig. 6. Plots of the ionization chamber and 15° optical scattering sensitivities as a function of their ratio for the prototype smoke detector. Also shown are data from previous experiments.



Fig. 7. Responses of the ion and optical chambers of the prototype smoke detector and the alarms of the commercial smoke detector to both smoldering and flaming wood smoke.

Table 3

Average values of the prototype ionization chamber response (ΔCEV), the 15° optical scattering response ($\Delta I(15)$), and the average smoke particle mass concentrations at the alarm point of the commercial detector to smoldering fires

Combustible sample	CEV (V)	V(15) (V)	Mass concentration (mg/m ³)
Pittsburgh seam coal	1.07	0.136	12.6
Douglas fir	0.28	0.200	8.9
Styrene butadiene rubber	0.22	0.182	10.3

The average signals from the 15° angular scattering and ionization chamber at the commercial smoke detector alarm are shown in Table 3. It is worth noting that in the flaming combustion mode experiments the maximum observed mass concentration never exceeded 8.0 mg/m^3 , and it is believed that the combination of these lower mass concentrations coupled with the smaller particle diameters is responsible for commercial smoke detector's poor response to the flaming fires.

4. Conclusions

The results of this study indicate that the prototype smoke detector fabricated to combine both the ionization chamber and the optical scattering chamber functions as expected. The responses of the two components are similar to the responses previously measured as separate components. The utilization of the ratio of ionization chamber signal to optical scattering signal shows potential for use in the discrimination of very fine particles, such as those from diesel exhausts, and very coarse particles, such as mine dusts. The commercial smoke detector showed adequate response to smoldering combustion, but did not exhibit good response to flaming fires. However, the potential for the detector to be insensitive to both very small particles, such as those from diesel exhausts, because it operates on the principle of light scattering and to the larger particles as a result of the flow and filter incorporated into the detector warrant further test and evaluation under typical mine conditions.

References

- Charles L. Smith, Smoke detector operability survey, Report on Findings, US Consumer Product Safety Commission, October 1994, 98pp.
- [2] Linda E. Smith, Fire incident study, National Smoke Detector Project, US Consumer Product Safety Commission, January 1995, 61pp.
- [3] William L. Grosshandler (Ed.), Nuisance Alarms in Aircraft Cargo Areas and Critical Telecommunications Systems: Proceedings of the Third NIST Fire Detector Workshop, NISTIR 6146, BFRL, NIST, March 1998, 34pp.
- [4] G.W. Mulholland, C. Croarkin, Specific extinction coefficient of flame generated smoke, Fire Mater. 24 (5) (2000) 227–230.
- [5] M.Y. Choi, G.W. Mulholland, A. Hamins, T. Kashiwagi, Experimental study of the optical properties of soot and smoke, NISTIT 5499, NIST, in: Annual Conference on Fire Research: Book of Abstracts, October 1994, pp. 123–124.
- [6] C.M. Sorensen, G.D. Feke, Post-flame soot, in: Proceedings of the International Conference on Fire Research and Engineering (ICFRE), September 1995, pp. 281–285.
- [7] Smoke Characterization Project, Final Report, Project Number: 06CA08584.
 File Number: NC 5756, Underwriters Laboratories Inc., Northbrook, IL 60062, April 24, 2007.
- [8] G.W. Mulholland, E.L. Johnsson, D.A. Shear, M.G. Fernandez, Design and testing of a new smoke concentration meter, in: Proceedings of the Fall Conference on Fire Retardant Chemicals Association (FRCA), October 1998, pp. 41–49.
- [9] D.T. Gottuk, M.J. Peatross, R.J. Roby, C.L. Beyler, Advanced fire detection using multi-signature alarm algorithms, in: Proceedings of the International Conference on Automatic Fire Detection "AUBE 99," March 1999, pp. 237–246.

- [10] J.A. Milke, Application of neural networks for discriminating fire detectors, in: Proceedings of the International Conference on Automatic Fire Detection AAUBE > 95, April 1995, pp. 213–222.
- [11] W.L. Grosshandler, Review of measurements and candidate signatures for early fire detection, NISTIR 5555, BFRL, NIST, January 1995, 36pp.
- [12] M. Brinn, B. Bott, A fresh approach to mine fire detection, Trans. Inst. Min. Eng. (1994) 71-74.
- [13] Charles D. Litton, Ronald S. Conti, John G. Tabacchi, Grace Richard, Evaluation of a nitric oxide-compensated carbon monoxide fire sensor, BuMines IC 9339, 1993, 10pp.
- [14] C.D. Litton, The use of light scattering and ion chamber responses for the detection of fires in diesel contaminated atmospheres, Fire Saf. J. 27 (2002) 409–425.
- [15] C.D. Litton, Kirk R. Smith, Rufus Edwards, Tracy Allen, Combined optical and ionization measurement techniques for inexpensive characterization of micrometer and submicrometer aerosols, Aerosol Sci. Technol. 38 (2004) 1054–1062.
- [16] Rufus Edwards, Kirk R. Smith, Brent Kirby, Tracy Allen, Charles D. Litton, Susanne Hering, An inexpensive dual-chamber particle monitor: laboratory characterization, J. Air Waste Manage. Assoc. 56 (2006) 789–799.
- [17] UL 217-Single and Multiple Station Smoke Alarms, Underwriters Laboratories Inc., Northbrook, IL, 60062.
- [18] J.C. Edwards, G.S. Morrow, Development of coal combustion sensitivity tests for smoke detectors, US Bureau of Mines Report of Investigations 9551, 1995, 12pp.
- [19] V.A. Marple, K.L. Rubow, An aerosol chamber for instrument evaluation and calibration, Am. Ind. Hyg. Assoc. J. 44 (1983) 361–367.
- [20] H. Patashnick, G. Rupprecht, Microweighing goes on-line in real time, Res. Dev. 28 (6) (1986) 74-78.
- [21] C.D. Litton, Studies of the measurement of respirable coal dusts and diesel particulate matter, Meas. Sci. Technol. 13 (2002) 365–374.